

# DALTON FIRE DEPARTMENT

**TODD PANGLE**  
Fire Chief  
Telephone 706-278-7363  
Fax 706-272-7107  
tpangle@daltonga.gov

404 School Street  
Dalton, GA 30720



## PUBLIC SAFETY COMMISSION

Bill Weaver  
Keith Whitworth  
Terry Mathis  
Kenneth E. Willis  
Anthony Walker

## Monthly Synopsis

November 2019

### Incident Response

<u>Category</u>	<u>Responses</u>	<u>Percentage</u>
Fire	8	2.63%
Overpressure Rupture, Overheat	1	0.32%
Rescue/Medical	210	69.07%
Hazardous Condition	10	3.28%
Service Call	8	2.63%
Good Intent	45	14.08%
False Alarm	22	7.23%
<b>Total Responses</b>	<b>304</b>	
<b>Average Response Time</b>	<b>3:24</b>	
<b>Estimated Loss</b>	<b>\$42,100</b>	

## DALTON

## Incident Type Report (Monthly Summary )

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
1 Fire				
111 Building fire	2	0.65%	\$25,000	59.38%
113 Cooking fire, confined to container	2	0.65%	\$0	0.00%
131 Passenger vehicle fire	3	0.98%	\$17,100	40.61%
142 Brush or brush-and-grass mixture fire	1	0.32%	\$0	0.00%
	<b>8</b>	<b>2.63%</b>	<b>\$42,100</b>	<b>100.00%</b>
2 Overpressure Rupture, Explosion, Overheat (no fire)				
251 Excessive heat, scorch burns with no	1	0.32%	\$0	0.00%
	<b>1</b>	<b>0.32%</b>	<b>\$0</b>	<b>0.00%</b>
3 Rescue & Emergency Medical Service Incident				
311 Medical assist, assist EMS crew	182	59.86%	\$0	0.00%
322 Motor vehicle accident with injuries	12	3.94%	\$0	0.00%
323 Motor vehicle/pedestrian accident (MV Ped)	1	0.32%	\$0	0.00%
324 Motor Vehicle Accident with no injuries	13	4.27%	\$0	0.00%
353 Removal of victim(s) from stalled elevator	1	0.32%	\$0	0.00%
357 Extrication of victim(s) from machinery	1	0.32%	\$0	0.00%
	<b>210</b>	<b>69.07%</b>	<b>\$0</b>	<b>0.00%</b>
4 Hazardous Condition (No Fire)				
412 Gas leak (natural gas or LPG)	2	0.65%	\$0	0.00%
423 Refrigeration leak	1	0.32%	\$0	0.00%
442 Overheated motor	3	0.98%	\$0	0.00%
444 Power line down	1	0.32%	\$0	0.00%
445 Arcing, shorted electrical equipment	2	0.65%	\$0	0.00%
462 Aircraft standby	1	0.32%	\$0	0.00%
	<b>10</b>	<b>3.28%</b>	<b>\$0</b>	<b>0.00%</b>
5 Service Call				
500 Service Call, other	1	0.32%	\$0	0.00%
522 Water or steam leak	1	0.32%	\$0	0.00%
531 Smoke or odor removal	1	0.32%	\$0	0.00%
553 Public service	1	0.32%	\$0	0.00%
561 Unauthorized burning	4	1.31%	\$0	0.00%
	<b>8</b>	<b>2.63%</b>	<b>\$0</b>	<b>0.00%</b>

**DALTON****Incident Type Report (Monthly Summary )****Alarm Date Between {11/01/2019} And {11/30/2019}**

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
6 Good Intent Call				
600 Good intent call, Other	1	0.32%	\$0	0.00%
611 Dispatched & cancelled en route	36	11.84%	\$0	0.00%
622 No Incident found on arrival at dispatch	4	1.31%	\$0	0.00%
631 Authorized controlled burning	1	0.32%	\$0	0.00%
651 Smoke scare, odor of smoke	3	0.98%	\$0	0.00%
	<b>45</b>	<b>14.80%</b>	<b>\$0</b>	<b>0.00%</b>
7 False Alarm & False Call				
715 Local alarm system, malicious false alarm	1	0.32%	\$0	0.00%
731 Sprinkler activation due to malfunction	1	0.32%	\$0	0.00%
733 Smoke detector activation due to	2	0.65%	\$0	0.00%
735 Alarm system sounded due to malfunction	5	1.64%	\$0	0.00%
743 Smoke detector activation, no fire -	8	2.63%	\$0	0.00%
745 Alarm system activation, no fire -	5	1.64%	\$0	0.00%
	<b>22</b>	<b>7.23%</b>	<b>\$0</b>	<b>0.00%</b>

Total Incident Count: 304

Total Est Loss:

\$42,100

**DALTON**

**Dollar Value Saved & Loss Analysis (Monthly)**

**Alarm Date Between {11/01/2019} And {11/30/2019}**

<b>Incident Type</b>	<b>Count</b>	<b>Total Values</b>	<b>Total Losses</b>	<b>Total Saved</b>	<b>Percent Lost</b>	<b>Percent Saved</b>
111 Building fire	2	\$206,689	\$25,000	\$181,689	12.10%	87.90%
131 Passenger vehicle fire	3	\$19,200	\$17,100	\$2,100	89.06%	10.94%
<b>Grand Totals</b>	<b>5</b>	<b>\$225,889</b>	<b>\$42,100</b>	<b>\$183,789</b>		

**Total Percent Lost: 18.64 %**

**Total Percent Saved: 81.36 %**

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003267	0	11/01/2019	00:27:21	905 Hamilton (South)	611 Dispatched & cancelled en route	
19-0003268	0	11/01/2019	01:47:58	1411 Chattanooga	611 Dispatched & cancelled en route	
19-0003269	0	11/01/2019	07:02:35	Hamilton (South)	311 Medical assist, assist EMS crew	
19-0003270	0	11/01/2019	08:03:05	McGhee	324 Motor Vehicle Accident with no	
19-0003271	0	11/01/2019	11:38:24	1004 Cartwright	311 Medical assist, assist EMS crew	
19-0003272	0	11/01/2019	11:52:54	Morris (East)	412 Gas leak (natural gas or LPG)	
19-0003273	0	11/01/2019	13:18:47	Crawford (West)	322 Motor vehicle accident with	
19-0003274	0	11/01/2019	13:41:27	Tibbs (South)	324 Motor Vehicle Accident with no	
19-0003275	0	11/01/2019	15:48:06	2007 Shields	311 Medical assist, assist EMS crew	
19-0003276	0	11/01/2019	18:52:55	Tibbs (South)	611 Dispatched & cancelled en route	
19-0003277	0	11/01/2019	21:16:46	102 Springdale	311 Medical assist, assist EMS crew	
19-0003278	0	11/01/2019	22:09:35	Walnut (East)	322 Motor vehicle accident with	
19-0003279	0	11/02/2019	04:22:25	300 Smith Industrial	611 Dispatched & cancelled en route	
19-0003280	0	11/02/2019	05:26:36	1000 Rockdale	311 Medical assist, assist EMS crew	
19-0003281	0	11/02/2019	14:32:17	Waugh (East)	611 Dispatched & cancelled en route	
19-0003282	0	11/02/2019	18:36:55	820 Shugart	311 Medical assist, assist EMS crew	
19-0003283	0	11/02/2019	18:45:34	1424 Walston	311 Medical assist, assist EMS crew	
19-0003284	0	11/02/2019	20:45:42	1212 Elkwood	311 Medical assist, assist EMS crew	
19-0003285	0	11/02/2019	22:33:00	3017 Brookhaven (East)	311 Medical assist, assist EMS crew	
19-0003286	0	11/03/2019	09:27:12	928 Hardwick	311 Medical assist, assist EMS crew	
19-0003287	0	11/03/2019	10:30:43	1220 Broadrick	311 Medical assist, assist EMS crew	
19-0003288	0	11/03/2019	16:18:28	1365 Walnut (West)	311 Medical assist, assist EMS crew	
19-0003289	0	11/03/2019	17:04:26	422 Sassafras	311 Medical assist, assist EMS crew	
19-0003290	0	11/03/2019	18:36:52	623 Campus	311 Medical assist, assist EMS crew	
19-0003291	0	11/03/2019	22:43:42	1905 Middle Summit	311 Medical assist, assist EMS crew	
19-0003292	0	11/03/2019	23:19:00	703 Morningside	311 Medical assist, assist EMS crew	
19-0003293	0	11/04/2019	01:03:12	1527 Waring	311 Medical assist, assist EMS crew	
19-0003294	0	11/04/2019	02:12:01	1687 Southbrook	311 Medical assist, assist EMS crew	
19-0003295	0	11/04/2019	07:13:31	285 Kraft	311 Medical assist, assist EMS crew	
19-0003296	0	11/04/2019	09:15:38	515 Pentz (South)	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003297	0	11/04/2019	09:34:24	2107 Walnut (East)	553 Public service	
19-0003298	0	11/04/2019	10:22:16	1320 Winton	311 Medical assist, assist EMS crew	
19-0003299	0	11/04/2019	10:44:16	1320 Winton	743 Smoke detector activation, no fire	
19-0003300	0	11/04/2019	11:26:14	405 Virgil	311 Medical assist, assist EMS crew	
19-0003301	0	11/04/2019	11:30:30	519 Hawthorne (West)	622 No Incident found on arrival at	
19-0003302	0	11/04/2019	14:40:03	609 Thornton (South)	311 Medical assist, assist EMS crew	
19-0003303	0	11/04/2019	16:44:50	1320 Morris (East)	311 Medical assist, assist EMS crew	
19-0003304	0	11/04/2019	16:49:01	1905 Middle Summit	311 Medical assist, assist EMS crew	
19-0003305	0	11/04/2019	18:23:08	700 Phoenix	311 Medical assist, assist EMS crew	
19-0003306	0	11/04/2019	21:57:55	1703 Beechland	311 Medical assist, assist EMS crew	
19-0003307	0	11/05/2019	00:12:48	2581 Abutment	311 Medical assist, assist EMS crew	
19-0003308	0	11/05/2019	02:08:05	811 Willow Park (East)	611 Dispatched & cancelled en route	
19-0003309	0	11/05/2019	07:10:05	1218 Broadrick	715 Local alarm system, malicious	
19-0003310	0	11/05/2019	10:11:48	230 Brickyard	311 Medical assist, assist EMS crew	
19-0003311	0	11/05/2019	10:33:02	1749 Brighton	311 Medical assist, assist EMS crew	
19-0003312	0	11/05/2019	11:05:52	I-75 N. Bound	622 No Incident found on arrival at	
19-0003313	0	11/05/2019	11:10:25	201 Hamilton (South)	442 Overheated motor	
19-0003314	0	11/05/2019	11:45:02	1507 Byron	735 Alarm system sounded due to	
19-0003315	0	11/05/2019	13:24:19	1004 Cartwright	311 Medical assist, assist EMS crew	
19-0003316	0	11/05/2019	16:17:39	603 Jones	311 Medical assist, assist EMS crew	
19-0003317	0	11/05/2019	18:22:50	1007 Alabama	311 Medical assist, assist EMS crew	
19-0003318	0	11/05/2019	22:36:25	118 Hamilton (North)	651 Smoke scare, odor of smoke	
19-0003319	0	11/06/2019	08:09:52	162 Bear Creek	311 Medical assist, assist EMS crew	
19-0003320	0	11/06/2019	11:39:29	307 Fredrick (South)	311 Medical assist, assist EMS crew	
19-0003321	0	11/06/2019	12:16:31	700 Phoenix	311 Medical assist, assist EMS crew	
19-0003322	0	11/06/2019	13:07:49	Chattanooga	311 Medical assist, assist EMS crew	
19-0003323	0	11/06/2019	13:14:48	652 Haigmill Lake	311 Medical assist, assist EMS crew	
19-0003324	0	11/06/2019	14:33:19	1605 Underwood	735 Alarm system sounded due to	
19-0003325	0	11/06/2019	15:17:02	938 Market	311 Medical assist, assist EMS crew	
19-0003326	0	11/06/2019	15:52:18	1605 Underwood	735 Alarm system sounded due to	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003327	0	11/06/2019	17:45:56	813	Battlefield Pk	611 Dispatched & cancelled en route
19-0003328	0	11/06/2019	18:18:09	1523	Walnut (West)	324 Motor Vehicle Accident with no
19-0003329	0	11/06/2019	20:43:50	1302	Sherwood	311 Medical assist, assist EMS crew
19-0003330	0	11/06/2019	23:09:25	332	Haigmill Lake	631 Authorized controlled burning
19-0003331	0	11/07/2019	16:23:27	1616	Morris (East)	311 Medical assist, assist EMS crew
19-0003332	0	11/07/2019	18:15:28	865	Shugart	311 Medical assist, assist EMS crew
19-0003333	0	11/07/2019	19:46:13	500	Autumn	611 Dispatched & cancelled en route
19-0003334	0	11/07/2019	19:47:58	2311	Chattanooga	743 Smoke detector activation, no fire
19-0003335	0	11/07/2019	21:53:55	214	Easterling (North)	311 Medical assist, assist EMS crew
19-0003336	0	11/07/2019	21:54:58	1034	Factory	311 Medical assist, assist EMS crew
19-0003337	0	11/07/2019	23:30:56	347	Ivy Gate	311 Medical assist, assist EMS crew
19-0003338	0	11/08/2019	00:19:59	1306	Underwood	311 Medical assist, assist EMS crew
19-0003339	0	11/08/2019	12:46:32	1218	Broadrick	311 Medical assist, assist EMS crew
19-0003340	0	11/08/2019	14:36:48	816	Walnut Square	311 Medical assist, assist EMS crew
19-0003341	0	11/08/2019	15:52:18	900	Shugart	311 Medical assist, assist EMS crew
19-0003342	0	11/08/2019	16:58:12	2105	Walnut (East)	611 Dispatched & cancelled en route
19-0003343	0	11/08/2019	18:59:02		I-75 S. Bound	322 Motor vehicle accident with
19-0003344	0	11/08/2019	19:06:04	646	Hamilton (South)	444 Power line down
19-0003345	0	11/08/2019	20:49:56	901	West Bridge	735 Alarm system sounded due to
19-0003346	0	11/08/2019	21:29:58	901	West Bridge	611 Dispatched & cancelled en route
19-0003347	0	11/09/2019	00:17:34	404	Lesley	311 Medical assist, assist EMS crew
19-0003348	0	11/09/2019	00:29:12	207	Matilda. (West)	311 Medical assist, assist EMS crew
19-0003349	0	11/09/2019	01:28:55	MM329	I-75 S. Bound	611 Dispatched & cancelled en route
19-0003350	0	11/09/2019	01:35:39	MM332	I-75 S. Bound	611 Dispatched & cancelled en route
19-0003351	0	11/09/2019	10:14:49	312	Hewitt	611 Dispatched & cancelled en route
19-0003352	0	11/09/2019	11:17:12	1529	Walnut (West)	311 Medical assist, assist EMS crew
19-0003353	0	11/09/2019	16:05:50	433	Cedar	111 Building fire
19-0003354	0	11/09/2019	19:43:06		Chattanooga	622 No Incident found on arrival at
19-0003355	0	11/09/2019	22:15:01	407	Dantzler	311 Medical assist, assist EMS crew
19-0003356	0	11/09/2019	22:50:31	1406	Stacy	311 Medical assist, assist EMS crew

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003357	0	11/10/2019	01:27:47	Maddox Chapel	323 Motor vehicle/pedestrian accident	
19-0003358	0	11/10/2019	01:38:13	1116 Willowdale	311 Medical assist, assist EMS crew	
19-0003359	0	11/10/2019	06:24:26		322 Motor vehicle accident with	
19-0003360	0	11/10/2019	10:06:20	1621 Beechland	311 Medical assist, assist EMS crew	
19-0003361	0	11/10/2019	10:58:40	1912 Cascade	311 Medical assist, assist EMS crew	
19-0003362	0	11/10/2019	11:13:41	1104 Walston	442 Overheated motor	
19-0003363	0	11/10/2019	12:19:42	815 Shugart	611 Dispatched & cancelled en route	
19-0003364	0	11/10/2019	14:03:59	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0003365	0	11/10/2019	14:13:58	820 Shugart	311 Medical assist, assist EMS crew	
19-0003366	0	11/10/2019	18:49:26		322 Motor vehicle accident with	
19-0003367	0	11/11/2019	00:05:47	1218 Broadrick	311 Medical assist, assist EMS crew	
19-0003368	0	11/11/2019	13:00:58	105 Thornton (North)	311 Medical assist, assist EMS crew	
19-0003369	0	11/11/2019	15:23:00	1300 Hamilton (South)	731 Sprinkler activation due to	
19-0003370	0	11/11/2019	15:52:13	1600 Puryear	113 Cooking fire, confined to	
19-0003371	0	11/11/2019	18:23:42	1320 Winton	611 Dispatched & cancelled en route	
19-0003372	0	11/11/2019	20:14:04	1300 Georgian	311 Medical assist, assist EMS crew	
19-0003373	0	11/11/2019	20:24:11	914 Redwine	311 Medical assist, assist EMS crew	
19-0003374	0	11/11/2019	21:55:56	330 Hamilton (South)	743 Smoke detector activation, no fire	
19-0003375	0	11/11/2019	23:12:27	1108 Rio Vista	311 Medical assist, assist EMS crew	
19-0003376	0	11/12/2019	04:34:53	2505 Walnut (East)	311 Medical assist, assist EMS crew	
19-0003377	0	11/12/2019	04:36:28	500 Bluff Hill	311 Medical assist, assist EMS crew	
19-0003378	0	11/12/2019	06:06:06	1116 Willowdale	311 Medical assist, assist EMS crew	
19-0003379	0	11/12/2019	06:20:14	818 Shugart	311 Medical assist, assist EMS crew	
19-0003380	0	11/12/2019	07:58:10	2017 Shields	311 Medical assist, assist EMS crew	
19-0003381	0	11/12/2019	09:45:55	613 Oxford	311 Medical assist, assist EMS crew	
19-0003382	0	11/12/2019	10:06:59	98 Walnut (West)	131 Passenger vehicle fire	\$10,000
19-0003382	1	11/12/2019	10:06:59	98 Walnut (West)	131 Passenger vehicle fire	\$3,500
19-0003383	0	11/12/2019	10:25:42	405 Roberts	311 Medical assist, assist EMS crew	
19-0003384	0	11/12/2019	11:38:46	1200 Memorial	611 Dispatched & cancelled en route	
19-0003385	0	11/12/2019	11:56:11	1300 Waugh (West)	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003386	0	11/12/2019	12:52:40	104 Fort Hill	311 Medical assist, assist EMS crew	
19-0003387	0	11/12/2019	15:44:08	Thornton (South)	322 Motor vehicle accident with	
19-0003388	0	11/12/2019	15:56:07	321 Spencer (North)	311 Medical assist, assist EMS crew	
19-0003389	0	11/12/2019	16:12:32	1003 MLK Jr.	311 Medical assist, assist EMS crew	
19-0003390	0	11/12/2019	16:43:22	1246 Thornton (North)	311 Medical assist, assist EMS crew	
19-0003391	0	11/13/2019	01:13:43	1600 MLK Jr.	733 Smoke detector activation due to	
19-0003392	0	11/13/2019	02:19:25	I-75 S. Bound	611 Dispatched & cancelled en route	
19-0003393	0	11/13/2019	11:15:00	230 Brickyard	611 Dispatched & cancelled en route	
19-0003394	0	11/13/2019	13:54:08	104 Fort Hill	311 Medical assist, assist EMS crew	
19-0003395	0	11/13/2019	14:42:06	1300 Underwood	311 Medical assist, assist EMS crew	
19-0003396	0	11/13/2019	17:34:27	500 Walnut (East)	311 Medical assist, assist EMS crew	
19-0003397	0	11/13/2019	17:56:36	415 Benton	561 Unauthorized burning	
19-0003398	0	11/13/2019	18:35:00	1909 Walnut (East)	322 Motor vehicle accident with	
19-0003399	0	11/13/2019	20:42:12	187 Goose Hill (South)	611 Dispatched & cancelled en route	
19-0003400	0	11/13/2019	21:10:44	904 Valentine	311 Medical assist, assist EMS crew	
19-0003401	0	11/13/2019	22:19:26	1116 Willowdale	311 Medical assist, assist EMS crew	
19-0003402	0	11/13/2019	22:27:28	304 Water	311 Medical assist, assist EMS crew	
19-0003403	0	11/14/2019	01:05:52	4483 Airport	462 Aircraft standby	
19-0003404	0	11/14/2019	04:21:24	1116 Willowdale	522 Water or steam leak	
19-0003405	0	11/14/2019	04:43:58	Brady	311 Medical assist, assist EMS crew	
19-0003406	0	11/14/2019	08:25:50	Thornton (North)	324 Motor Vehicle Accident with no	
19-0003407	0	11/14/2019	09:56:09	807 Croy	311 Medical assist, assist EMS crew	
19-0003408	0	11/14/2019	12:51:47	1420 Mineral Springs	611 Dispatched & cancelled en route	
19-0003409	0	11/14/2019	13:02:57	187 Goose Hill (South)	611 Dispatched & cancelled en route	
19-0003410	0	11/14/2019	13:05:32	1827 Wood Valley	311 Medical assist, assist EMS crew	
19-0003411	0	11/14/2019	13:09:40	927 Hamilton (South)	745 Alarm system activation, no fire	-
19-0003412	0	11/14/2019	13:19:02	812 Greenwood	311 Medical assist, assist EMS crew	
19-0003413	0	11/14/2019	13:31:50	202 Easterling (North)	500 Service Call, other	
19-0003414	0	11/14/2019	18:22:26	603 Red Bird	311 Medical assist, assist EMS crew	
19-0003415	0	11/14/2019	18:49:25	1106 Nelson	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003416	0	11/14/2019	23:10:42	2305	Abutment	
19-0003417	0	11/15/2019	04:29:31	1801	Dug Gap	
19-0003418	0	11/15/2019	09:00:48	700	Phoenix	
19-0003419	0	11/15/2019	09:13:33	523	Lester	
19-0003420	0	11/15/2019	09:39:23	1310	Vann	
19-0003421	0	11/15/2019	10:18:11	509	McAfee	
19-0003422	0	11/15/2019	11:36:48	2105	Walnut (East)	
19-0003423	0	11/15/2019	12:10:43		Francis	
19-0003424	0	11/15/2019	15:52:56		Waugh (West)	
19-0003425	0	11/15/2019	16:35:36	618	Fifth	
19-0003426	0	11/15/2019	17:28:28	337	I-75 N. Bound	
19-0003427	0	11/15/2019	18:48:24	620	Fifth	
19-0003428	0	11/15/2019	19:38:28	521	Stillwood	
19-0003429	0	11/15/2019	21:52:31	1614	Ryman Ridge	
19-0003430	0	11/15/2019	23:53:00	310	Brickyard	
19-0003431	0	11/16/2019	01:25:15	437	Fourth	
19-0003432	0	11/16/2019	06:39:37	1116	Roan	
19-0003433	0	11/16/2019	13:20:48	785	Shugart	
19-0003434	0	11/16/2019	18:22:49	1116	Willowdale	
19-0003435	0	11/16/2019	21:09:55	521	Selvidge St. (North)	
19-0003436	0	11/16/2019	21:37:51	479	Conway	
19-0003437	0	11/16/2019	22:26:21	1807	Beechland	
19-0003438	0	11/17/2019	02:22:34	1495	Heather	
19-0003439	0	11/17/2019	05:48:40	113	Gunbarrel	
19-0003440	0	11/17/2019	06:43:37	614	Bryan	
19-0003441	0	11/17/2019	10:29:35	1811	Oakmont	
19-0003442	0	11/17/2019	10:43:20	227	Grace	
19-0003443	0	11/17/2019	11:24:17	700	Miller	
19-0003444	0	11/17/2019	12:36:57	1116	St. Charles	
19-0003445	0	11/17/2019	12:45:00	129	Ella	
						\$15,000

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003446	0	11/17/2019	13:17:07	North Bypass	311 Medical assist, assist EMS crew	
19-0003447	0	11/17/2019	19:03:33	302 Tarver	311 Medical assist, assist EMS crew	
19-0003448	0	11/17/2019	23:08:49	I-75 S. Bound	611 Dispatched & cancelled en route	
19-0003449	0	11/18/2019	00:17:16	603 Selvidge St. (North)	311 Medical assist, assist EMS crew	
19-0003450	0	11/18/2019	10:17:27	1320 Winton	531 Smoke or odor removal	
19-0003451	0	11/18/2019	13:34:14	709 Underwood	311 Medical assist, assist EMS crew	
19-0003452	0	11/18/2019	17:03:24	Zoysia	311 Medical assist, assist EMS crew	
19-0003453	0	11/18/2019	21:40:23	1204 Georgian	311 Medical assist, assist EMS crew	
19-0003454	0	11/18/2019	23:10:56	1312 Winton	311 Medical assist, assist EMS crew	
19-0003455	0	11/19/2019	07:40:11	1320 Winton	743 Smoke detector activation, no fire	
19-0003456	0	11/19/2019	11:13:46	225 Westerly	611 Dispatched & cancelled en route	
19-0003457	0	11/19/2019	13:19:44	1024 Abutment	311 Medical assist, assist EMS crew	
19-0003458	0	11/19/2019	20:32:17	2180 Arbordale	311 Medical assist, assist EMS crew	
19-0003459	0	11/19/2019	21:54:55	1109 James	611 Dispatched & cancelled en route	
19-0003460	0	11/19/2019	22:38:21	College	324 Motor Vehicle Accident with no	
19-0003461	0	11/20/2019	02:16:54	2305 Abutment	311 Medical assist, assist EMS crew	
19-0003462	0	11/20/2019	03:50:47	701 Fourth	311 Medical assist, assist EMS crew	
19-0003463	0	11/20/2019	12:08:23	1004 Cartwright	311 Medical assist, assist EMS crew	
19-0003464	0	11/20/2019	13:14:19	1517 Walnut (West)	311 Medical assist, assist EMS crew	
19-0003465	0	11/20/2019	14:50:34	609 Thornton (South)	311 Medical assist, assist EMS crew	
19-0003466	0	11/20/2019	19:16:30	618 Fifth	311 Medical assist, assist EMS crew	
19-0003467	0	11/20/2019	21:46:59	1807 Beechland	311 Medical assist, assist EMS crew	
19-0003468	0	11/21/2019	01:11:10	1200 Memorial	745 Alarm system activation, no fire -	
19-0003469	0	11/21/2019	09:14:29	902 Hamilton (North)	311 Medical assist, assist EMS crew	
19-0003470	0	11/21/2019	09:58:21	Abutment	324 Motor Vehicle Accident with no	
19-0003471	0	11/21/2019	13:07:35	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0003472	0	11/21/2019	14:16:44	1116 Willowdale	311 Medical assist, assist EMS crew	
19-0003473	0	11/21/2019	15:58:21	1116 Willowdale	611 Dispatched & cancelled en route	
19-0003474	0	11/21/2019	18:19:49	1811 Elaine	311 Medical assist, assist EMS crew	
19-0003475	0	11/21/2019	19:58:44	1220 Broadrick	745 Alarm system activation, no fire -	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003476	0	11/21/2019	21:50:16	1003 Willow Park Lane	311 Medical assist, assist EMS crew	
19-0003477	0	11/22/2019	07:48:47	1749 Brighton	311 Medical assist, assist EMS crew	
19-0003478	0	11/22/2019	08:20:47	209 Fredrick (North)	311 Medical assist, assist EMS crew	
19-0003479	0	11/22/2019	08:46:26	Keith	311 Medical assist, assist EMS crew	
19-0003480	0	11/22/2019	10:19:28	mm338 I-75 N. Bound	622 No Incident found on arrival at	
19-0003481	0	11/22/2019	11:07:50	1807 Shadow	311 Medical assist, assist EMS crew	
19-0003482	0	11/22/2019	12:18:25	712 Morris (East)	311 Medical assist, assist EMS crew	
19-0003483	0	11/22/2019	12:51:42	1009 Professional	311 Medical assist, assist EMS crew	
19-0003484	0	11/22/2019	14:03:31	500 Tibbs (South)	311 Medical assist, assist EMS crew	
19-0003485	0	11/22/2019	18:56:21	1212 Broadrick	311 Medical assist, assist EMS crew	
19-0003486	0	11/22/2019	19:09:08	1901 Middle Summit	311 Medical assist, assist EMS crew	
19-0003487	0	11/22/2019	19:12:21	712 Corey	311 Medical assist, assist EMS crew	
19-0003488	0	11/22/2019	21:15:54	North Bypass	322 Motor vehicle accident with	
19-0003489	0	11/22/2019	23:47:23	Dug Gap	324 Motor Vehicle Accident with no	
19-0003490	0	11/22/2019	23:53:01	217 Cuyler (west)	311 Medical assist, assist EMS crew	
19-0003491	0	11/23/2019	04:15:51	1220 Broadrick	311 Medical assist, assist EMS crew	
19-0003492	0	11/23/2019	06:14:41	516 Burchfield	311 Medical assist, assist EMS crew	
19-0003493	0	11/23/2019	09:42:50	421 Underwood	311 Medical assist, assist EMS crew	
19-0003494	0	11/23/2019	10:08:44	407 Roberts	311 Medical assist, assist EMS crew	
19-0003495	0	11/23/2019	11:02:48	704 Moonraker	311 Medical assist, assist EMS crew	
19-0003496	0	11/23/2019	12:37:42	310 Chestnut	311 Medical assist, assist EMS crew	
19-0003497	0	11/23/2019	15:42:26	815 Shugart	311 Medical assist, assist EMS crew	
19-0003498	0	11/23/2019	19:26:15	879 College	353 Removal of victim(s) from stalled	
19-0003499	0	11/23/2019	20:38:49	1305 Vann	311 Medical assist, assist EMS crew	
19-0003500	0	11/24/2019	00:40:11	210 Easterling (North)	311 Medical assist, assist EMS crew	
19-0003501	0	11/24/2019	01:12:48	North Bypass	324 Motor Vehicle Accident with no	
19-0003502	0	11/24/2019	12:57:32	333 Country Club	311 Medical assist, assist EMS crew	
19-0003503	0	11/24/2019	14:30:57	475 Reed	743 Smoke detector activation, no fire	
19-0003504	0	11/24/2019	16:46:33	614 Dantzler	311 Medical assist, assist EMS crew	
19-0003505	0	11/24/2019	23:08:22	1312 Winton	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003506	0	11/24/2019	23:33:03	1426 Walston	423 Refrigeration leak	
19-0003507	0	11/25/2019	02:04:14	843 McAfee	311 Medical assist, assist EMS crew	
19-0003508	0	11/25/2019	08:29:24	Morris (East)	324 Motor Vehicle Accident with no	
19-0003509	0	11/25/2019	09:38:35	816 Walnut Square	311 Medical assist, assist EMS crew	
19-0003510	0	11/25/2019	11:33:37	1144 Boylston	311 Medical assist, assist EMS crew	
19-0003511	0	11/25/2019	12:48:16	1147 Boylston	311 Medical assist, assist EMS crew	
19-0003512	0	11/25/2019	13:18:33	1320 Winton	745 Alarm system activation, no fire -	
19-0003513	0	11/25/2019	17:50:14	1850 Chattanooga	611 Dispatched & cancelled en route	
19-0003514	0	11/25/2019	22:17:21	101 Hawthorne (East)	322 Motor vehicle accident with	
19-0003515	0	11/25/2019	22:18:53	1306 Underwood	611 Dispatched & cancelled en route	
19-0003516	0	11/26/2019	03:30:07	2221 Rocky Face	651 Smoke scare, odor of smoke	
19-0003517	0	11/26/2019	06:29:26	1007 Willow Park Lane	311 Medical assist, assist EMS crew	
19-0003518	0	11/26/2019	07:43:27	507 Anderson	311 Medical assist, assist EMS crew	
19-0003519	0	11/26/2019	08:23:31	405 School	743 Smoke detector activation, no fire	
19-0003520	0	11/26/2019	10:53:20	1203 Glenwood (North)	311 Medical assist, assist EMS crew	
19-0003521	0	11/26/2019	13:07:39	1318 Underwood	311 Medical assist, assist EMS crew	
19-0003522	0	11/26/2019	13:31:21	520 Vernon	113 Cooking fire, confined to	
19-0003523	0	11/26/2019	13:56:23	Fields	324 Motor Vehicle Accident with no	
19-0003524	0	11/26/2019	17:53:31	1958 Springchase	311 Medical assist, assist EMS crew	
19-0003525	0	11/26/2019	18:57:28	806 Walnut (West)	311 Medical assist, assist EMS crew	
19-0003526	0	11/26/2019	19:52:07	620 Fifth	311 Medical assist, assist EMS crew	
19-0003527	0	11/26/2019	22:18:06	2428 Abutment	311 Medical assist, assist EMS crew	
19-0003528	0	11/26/2019	23:23:20	1306 Underwood	311 Medical assist, assist EMS crew	
19-0003529	0	11/27/2019	01:36:32	1257 Glenwood (North)	611 Dispatched & cancelled en route	
19-0003530	0	11/27/2019	02:02:30	905 Hamilton (South)	311 Medical assist, assist EMS crew	
19-0003531	0	11/27/2019	07:58:01	Lamar	324 Motor Vehicle Accident with no	
19-0003532	0	11/27/2019	10:17:20	711 Hamilton (South)	311 Medical assist, assist EMS crew	
19-0003533	0	11/27/2019	13:28:17	1102 Burleyson	743 Smoke detector activation, no fire	
19-0003534	0	11/27/2019	13:36:46	205 Industrial (West)	357 Extrication of victim(s) from	
19-0003535	0	11/27/2019	14:28:48	1001 Poly Pac	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003536	0	11/27/2019	15:55:31	1000 Jones	311 Medical assist, assist EMS crew	
19-0003537	0	11/27/2019	16:29:04	I-75 S. Bound	611 Dispatched & cancelled en route	
19-0003538	0	11/27/2019	16:35:34	620 Fifth	445 Arcing, shorted electrical	
19-0003539	0	11/27/2019	16:46:35	500 Straight	651 Smoke scare, odor of smoke	
19-0003540	0	11/27/2019	21:23:36	I-75 S. Bound	131 Passenger vehicle fire	\$3,600
19-0003541	0	11/27/2019	23:03:43	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0003542	0	11/28/2019	05:49:22	1916 Meadowbrook	311 Medical assist, assist EMS crew	
19-0003543	0	11/28/2019	09:50:09	745 College	442 Overheated motor	
19-0003544	0	11/28/2019	12:48:52	I-75 N. Bound	611 Dispatched & cancelled en route	
19-0003545	0	11/28/2019	15:07:52	922 Avenue F	311 Medical assist, assist EMS crew	
19-0003546	0	11/28/2019	16:25:32	1800 Underwood	311 Medical assist, assist EMS crew	
19-0003547	0	11/28/2019	21:23:54	1305 Cleveland	251 Excessive heat, scorch burns with	
19-0003548	0	11/29/2019	00:38:10	321 Boundary (North)	311 Medical assist, assist EMS crew	
19-0003549	0	11/29/2019	06:24:43	1507 Tibbs (North)	311 Medical assist, assist EMS crew	
19-0003550	0	11/29/2019	09:17:43	801 Katlau	311 Medical assist, assist EMS crew	
19-0003551	0	11/29/2019	13:25:20	1100 Nelson	561 Unauthorized burning	
19-0003552	0	11/29/2019	13:55:55	1035 Abutment	745 Alarm system activation, no fire -	
19-0003553	0	11/29/2019	14:06:41	1365 Walnut (West)	311 Medical assist, assist EMS crew	
19-0003554	0	11/29/2019	17:45:36	I-75 N. Bound	311 Medical assist, assist EMS crew	
19-0003555	0	11/29/2019	19:28:26	1801 Dug Gap	311 Medical assist, assist EMS crew	
19-0003556	0	11/29/2019	23:35:32	1618 Beechland	311 Medical assist, assist EMS crew	
19-0003557	0	11/30/2019	00:30:32	421 Claude	311 Medical assist, assist EMS crew	
19-0003558	0	11/30/2019	03:19:45	1304 May	735 Alarm system sounded due to	
19-0003559	0	11/30/2019	15:14:23	Ross	611 Dispatched & cancelled en route	
19-0003560	0	11/30/2019	15:20:45	2 Brothers	311 Medical assist, assist EMS crew	
19-0003561	0	11/30/2019	16:22:28	1039 Factory	561 Unauthorized burning	
19-0003562	0	11/30/2019	16:28:42	875 Shugart	311 Medical assist, assist EMS crew	
19-0003563	0	11/30/2019	16:58:10	Frazier	561 Unauthorized burning	
19-0003564	0	11/30/2019	18:21:44	1203 Acme	311 Medical assist, assist EMS crew	
19-0003565	0	11/30/2019	20:02:56	504 Evie	611 Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2019} And {11/30/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0003566	0	11/30/2019	21:06:23	2123 Holly	311 Medical assist, assist EMS crew	
19-0003567	0	11/30/2019	21:08:58	1218 Broadrick	611 Dispatched & cancelled en route	
19-0003568	0	11/30/2019	22:07:51	421 Underwood	311 Medical assist, assist EMS crew	
19-0003569	0	11/30/2019	22:31:04	1006 Croy	611 Dispatched & cancelled en route	
<b>Total Incident Count</b>					<b>Total Est Loss</b>	<b>\$42,100</b>

**DALTON****Incident Type Period Comparisons****Alarm Date Between {11/01/2019} and {11/30/2019}**

Incident Type	11/01/2019	11/01/2018	11/01/2017	11/01/2016
	to	to	to	to
	11/30/2019	11/30/2018	11/30/2017	11/30/2016
111 Building fire	2	3	5	8
113 Cooking fire, confined to container	2	2	1	0
131 Passenger vehicle fire	3	2	1	5
132 Road freight or transport vehicle fire	0	1	0	0
137 Camper or recreational vehicle (RV) fire	0	1	0	0
140 Natural vegetation fire, Other	0	1	0	0
141 Forest, woods or wildland fire	0	0	1	5
142 Brush or brush-and-grass mixture fire	1	0	2	6
143 Grass fire	0	1	0	0
150 Outside rubbish fire, Other	0	0	0	1
151 Outside rubbish, trash or waste fire	0	1	2	3
154 Dumpster or other outside trash receptacle fire	0	0	0	1
162 Outside equipment fire	0	0	0	1
170 Cultivated vegetation, crop fire, Other	0	0	0	1
251 Excessive heat, scorch burns with no ignition	1	1	0	1
311 Medical assist, assist EMS crew	182	187	183	180
322 Motor vehicle accident with injuries	12	8	1	7
323 Motor vehicle/pedestrian accident (MV Ped)	1	0	0	0
324 Motor Vehicle Accident with no injuries	13	9	1	7
351 Extrication of victim(s) from building/structure	0	0	0	1
352 Extrication of victim(s) from vehicle	0	1	0	0
353 Removal of victim(s) from stalled elevator	1	0	0	0
357 Extrication of victim(s) from machinery	1	0	0	1
410 Combustible/flammable gas/liquid condition,	0	0	1	0
411 Gasoline or other flammable liquid spill	0	2	1	0
412 Gas leak (natural gas or LPG)	2	1	0	4
413 Oil or other combustible liquid spill	0	1	0	0

**DALTON****Incident Type Period Comparisons****Alarm Date Between {11/01/2019} and {11/30/2019}**

Incident Type	11/01/2019	11/01/2018	11/01/2017	11/01/2016
	to	to	to	to
	11/30/2019	11/30/2018	11/30/2017	11/30/2016
421 Chemical hazard (no spill or leak)	0	1	0	0
423 Refrigeration leak	1	0	0	0
424 Carbon monoxide incident	0	0	0	1
441 Heat from short circuit (wiring), defective/worn	0	1	3	0
442 Overheated motor	3	0	0	0
444 Power line down	1	3	0	1
445 Arcing, shorted electrical equipment	2	4	1	1
451 Biological hazard, confirmed or suspected	0	0	1	0
461 Building or structure weakened or collapsed	0	1	0	0
462 Aircraft standby	1	0	0	0
463 Vehicle accident, general cleanup	0	1	0	1
500 Service Call, other	1	0	1	0
510 Person in distress, Other	0	1	0	1
511 Lock-out	0	0	1	0
512 Ring or jewelry removal	0	0	1	0
522 Water or steam leak	1	0	0	0
531 Smoke or odor removal	1	0	1	1
542 Animal rescue	0	0	1	0
550 Public service assistance, Other	0	0	0	1
551 Assist police or other governmental agency	0	2	0	1
552 Police matter	0	1	0	0
553 Public service	1	2	7	2
555 Defective elevator, no occupants	0	1	0	0
561 Unauthorized burning	4	0	2	12
600 Good intent call, Other	1	0	0	0
611 Dispatched & cancelled en route	36	38	27	19
622 No Incident found on arrival at dispatch address	4	3	5	14

**DALTON****Incident Type Period Comparisons****Alarm Date Between {11/01/2019} and {11/30/2019}**

Incident Type	11/01/2019	11/01/2018	11/01/2017	11/01/2016
	to	to	to	to
	11/30/2019	11/30/2018	11/30/2017	11/30/2016
631 Authorized controlled burning	1	1	0	1
651 Smoke scare, odor of smoke	3	5	3	8
653 Smoke from barbecue, tar kettle	0	0	0	1
671 HazMat release investigation w/no HazMat	0	1	3	3
713 Telephone, malicious false alarm	0	0	0	1
715 Local alarm system, malicious false alarm	1	2	2	1
721 Bomb scare - no bomb	0	0	1	0
731 Sprinkler activation due to malfunction	1	0	1	1
732 Extinguishing system activation due to	0	0	1	0
733 Smoke detector activation due to malfunction	2	1	4	7
735 Alarm system sounded due to malfunction	5	5	4	0
736 CO detector activation due to malfunction	0	1	1	0
741 Sprinkler activation, no fire - unintentional	0	0	2	0
742 Extinguishing system activation	0	1	0	0
743 Smoke detector activation, no fire -	8	18	16	13
744 Detector activation, no fire - unintentional	0	4	3	3
745 Alarm system activation, no fire - unintentional	5	16	10	8
746 Carbon monoxide detector activation, no CO	0	2	0	0
<b>Totals</b>	<b>304</b>	<b>338</b>	<b>301</b>	<b>334</b>

# Dalton Fire Department

## Monthly Emergency Response Time Analysis

### Emergency Responses

Response		Count	Percentage
Hrs	Mins		
< 01		18	4.9%
01		44	12.1%
02		100	27.5%
03		94	25.8%
04		57	15.7%
05		25	6.8%
06		13	3.5%
07		7	1.9%
10		4	1.1%
11		1	0.2%

Overall Average Response Time: 00:03:24

# **Dalton Fire Department**

## **Monthly Non-Emergency Response Time Analysis**

### **Non-Emergency Responses**

<b>Response</b>			
<b>Hrs</b>	<b>Mins</b>	<b>Count</b>	<b>Percentage</b>
	< 01	5	12.5%
	01	1	2.5%
	02	4	10.0%
	03	3	7.5%
	04	9	22.5%
	05	7	17.5%
	06	5	12.5%
	08	4	10.0%
	09	2	5.0%

**Overall Average Response Time: 00:04:38**

**Dalton Fire Department  
Medical Incident Study  
EMS On scene/Not on scene Prior to DFD Comparison  
11/1/19 –11/30/19**

**Total incidents in time period – 210**

**EMS on-scene prior to DFD – 55**

**EMS not on-scene prior – 162**

**During the month of November, Dalton Fire Department arrived on-scene prior to Hamilton EMS on 77% of medical responses.**

# **Training Division Monthly Report**

## **November 2019**

### **Overview**

Recruit Class 2019-01 concluded on November 8<sup>th</sup> when 4 candidates challenged state and national certification exams for Firefighter 1 and Firefighter 2. Annual physical agility testing was completed for all certified firefighters. A refresher course on fire cause determination and evidence preservation was delivered to all suppression personnel at the acquired structures on Underwood Circle. The department hosted Georgia Smoke Diver Class 58 during the week of November 11th. The class began with 42 candidates and graduated 16. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of November totaled 4,070.

### **Outside Schools**

4 firefighters attended Intermediate and Advanced Incident Command courses hosted by Whitfield County Emergency Management.

1 chief officer attended a symposium on human trafficking at Georgia Public Safety Training Center.

2 firefighters attended The Company Officer Academy delivered by Chiefs Rick Lasky and John Salka hosted by Roswell/Alpharetta Public Safety Training Center.

One member of the Fire Prevention Division attended a 54-hour course entitled Plans Review for Fire and Life Safety at the National Fire Academy in Emmitsburg, Maryland.

### **Support Functions**

- 164 hours were spent completing apparatus checks and equipment replenishment
- Cleaning and maintenance activities accounted for 487 hours in November
- 3 hours were dedicated to fire investigation and related activities
- Fall hydrant maintenance accounted for 108 work hours
- SCBA maintenance consumed 61 hours during the month

# **Prevention Division Monthly Report**

## **November 2019**

### **Inspections**

Annual Inspections	Total:	47
Apartment Inspections	Total:	
Site Inspections	Total:	10
Fire Alarm Inspection	Total:	1
Sprinkler System Inspection	Total:	
New Kitchen Hood Inspections	Total:	
Knox Box Installation	Total:	2
Occupational Tax Certificate Inspections	Total:	15
Alcohol Inspections	Total:	2
50 Percent Inspections	Total:	
80 Percent Inspections	Total:	
100 Percent Inspections	Total:	
Pre-Incident Surveys	Total:	12
Plan Reviews	Total:	
Addressing	Total:	9
<b>Total Inspections</b>		<b>98</b>

### **Public Relations**

Fire Safety Education		
Events	Total:	25
Staff Members Participated	Total:	81
Staff Hours	Total:	159
Number of Adults Reached	Total:	1205
Number of Children Reached	Total:	1630
<b>Total Residents Reached</b>		<b>2835</b>

**DALTON****Monthly Prevention Inspections by Type**

**Date Completed Between {11/01/2019} And  
{11/30/2019}**

<b>Date</b>	<b>Time</b>	<b>Occupancy</b>	<b>Hrs</b>	<b>Fee</b>
<b>200 INSPECTION - Annual</b>				
11/11/2019	10:39	20696 El Taco 801 Walnut (East) AVE /Suite D1	0.00	
11/11/2019	13:34	20699 Natural World 801 Walnut (East) AVE /Suite K	0.07	
11/11/2019	10:41	20700 Vacant 801 Walnut (East) AVE /Suite F2	0.00	
11/11/2019	10:40	20701 Groomingtails 801 Walnut (East) AVE /Suite H	0.00	
11/11/2019	13:26	20757 Select Staffing 801 Walnut (East) AVE /Suite N	0.11	
11/11/2019	13:15	20758 Executive Management Services Inc. 801 Walnut (East) AVE /Suite O	0.19	
11/11/2019	13:07	2P002 Raulston Properties 720 Glenwood (South) AVE	0.01	
11/11/2019	13:05	20413 Counseling Services 720 Glenwood (South) AVE /102	0.02	
11/11/2019	13:03	20414 Advanced Creative Solutions 720 Glenwood (South) AVE /104	0.03	
11/11/2019	12:40	20415 Intervention 720 Glenwood (South) AVE /106&108	0.00	
11/11/2019	12:40	20416 Intervention 720 Glenwood (South) AVE /110	0.00	
11/11/2019	12:42	20418 Vacant 720 Glenwood (South) AVE /202	0.00	
11/11/2019	12:42	20419 Vacant 720 Glenwood (South) AVE /204	0.00	
11/11/2019	12:59	20420 Sharon Langford Realty, LLC 720 Glenwood (South) AVE /206	0.04	
11/11/2019	12:42	20421 Vacant 720 Glenwood (South) AVE /210	0.00	
11/11/2019	12:43	20422 Southern Corp. 720 Glenwood (South) AVE /212	0.12	
11/11/2019	12:58	20423 Hotel Restaurant Supply 720 Glenwood (South) AVE /214	0.01	
11/11/2019	12:57	20424 Hotel Restaurant Supply 720 Glenwood (South) AVE /216	0.01	
11/11/2019	12:53	20425 Hotel Restaurant Supply 720 Glenwood (South) AVE /220	0.05	

**DALTON****Monthly Prevention Inspections by Type**

**Date Completed Between {11/01/2019} And  
{11/30/2019}**

<b>Date</b>	<b>Time</b>	<b>Occupancy</b>	<b>Hrs</b>	<b>Fee</b>
<b>200 INSPECTION - Annual</b>				
11/11/2019	12:43	20780 Vacant 720 Glenwood (South) AVE /208	0.00	
11/06/2019		10783 Peeples Cancer Center 1215 Memorial DR	0.00	
11/18/2019	13:21	40049 Liberty Tax 1345 Walnut (West) AVE	0.00	
11/18/2019	13:22	40047 Tobacco Outlet 1339 Walnut (West) AVE	0.06	
11/13/2019	13:20	30188 American Carpet Wholesale 2317 Chattanooga RD	0.12	
11/13/2019	07:45	20756 Veritas 801 Walnut (East) AVE /Suite L	0.03	
11/25/2019	15:25	2P009 Barrett Marketplace 801 Walnut (East) AVE	0.46	
11/25/2019	10:30	20600 Fortune Cookie 801 Walnut (East) AVE /Suite J	0.10	
11/25/2019	09:54	20692 Carneceria Loa #3 801 Walnut (East) AVE /Suite G	0.46	
11/25/2019	09:15	20693 Dalton RV 801 Walnut (East) AVE /Suite A	0.32	
11/25/2019	11:12	20694 Vacant 801 Walnut (East) AVE /Suite B	0.00	
11/25/2019	10:58	20695 Vallarta 801 Walnut (East) AVE /Suite C	0.28	
11/25/2019	09:42	20697 Cosmo Prof 801 Walnut (East) AVE /Suite F	0.16	
11/25/2019	11:14	20698 Super Carniceria LOA 801 Walnut (East) AVE /Suite E	0.00	
11/25/2019	10:42	20702 TALC 801 Walnut (East) AVE /Suite I	0.24	
11/22/2019	09:32	50120 Peak Fitness 1021 Riverburch PKY /Dalton, GA 30721	0.62	
11/25/2019	09:06	30160 K & T Tank Wash 1067 Willowdale RD	0.08	
11/25/2019	09:25	30135 Shaw Industries Plant #81 201 Springdale RD	0.13	
11/25/2019	10:40	40064 Applebee's 1322 Walnut (West) AVE	0.09	

**DALTON****Monthly Prevention Inspections by Type**

**Date Completed Between {11/01/2019} And  
{11/30/2019}**

<b>Date</b>	<b>Time</b>	<b>Occupancy</b>	<b>Hrs</b>	<b>Fee</b>
<b>200 INSPECTION - Annual</b>				
11/25/2019	10:25	40062 Shoney's 1302 Walnut (West) AVE	0.04	
11/25/2019	09:02	30159 Direct Packaging 1039 Willowdale RD	0.02	
11/25/2019		10808 The Lock Guys 417 Glenwood (North) AVE	0.00	
11/26/2019	14:01	20412 Life Touch Chiropractic 720 Glenwood (South) AVE /100	0.08	
11/26/2019	13:47	20417 Esperanza Counseling Services 720 Glenwood (South) AVE /112	0.03	
11/26/2019	13:50	20779 Vacant 720 Glenwood (South) AVE /200	0.00	
11/27/2019	10:58	2P001 Ty Rutledge Properties 506 Bear Creek RD	0.65	
11/27/2019	07:59	30259 HPP 1920 Environs LANE	0.17	
11/27/2019	08:25	30309 Williams Plastic Surgery 1506 Professional CT	0.58	
<b>Total Activities for Type: 47</b>				<b>5.38</b>

**210 INSPECTION - Site**

11/21/2019	11:05	40020 Holiday Inn Express 934 Market ST	0.02
11/21/2019		10783 Peeples Cancer Center 1215 Memorial DR	0.00
11/19/2019		20495 Alondra's #2 101 Walnut (West) AVE /Suite 9	0.00
11/19/2019		50151 Hammond Creek Middle School 330 Pleasant Grove DR NE	0.00
11/19/2019		30259 HPP 1920 Environs LANE	0.00
11/18/2019	14:09	30138 North Georgia Highlands 1503 Tibbs (North) RD	0.05
11/18/2019		10271 Tacos Tu Go 809 Hamilton (North) ST	0.00
11/08/2019	10:52	20225 Stoller Ind. 2220 Hamilton Extension ST	0.00

**DALTON****Monthly Prevention Inspections by Type**

**Date Completed Between {11/01/2019} And  
{11/30/2019}**

Date	Time	Occupancy	Hrs	Fee
<b>210 INSPECTION - Site</b>				
11/12/2019	09:34	10783 Peeples Cancer Center 1215 Memorial DR	0.66	
11/11/2019	13:52	30074 Avanti Enviromental Group, Inc. 1406 Coronet DR	1.23	
<b>Total Activities for Type:</b>			<b>10</b>	<b>1.96</b>
<b>221 INSPECTION - Fire Alarm</b>				
11/05/2019		10783 Peeples Cancer Center 1215 Memorial DR	0.00	
<b>Total Activities for Type:</b>			<b>1</b>	<b>0.00</b>
<b>251 INSPECTION - Knox Box Installation</b>				
11/21/2019	14:11	50137 Christian Heritage High School 1601 MLK Jr. BLVD	0.02	
11/21/2019		50094 Christian Heritage Elementary School 1600 MLK Jr. BLVD	0.00	
<b>Total Activities for Type:</b>			<b>2</b>	<b>0.02</b>
<b>261 INSPECTION - OTC</b>				
11/22/2019	13:51	20495 Alondra's #2 101 Walnut (West) AVE /Suite 9	1.46	
11/27/2019	09:18	20706 El Comal Tienda Y Cocina 616 Fourth AVE /Suites 4,5,6	1.09	
11/27/2019	13:35	20797 Jessica Stop N Shop 1101 New Doris ST	0.07	
11/25/2019	09:39	30208 VIP Liquors 785 Shugart RD /Suite 4	0.20	
11/25/2019	10:47	40100 Just Jump 1515 Walnut (West) AVE	0.15	
11/20/2019	10:42	20792 E.H Garage 406 Eleventh AVE	0.11	
11/20/2019	10:16	20797 Jessica Stop N Shop 1101 New Doris ST	0.19	

**DALTON****Monthly Prevention Inspections by Type**

**Date Completed Between {11/01/2019} And  
{11/30/2019}**

<b>Date</b>	<b>Time</b>	<b>Occupancy</b>	<b>Hrs</b>	<b>Fee</b>
<b>261 INSPECTION - OTC</b>				
11/20/2019	09:01	10007 Discoteque El Veneno 600 MLK Jr. BLVD /A	0.18	
11/20/2019	09:22	20143 Pye Barker Fire and Safety 634 Glenwood PL	0.32	
11/25/2019	14:17	20544 Boost Mobile 816 Walnut Square BLVD /51	0.01	
11/25/2019	14:18	20793 Boost Mobile 2514 Walnut (East) AVE	0.01	
11/25/2019	13:47	20365 Budgetel 609 Thornton (South) AVE	0.16	
11/01/2019	10:11	20180 Guadalajara of Dalton 817 Hamilton (South) ST	0.12	
11/08/2019	10:48	10771 American Import Auto Parts LLC. 412 Hamilton (North) ST	0.02	
11/12/2019	09:01	10007 Discoteque El Veneno 600 MLK Jr. BLVD /A	0.29	
<b>Total Activities for Type:</b>			<b>15</b>	<b>4.38</b>

**262 INSPECTION - Alcohol**

11/12/2019	12:31	20761 Cox's Liquor 1301 Walnut (East) AVE	0.25
11/15/2019	07:45	20761 Cox's Liquor 1301 Walnut (East) AVE	0.01
<b>Total Activities for Type:</b>			<b>2</b>
			<b>0.26</b>

**501 PRE-INCIDENT SURVEY**

11/25/2019	10:00	20130 Sons of Grant 613 Fifth AVE	1.00
11/25/2019	09:00	40180 McDonalds 1523 Walnut (West) AVE	0.00
11/25/2019	09:30	40191 Burger King 1512 Walnut (West) AVE	0.50
11/25/2019	10:00	40164 Krispy Kreme 1500 Walnut (West) AVE	0.50

**DALTON****Monthly Prevention Inspections by Type**

**Date Completed Between {11/01/2019} And  
{11/30/2019}**

<b>Date</b>	<b>Time</b>	<b>Occupancy</b>	<b>Hrs</b>	<b>Fee</b>
<b>501 PRE-INCIDENT SURVEY</b>				
11/18/2019		50052 Roses 1205 Glenwood (North) AVE /Suite 3/Dalton, GA 30719		0.00
11/18/2019		30157 Sun Star Enterprises 1830 Willowdale RD		0.00
11/18/2019	10:00	40163 Verizon Wireless 1516 Walnut (West) AVE		0.50
11/18/2019	09:30	40161 Georgia Hope Family & Childrens 1414 Dug Gap RD		0.50
11/18/2019	10:30	40162 State Farm 1904 Shields RD		0.50
11/11/2019	10:00	40189 KFC 1519 Walnut (West) AVE		0.00
11/11/2019	10:30	40190 Panda Express 1521 Walnut (West) AVE		0.00
11/11/2019	13:00	50156 Humane Society of Northwest Georgia 1210 Veterans DR		1.25
<b>Total Activities for Type:</b> 12				<b>4.75</b>

**Grand Total Activities:** 89

**Grand Totals:** 16.75 0.00

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20495      **Alondra's #2**  
**101 Walnut (West) AVE**  
**Suite 9**  
**Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
11/22/2019	2012 IFC 505.1 Address, no suite	1			0
	<b>Notes:</b> Address numbers should be a minimum of 4 inches tall and 1/2 inch wide. Numbers should be visible from road fronting the property, and be contrasting to the background. Install address suite number in a visible location.				
11/22/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box.				
11/22/2019	2012 IFC 509.1 Riser room not marked	1			0
	<b>Notes:</b> Install signage indicating riser location.				
11/22/2019	2012 IFC 605.3.1 Electrical panel, concealed	1			0
	<b>Notes:</b> Requires signage indicating concealed electrical panels.				
11/22/2019	2012 IFC 605.6 Electrical panel, cover not	1			0
	<b>Notes:</b> Openings in junction box cover on electrical outlet need to be sealed.				
11/22/2019	2012 IFC 912.2.1 FDC, location not signed	1			0
	<b>Notes:</b> Install FDC signage.				
11/22/2019	2012 NFPA 101 7.10.8.31 Exit, no exit	1			0
	<b>Notes:</b> Install signage stating Not an Exit.				
11/22/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Repair or replace emergency lighting.				
11/22/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
	<b>Notes:</b> Repair or replace exit signage.				
11/22/2019	DFDFMO AHJ, Requirement	1			0
	<b>Notes:</b> Install blank on inoperable hood system pull station.				

**Total Individual Violation Codes for Occupancy: 10**

\* Denotes Violations Corrected or Variance Issued

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And {11/30/2019}**

2P009      **Barrett Marketplace**  
**801 Walnut (East) AVE**  
**Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
11/25/2019	2011 NFPA 96 11.4 Kitchen hood,  <b>Notes:</b> Hood system at Loa is out of date.	1			0
11/25/2019	2012 IFC 313.1 Storage, propane / gas powered  <b>Notes:</b> Storage around water heater at Loa.	1			0
11/25/2019	2012 IFC 509.1 Riser room not marked  <b>Notes:</b> Add signage to riser room door.	1			0
11/25/2019	2012 IFC 605.1 Electrical panel, abatement of  <b>Notes:</b> Open spaces in electrical panel at Vallarta and Loa	1			0
11/25/2019	2012 IFC 605.5 Extension cord, Improper use  <b>Notes:</b> Using temporary wiring for permanent use.	1			0
11/25/2019	2012 IFC 906.2 Fire extinguisher, Properly  <b>Notes:</b> Out of date @ Loa, Suite K and suite N.	1			0
11/25/2019	2012 IFC 912.2.1 FDC, location not signed  <b>Notes:</b> Add signage above FDC.	1			0

**Total Individual Violation Codes for Occupancy: 7**

20692      **Carneceria Loa #3**  
**801 Walnut (East) AVE**  
**Suite G**  
**Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
11/25/2019	2011 NFPA 96 11.4 Kitchen hood,  <b>Notes:</b> Hood system requires cleaning and inspection.	1			0
11/25/2019	2012 IFC 305.1 Combustibles, to close to heat  <b>Notes:</b> Maintain proper clearance around gas powered water heater.	1			0
11/25/2019	2012 IFC 313.1 Storage, propane / gas powered  <b>Notes:</b> Maintain proper clearance around gas powered water heater.	1			0

**\* Denotes Violations Corrected or Variance Issued**

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And {11/30/2019}**

20692      Carneceria Loa #3  
 801 Walnut (East) AVE  
 Suite G  
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/25/2019	2012 IFC 509.1 Riser room not marked	1			0
	<b>Notes:</b> Riser room requires identification.				
11/25/2019	2012 IFC 605.1 Electrical panel, abatement of	1			0
	<b>Notes:</b> Blanks required for empty breaker positions.				
11/25/2019	2012 IFC 605.5 Extension cord, Improper use	1			0
	<b>Notes:</b> Extension cords cannot be used for permanent wiring.				
11/25/2019	2012 IFC 906.2 Fire extinguisher, Properly	1			0
	<b>Notes:</b> Fire extinguisher inspection is out of date.				
11/25/2019	2012 IFC 912.2.1 FDC, location not signed	1			0
	<b>Notes:</b> FDC requires signage indicating location.				
<hr/>					
<b>Total Individual Violation Codes for Occupancy: 8</b>					

20761      Cox's Liquor  
 1301 Walnut (East) AVE  
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/12/2019 *	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building.				
11/12/2019 *	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building.				

**\* Denotes Violations Corrected or Variance Issued**

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20761 Cox's Liquor  
1301 Walnut (East) AVE  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
<b>Total Individual Violation Codes for Occupancy: 2</b>					

20693 Dalton RV  
801 Walnut (East) AVE  
Suite A  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/25/2019	2012 NFPA 101 7.9.3.1.1 Emergency light, <b>Notes:</b> Emergency exit and lighting inoperable.	1			0
<b>Total Individual Violation Codes for Occupancy: 2</b>					
11/25/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional <b>Notes:</b> Emergency exit and lighting inoperable.	1			0

**Total Individual Violation Codes for Occupancy: 2**

10007 Discoteque El Veneno  
600 MLK Jr. BLVD  
A  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/12/2019	* 2012 IFC 313.1 Storage, propane / gas powered <b>Notes:</b> Remove combustibles near gas powered equipment.	1			0
<b>Total Individual Violation Codes for Occupancy: 2</b>					
11/12/2019	* 2012 IFC 313.1 Storage, propane / gas powered <b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Remove combustibles near gas powered equipment.	1			0
11/12/2019	2012 IFC 506.1 Knox Box, requirements <b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access	1			0

**\* Denotes Violations Corrected or Variance Issued**

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

10007      **Discoteque El Veneno**  
600 MLK Jr. BLVD  
A  
Dalton, GA 30720

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
	building. Install Knox Box on building.				
11/12/2019	2012 IFC 506.1 Knox Box, requirements  <b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box on building.	1			0
11/12/2019	2012 IFC 605.1 Electrical panel, abatement of  <b>Notes:</b> Exposed electrical should be in conduit or covered with wall covering.	1			0
11/12/2019	2012 IFC 605.1 Electrical panel, abatement of  <b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Exposed electrical should be in conduit or covered with wall covering.	1			0
11/12/2019	* 2012 IFC 605.3 Electrical panel, obstructed  <b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Remove combustibles near electrical panels.	1			0
11/12/2019	* 2012 IFC 605.3 Electrical panel, obstructed  <b>Notes:</b> Remove combustibles near electrical panels.	1			0
11/12/2019	* 2012 IFC 605.6 Electrical panel, cover not  <b>Notes:</b> Secure doors on electrical panels.	1			0
11/12/2019	* 2012 IFC 605.6 Electrical panel, cover not  <b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Secure doors on electrical panels.	1			0
11/12/2019	* 2012 IFC 906.2 Fire extinguisher, Properly  <b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Have fire extinguishers serviced by a licensed contractor.	1			0
11/12/2019	* 2012 IFC 906.2 Fire extinguisher, Properly  <b>Notes:</b> Have fire extinguishers serviced by a licensed contractor.	1			0

\* Denotes Violations Corrected or Variance Issued

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

10007      Discoteque El Veneno  
600 MLK Jr. BLVD  
A  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/12/2019	* 2012 NFPA 101 7.2.1.5.1 Exit, while building	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request.				
	Original Violation Remarks: Remove unapproved lock on exit door.				
11/12/2019	* 2012 NFPA 101 7.2.1.5.1 Exit, while building	1			0
	<b>Notes:</b> Remove unapproved lock on exit door.				
11/12/2019	* 2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Repair or replace emergency light.				
11/12/2019	* 2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request.				
	Original Violation Remarks: Repair or replace emergency light.				
11/12/2019	* DFDFMO AHJ, Requirement	1			0
	<b>Notes:</b> Install carbon monoxide detector due to gas appliances being used.				
11/12/2019	* DFDFMO AHJ, Requirement	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request.				
	Original Violation Remarks: Install carbon monoxide detector due to gas appliances being used.				

**Total Individual Violation Codes for Occupancy: 18**

20706      El Comal Tienda Y Cocina  
616 Fourth AVE  
Suites 4,5,6  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/27/2019	2011 NFPA 96 10.9.1 Kitchen hood suppression	1			0
	<b>Notes:</b> Hood system requires up to date inspection and cleaning.				
11/27/2019	2011 NFPA 96 11.2.4 Kitchen hood suppression	1			0
	<b>Notes:</b> Hood system requires up to date inspection and cleaning.				

**\* Denotes Violations Corrected or Variance Issued**

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20706      **El Comal Tienda Y Cocina**  
616 Fourth AVE  
Suites 4,5,6  
Dalton, GA 30720

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
11/27/2019	2011 NFPA 96 11.4 Kitchen hood,  <b>Notes:</b> Hood system requires up to date inspection and cleaning.	1			0
11/27/2019	2011 NFPA 96 11.7.1 Cooking equipment, In proper  <b>Notes:</b> Pilot light inoperable on gas range.	1			0
11/27/2019	2011 NFPA 96 11.7.2 Cooking equipment,  <b>Notes:</b> Clean cooking equipment regularly.	1			0
11/27/2019	2012 IFC 505.1 Address, no suite  <b>Notes:</b> Address numbers should be a minimum of 4 inches tall and 1/2 inch wide. Numbers should be visible from road fronting the property, and be contrasting to the background. Install address signage indicating suite number.	1			0
11/27/2019	2012 IFC 605.1 Electrical panel, abatement of  <b>Notes:</b> Exposed electrical wiring requires should be covered with appropriate electrical conduit.	1			0
11/27/2019	2012 IFC 605.3 Electrical panel, obstructed  <b>Notes:</b> Clear access must be maintained around electrical panels.	1			0
11/27/2019	2012 IFC 605.4 Multi outlet adaptor  <b>Notes:</b> Multi plug outlets are required to be mounted.	1			0
11/27/2019	2012 IFC 605.5 Extension cord, Improper use  <b>Notes:</b> Extension cords shall not be used for permanent wiring	1			0
11/27/2019	2012 IFC 605.6 Electrical panel, cover not  <b>Notes:</b> Install proper covers on electrical junction boxes.	1			0
11/27/2019	2012 IFC 906.2 Fire extinguisher, Properly  <b>Notes:</b> Fire extinguisher requires up to date inspection and proper mounting.	1			0
11/27/2019	2013 NFPA 10 6.1.3.8.1 Fire extinguisher,  <b>Notes:</b> Fire extinguisher requires up to date inspection and proper mounting.	1			0
11/27/2019	2013 NFPA 10 6.6.1 Class K fire extinguisher  <b>Notes:</b> Fire extinguisher requires up to date inspection and proper mounting.	1			0

\* Denotes Violations Corrected or Variance Issued

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20706      **El Comal Tienda Y Cocina**  
               616 Fourth AVE  
               Suites 4,5,6  
               Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/27/2019	2013 NFPA 96 10.2.2 Class K placard required	1			0

**Notes:** See Annex A NFPA 10Placard must be properly mounted.

**Total Individual Violation Codes for Occupancy: 15**

20758      **Executive Management Services Inc.**  
               801 Walnut (East) AVE  
               Suite O  
               Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/11/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0

**Notes:** Replace emergency light or replace battery.

**Total Individual Violation Codes for Occupancy: 1**

20797      **Jessica Stop N Shop**  
               1101 New Doris ST  
               Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/20/2019	* 2012 IFC 505.1 Address, no suite	1			0

**Notes:** Recheck violation record automatically created from a recheck request.

Original Violation Remarks: Address numbers should be a minimum of 4 inches tall and 1/2 inch wide. Numbers should be visible from road fronting the property, and be contrasting to the background. Install required address signage as discussed.

11/20/2019	* 2012 IFC 505.1 Address, no suite	1			0
------------	------------------------------------	---	--	--	---

**Notes:** Address numbers should be a minimum of 4 inches tall and 1/2 inch wide. Numbers should be visible from road fronting the property, and be contrasting to the background. Install required address signage as discussed.

**\* Denotes Violations Corrected or Variance Issued**

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20797      Jessica Stop N Shop  
1101 New Doris ST  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/20/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box on building.				
11/20/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box on building.				
11/20/2019	2012 IFC 605.1 Electrical panel, abatement of	1			0
	<b>Notes:</b> Install blank in electrical panel.				
11/20/2019	2012 IFC 605.1 Electrical panel, abatement of	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Install blank in electrical panel.				
11/20/2019	* 2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Top of extinguisher should be no higher than 4'6". Reinstall at proper height with proper bracket.				
11/20/2019	* 2013 NFPA 10 6.1.3.8.1 Fire extinguisher,	1			0
	<b>Notes:</b> Top of extinguisher should be no higher than 4'6". Reinstall at proper height with proper bracket.				

**Total Individual Violation Codes for Occupancy: 8**

20412      Life Touch Chiropractic  
720 Glenwood (South) AVE  
100  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
<b>* Denotes Violations Corrected or Variance Issued</b>					
12/02/2019	10:08				Page

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And {11/30/2019}**

---

11/26/2019	2012 IFC 906.2 Fire extinguisher, Properly	1	0
------------	--------------------------------------------	---	---

**Notes:** Fire extinguishers should be serviced annually by a GA licensed contractor.

---

**Total Individual Violation Codes for Occupancy: 1**

20699            **Natural World**  
                  801 Walnut (East) AVE  
                  Suite K  
                  Dalton, GA 30720

---

Reported	Code/Description	Count	Article	Division	Page
11/11/2019	2012 IFC 906.2 Fire extinguisher, Properly	1			0

**Notes:** Must have annual inspection.

---

**Total Individual Violation Codes for Occupancy: 1**

50120            **Peak Fitness**  
                  1021 Riverburch PKY  
                  Dalton, GA 30721

---

Reported	Code/Description	Count	Article	Division	Page
11/22/2019	2012 IFC 506.1 Knox Box, requirements	1			0

**Notes:** Install Knox Box on building. Order at <https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992>. It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building.

11/22/2019    2012 IFC 906.2 Fire extinguisher, Properly            1            0

**Notes:** Extinguishers out of date.

11/22/2019    2012 NFPA 101 7.9.3.1.1 Emergency light,            1            0

**Notes:** Multiple emergency lights not functioning.

11/22/2019    2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire            1            0

**Notes:** Provide inspection report.

11/22/2019    2012 NFPA101 7.10.5.1 Exit sign, non functional            1            0

**Notes:** Multiple exit signs not working.

**\* Denotes Violations Corrected or Variance Issued**

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

50120      **Peak Fitness**  
 1021 Riverburch PKY  
 Dalton, GA 30721

Reported	Code/Description	Count	Article	Division	Page
11/22/2019	2013 NFPA 72 10.6.5.2.3 Fire alarm, circuit ID	1			0
<b>Notes:</b> Mark breaker.					
11/22/2019	2013 NFPA 72 10.6.5.4 Fire alarm, breaker lock	1			0
<b>Notes:</b> Add breaker lock.					
<b>Total Individual Violation Codes for Occupancy: 7</b>					

10783      **Peoples Cancer Center**  
 1215 Memorial DR  
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/12/2019	DFDFMO AHJ, Requirement	1			0
<b>Notes:</b> Revise egress routes as discussed.					
<b>Total Individual Violation Codes for Occupancy: 1</b>					

20143      **Pye Barker Fire and Safety**  
 634 Glenwood PL  
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/20/2019	2012 IFC 506.1 Knox Box, requirements	1			0
<b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box					
11/20/2019	DFDFMO AHJ, Requirement	1			0
<b>Notes:</b> Secure compressed gas cylinders.					

\* Denotes Violations Corrected or Variance Issued

**DALTON**

**Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20143 Pye Barker Fire and Safety  
634 Glenwood PL  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

**Total Individual Violation Codes for Occupancy: 2**

20757 Select Staffing  
801 Walnut (East) AVE  
Suite N  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

11/11/2019 2012 IFC 906.2 Fire extinguisher, Properly

1

0

**Notes:** Extinguishers must have annual inspection.

**Total Individual Violation Codes for Occupancy: 1**

20422 Southern Corp.  
720 Glenwood (South) AVE  
212  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

11/11/2019 2012 IFC 605.4 Multi outlet adaptor

1

0

**Notes:** Multi plug cords should be plugged directly into the wall outlet.

11/11/2019 DFDFMO AHJ, Requirement

1

0

**Notes:** Install carbon monoxide detector in suite due to gas heater being used.

**Total Individual Violation Codes for Occupancy: 2**

20702 TALC  
801 Walnut (East) AVE  
Suite I  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

**\* Denotes Violations Corrected or Variance Issued**

12/02/2019 10:08

Page 1

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20702            **TALC**  
                   801 Walnut (East) AVE  
                   Suite I  
                   Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/25/2019	2012 IFC 906.2 Fire extinguisher, Properly	1			0
<b>Notes:</b> Fire extinguisher requires annual inspection.					

**Total Individual Violation Codes for Occupancy: 1**

10808            **The Lock Guys**  
                   417 Glenwood (North) AVE  
                   Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/25/2019	2012 IFC 505.1 Address, no suite	1			0
<b>Notes:</b> Address numbers should be a minimum of 4 inches tall and 1/2 inch wide. Numbers should be visible from road fronting the property, and be contrasting to the background.					
11/25/2019	2012 IFC 506.1 Knox Box, requirements	1			0
<b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.					
11/25/2019	2012 IFC 605.4 Multi outlet adaptor	1			0
<b>Notes:</b> Need to secure multi plug adapter to the wall.					
<b>Total Individual Violation Codes for Occupancy: 3</b>					

2P001            **Ty Rutledge Properties**  
                   506 Bear Creek RD  
                   Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
<b>* Denotes Violations Corrected or Variance Issued</b>					

\* Denotes Violations Corrected or Variance Issued

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

2P001      **Ty Rutledge Properties**  
506 Bear Creek RD  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
11/27/2019	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1			0
	<b>Notes:</b> Sprinkler system requires up to date inspection.				
11/27/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box.				
11/27/2019	2012 IFC 605.1 Electrical panel, abatement of	1			0
	<b>Notes:</b> Open breaker spaces in electrical panels require blanking				
11/27/2019	2012 IFC 605.4 Multi outlet adaptor	1			0
	<b>Notes:</b> Multi plug adapter should not be plugged into an extension cord.				
11/27/2019	2012 IFC 605.5 Extension cord, Improper use	1			0
	<b>Notes:</b> Extension cords shall not be used for permanent wiring.				
11/27/2019	2012 IFC 605.6 Electrical panel, cover not	1			0
	<b>Notes:</b> Install proper outlet and junction box covers.				
11/27/2019	2012 IFC 906.2 Fire extinguisher, Properly	1			0
	<b>Notes:</b> Fire extinguishers require up to date inspection.				
11/27/2019	2012 IFC 912.2.1 FDC, location not signed	1			0
	<b>Notes:</b> Install required FDC signage.				
11/27/2019	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access	1			0
	<b>Notes:</b> Maintain clear path of egress.				
11/27/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Emergency light inoperable.				

-----  
**Total Individual Violation Codes for Occupancy: 10**

\* Denotes Violations Corrected or Variance Issued

**DALTON****Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {11/01/2019} And  
{11/30/2019}**

20695      **Vallarta**  
**801 Walnut (East) AVE**  
**Suite C**  
**Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
11/25/2019	2012 IFC 605.1 Electrical panel, abatement of  <b>Notes:</b> Blanks are required for open breaker spaces.	1			0
11/25/2019	2012 IFC 605.3 Electrical panel, obstructed  <b>Notes:</b> Maintain proper clearance around electrical panel.	1			0
11/25/2019	2012 IFC 605.5 Extension cord, Improper use  <b>Notes:</b> Cannot use extension cords for permanent wiring.	1			0

**Total Individual Violation Codes for Occupancy: 3**

30309      **Williams Plastic Surgery**  
**1506 Professional CT**  
**Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
11/27/2019	2012 IFC 506.1 Knox Box, requirements  <b>Notes:</b> Install Knox Box on building. Order at <a href="https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992">https://www.knoxbox.com/store/selectProduct.cfm?fdID=7992</a> . It should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Go to <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. As discussed.	1			0
11/27/2019	2012 IFC 605.3.1 Electrical panel, concealed  <b>Notes:</b> Install signage Indicating electrical panels and FACP.	1			0
11/27/2019	2012 NFPA 101 7.2.1.8.2.1 Firedoor, no auto  <b>Notes:</b> Fire closures must be installed on all fire doors.	1			0
11/27/2019	2013 NFPA 72 10.6.5.4 Fire alarm, breaker lock  <b>Notes:</b> Install lock on fire alarm breaker	1			0

**Total Individual Violation Codes for Occupancy: 4**

\* Denotes Violations Corrected or Variance Issued

**Grand Total Violations: 107**