

Dalton Fire Department

Dalton, GA

This report was generated on 10/19/2021 11:54:28 AM



Incident Statistics

Zone(s): All Zones | Start Date: 09/01/2020 | End Date: 09/30/2020

INCIDENT COUNT			
INCIDENT TYPE		# INCIDENTS	
EMS		186	
FIRE		91	
TOTAL		277	
TOTAL TRANSPORTS (N2 and N3)			
APPARATUS	# of APPARATUS TRANSPORTS	# of PATIENT TRANSPORTS	TOTAL # of PATIENT CONTACTS
TOTAL			
PRE-INCIDENT VALUE		LOSSES	
\$540,100.00		\$249,601.00	
CO CHECKS			
TOTAL			
MUTUAL AID			
Aid Type		Total	
Aid Given		19	
Aid Received		3	
OVERLAPPING CALLS			
# OVERLAPPING		% OVERLAPPING	
0		0	
LIGHTS AND SIREN - AVERAGE RESPONSE TIME (Dispatch to Arrival)			
Station	EMS	FIRE	
AVERAGE FOR ALL CALLS			
LIGHTS AND SIREN - AVERAGE TURNOUT TIME (Dispatch to Enroute)			
Station	EMS	FIRE	
AVERAGE FOR ALL CALLS			
AGENCY		AVERAGE TIME ON SCENE (MM:SS)	

Only Reviewed Incidents included. EMS for Incident counts includes only 300 to 399 Incident Types. All other incident types are counted as FIRE. CO Checks only includes Incident Types: 424, 736 and 734. # Apparatus Transports = # of incidents where apparatus transported. # Patient Transports = All patients transported by EMS. # Patient Contacts = # of PCR contacted by apparatus. This report now returns both NEMSIS 2 & 3 data as appropriate. For overlapping calls that span over multiple days, total per month will not equal Total count for year.

Dalton Fire Department


Dalton, GA

This report was generated on 10/19/2021 11:56:12 AM



Incidents by Day of the Week for Date Range

Start Incident Type: 100 | End Incident Type: 911 | Start Date: 09/01/2021 | End Date: 09/30/2021



DAY OF THE WEEK	# INCIDENTS
Sunday	36
Monday	47
Tuesday	44
Wednesday	65
Thursday	64
Friday	64
Saturday	48
TOTAL	368

Only Reviewed incidents included.



emergencyreporting.com

Doc Id: 1284

Page # 1 of 1

Dalton Fire Department


Dalton, GA

This report was generated on 10/19/2021 11:56:47 AM



Incidents per Hour for Incident Type Range for Date Range

Start Incident Type: 100 | End Incident Type: 911 | Start Date: 09/01/2021 | End Date: 09/30/2021



HOUR	# of CALLS
00:00 - 00:59	7
01:00 - 01:59	11
02:00 - 02:59	7
03:00 - 03:59	11
04:00 - 04:59	10
05:00 - 05:59	6
06:00 - 06:59	11
07:00 - 07:59	14
08:00 - 08:59	22
09:00 - 09:59	19
10:00 - 10:59	18
11:00 - 11:59	24
12:00 - 12:59	18
13:00 - 13:59	11
14:00 - 14:59	14
15:00 - 15:59	14
16:00 - 16:59	18
17:00 - 17:59	25
18:00 - 18:59	20
19:00 - 19:59	21
20:00 - 20:59	21
21:00 - 21:59	20
22:00 - 22:59	16
23:00 - 23:59	10
TOTAL:	368

Only REVIEWED incidents included.



Dalton Fire Department

Dalton, GA

This report was generated on 10/19/2021 11:57:35 AM



Incident Type Count per Station for Date Range

Start Date: 09/01/2021 | End Date: 09/30/2021

INCIDENT TYPE	# INCIDENTS
Station: 1 - STATION 1	
113 - Cooking fire, confined to container	2
131 - Passenger vehicle fire	1
142 - Brush or brush-and-grass mixture fire	3
143 - Grass fire	1
251 - Excessive heat, scorch burns with no ignition	1
311 - Medical assist, assist EMS crew	110
321 - EMS call, excluding vehicle accident with injury	1
322 - Motor vehicle accident with injuries	5
323 - Motor vehicle/pedestrian accident (MV Ped)	3
324 - Motor vehicle accident with no injuries.	1
350 - Extrication, rescue, other	1
410 - Combustible/flammable gas/liquid condition, other	1
444 - Power line down	1
445 - Arcing, shorted electrical equipment	1
500 - Service Call, other	1
561 - Unauthorized burning	1
600 - Good intent call, other	1
611 - Dispatched & cancelled en route	8
622 - No incident found on arrival at dispatch address	7
651 - Smoke scare, odor of smoke	3
671 - HazMat release investigation w/no HazMat	2
711 - Municipal alarm system, malicious false alarm	1
733 - Smoke detector activation due to malfunction	4
734 - Heat detector activation due to malfunction	1
735 - Alarm system sounded due to malfunction	2
743 - Smoke detector activation, no fire - unintentional	1
744 - Detector activation, no fire - unintentional	2

Incidents for 1 - Station 1:

166

Station: 2 - STATION 2	
111 - Building fire	1
142 - Brush or brush-and-grass mixture fire	1
311 - Medical assist, assist EMS crew	40
322 - Motor vehicle accident with injuries	5
324 - Motor vehicle accident with no injuries.	2
352 - Extrication of victim(s) from vehicle	1

Only REVIEWED incidents included.



emergencyreporting.com
Doc Id: 857
Page # 1 of 3

INCIDENT TYPE	# INCIDENTS
444 - Power line down	1
500 - Service Call, other	2
522 - Water or steam leak	1
611 - Dispatched & cancelled en route	7
735 - Alarm system sounded due to malfunction	2
741 - Sprinkler activation, no fire - unintentional	1
743 - Smoke detector activation, no fire - unintentional	1
745 - Alarm system activation, no fire - unintentional	2

Incidents for 2 - Station 2:

67

Station: 3 - STATION 3	
111 - Building fire	1
311 - Medical assist, assist EMS crew	40
322 - Motor vehicle accident with injuries	8
324 - Motor vehicle accident with no injuries.	1
444 - Power line down	1
461 - Building or structure weakened or collapsed	1
500 - Service Call, other	2
522 - Water or steam leak	1
611 - Dispatched & cancelled en route	6
622 - No incident found on arrival at dispatch address	4
651 - Smoke scare, odor of smoke	1
652 - Steam, vapor, fog or dust thought to be smoke	1
735 - Alarm system sounded due to malfunction	2
743 - Smoke detector activation, no fire - unintentional	1
744 - Detector activation, no fire - unintentional	1
746 - Carbon monoxide detector activation, no CO	1

Incidents for 3 - Station 3:

72

Station: 4 - STATION 4	
132 - Road freight or transport vehicle fire	1
162 - Outside equipment fire	1
311 - Medical assist, assist EMS crew	21
322 - Motor vehicle accident with injuries	3
444 - Power line down	1
445 - Arcing, shorted electrical equipment	1
553 - Public service	1
611 - Dispatched & cancelled en route	2
622 - No incident found on arrival at dispatch address	1
651 - Smoke scare, odor of smoke	1
731 - Sprinkler activation due to malfunction	1
733 - Smoke detector activation due to malfunction	1
744 - Detector activation, no fire - unintentional	1

Only REVIEWED incidents included.



INCIDENT TYPE	# INCIDENTS
745 - Alarm system activation, no fire - unintentional	1

Incidents for 4 - Station 4:

37

Station: 5 - STATION 5

311 - Medical assist, assist EMS crew	17
322 - Motor vehicle accident with injuries	1
324 - Motor vehicle accident with no injuries.	1
611 - Dispatched & cancelled en route	4
651 - Smoke scare, odor of smoke	1
733 - Smoke detector activation due to malfunction	1
745 - Alarm system activation, no fire - unintentional	1

Incidents for 5 - Station 5:

26

Only REVIEWED incidents included.



Dalton Fire Department



Dalton, GA

This report was generated on 10/19/2021 11:58:09 AM



Major Incident Types by Month for Date Range

Start Date: 09/01/2021 | End Date: 09/30/2021



INCIDENT TYPE	SEP	TOTAL
False Alarm & False Call	28	28
Fire	12	12
Good Intent Call	49	49
Hazardous Condition (No Fire)	8	8
Overpressure Rupture, Explosion, Overheat(no fire)	1	1
Rescue & Emergency Medical Service Incident	261	261
Service Call	9	9
Total	368	368

Only REVIEWED incidents included



Dalton Fire Department


Dalton, GA

This report was generated on 10/19/2021 11:58:41 AM



Count of Aid Given and Received for Incidents for Date Range

Start Date: 09/01/2021 | End Date: 09/30/2021



AID TYPE	TOTAL	% of TOTAL
Mutual aid received	1	0.3%
Automatic aid received	1	0.3%
Automatic aid given	15	4.1%
None	351	95.4%

Only REVIEWED incidents included



Dalton Fire Department

Dalton, GA

This report was generated on 10/19/2021 11:59:04 AM



Detailed Fire Losses per Incident Type for Date Range

Start Date: 09/01/2021 | End Date: 09/30/2021

INCIDENT TYPE	COUNT	% OF INCIDENTS	TOTAL LOSSES (Sum of Property and Content Loss)	% OF TOTAL
111 - Building fire	2	66.67 %	\$110,250.00	88.73 %
131 - Passenger vehicle fire	1	33.33 %	\$14,000.00	11.27 %

Only REVIEWED incidents included.



emergencyreporting.com

Doc Id: 1238

Page # 1 of 1

Dalton Fire Department

Dalton, GA

This report was generated on 10/19/2021 11:59:27 AM



Detailed Property And Contents Saved for Date Range

Start Date: 09/01/2021 | End Date: 09/30/2021

INCIDENT #	DATE	TYPE	LOCATION	PRE-INCIDENT PROPERTY	PRE-INCIDENT CONTENTS	PRE-INCIDENT TOTAL	PROP. SAVED	CONT. SAVED	TOTAL SAVED
2021-02619	09/01/2021	131 - Passenger vehicle fire	W Walnut AVE Dalton	\$14,000.00	\$0.00	\$14,000.00	\$0.00	\$0.00	\$0.00
2021-02844	09/19/2021	111 - Building fire	1011 Riverbend RD Dalton	\$140,000.00	\$35,000.00	\$175,000.00	\$65,000.00	\$0.00	\$65,000.00
2021-02954	09/28/2021	111 - Building fire	1409 Coronet DR Dalton	\$0.00	\$250.00	\$250.00	\$0.00	\$0.00	\$0.00

TOTAL PRE-INCIDENT PROPERTY	TOTAL PRE-INCIDENT CONTENT	TOTAL PRE-INCIDENT	TOTAL PROP. SAVED	TOTAL CONT. SAVED	TOTAL SAVED
\$154,000.00	\$35,250.00	\$189,250.00	\$65,000.00	\$0.00	\$65,000.00

# INCIDENTS	AVG. VAL.	AVERAGE SAVED
3	\$63,083.00	\$21,666.00

Only REVIEWED incidents included



emergencyreporting.com

Doc Id: 1834

Page # 1 of 1

Training Division Monthly Report

September 2021

Overview

Recruit Class 2021-01 continued throughout the month with 4 candidates enrolled. The department hosted the 2-day Bearers of the Oath “What’s Your Plan?” course at the training center. A total of 28 students, including 6 from DFD, were enrolled from departments throughout the state. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of September totaled 3,086.

Outside Schools

One of the department’s certified fire inspectors attended a course on commercial sprinkler system plans review at the National Fire Academy in Emmitsburg, Maryland.

Two prospective members of the department’s technical rescue team attended a 40-hour Technical Rescue – Rope course at GPSTC and attained national certification as Rope Rescue Technicians through the National Board on Fire Service Professional Qualifications and Georgia Firefighter Standards and Training Council.

Dalton Fire Department

Dalton, GA

This report was generated on 10/13/2021 8:28:48 AM



Completed Inspections per Inspection Type for Date Range

Occupancy Status: All | Start Date: 09/01/2021 | End Date: 09/30/2021

ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Alcohol						
10388 - 4	Freya	303 E Morris ST Dalton, GA 30720	09/23/2021	Daniel, Matthew T.	Passed	Alcohol approval does not include event center, nightclub or disco tech. Occupancy load shall be less than 100 persons. The occupancy load will be calculated during the final OTC inspection.

Total # Inspections for Alcohol:

1

Inspection Type: Annual						
ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
10793	Trevor A. Brown, Attorney	603 S Thornton AVE Dalton, GA 30720	09/08/2021	Stratton, Dale Lee	Passed	
11370	D&S Monuments, LLC	925 N Glenwood AVE Dalton, GA 30721	09/09/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11372	M&M Recycling	923 N Glenwood AVE Dalton, GA 30721	09/09/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11371	Le's Indoor Flea Market	911 N Glenwood AVE Dalton, GA 30721	09/09/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10141 - 1	Georgia Nutrition	901 N Glenwood AVE Dalton, GA 30720	09/10/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10141 - 2	Tercero	903 N Glenwood AVE Dalton, GA 30721	09/10/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10029 - 4	Ruth and Doyles Florist	407 N Thornton AVE #Suite 3 Dalton, GA 30720	09/10/2021	Hearn, Scott Raymond	Passed	
10029 - 3	Ruth and Doyles Warehouse	407 N Thornton AVE #Suite 1 Dalton, GA 30720	09/10/2021	Hearn, Scott Raymond	Passed	
10029 - 1	The Haymes Group Accounting/Tax Service	407 N Thornton AVE #Suite 2 Dalton, GA 30720	09/10/2021	Hearn, Scott Raymond	Passed	
11331 - 1	Innovative Risk Services	405 N Hamilton ST #1 Dalton, GA 30720	09/13/2021	Hearn, Scott Raymond	Passed	
10030 - 8	Bloom Spa and Company	825 Chattanooga AVE #30 Dalton, GA 30720	09/14/2021	Hearn, Scott Raymond	Passed	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
10141 - 4	Paeteria Y Neveria	907 N Glenwood AVE Dalton, GA 30721	09/14/2021	Stratton, Dale Lee	Corrective Action Plan Given	Corrective action plan has been provided.
10141	901-907 N. Glenwood Ave Property	907 N Glenwood AVE Dalton, GA 30721	09/14/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10139	Color Express Inc.	711 N Glenwood AVE Dalton, GA 30721	09/14/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10137	Material Handling Inc.	631 N Glenwood AVE Dalton, GA 30720	09/15/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11354	Elder Law	400 N Selvidge ST Dalton, GA 30720	09/15/2021	Blankenship, Donnie	Corrective Action Plan Given	
11356	Robert Jenkins Law Firm	408 N Selvidge ST Dalton, GA 30720	09/15/2021	Blankenship, Donnie	Corrective Action Plan Given	
11374	Jake's Enterprise, LLC	707 N Glenwood AVE Dalton, GA 30721	09/16/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10528	Whitfield County Public Schools	201 E Tyler ST Dalton, GA 30720	09/16/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11376	Dalton Food and Tobacco	601 N Glenwood AVE Dalton, GA 30721	09/20/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11379	Dollar General Store	511 N Glenwood AVE Dalton, GA 30721	09/20/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10136	Auto Zone	505 N Glenwood AVE Dalton, GA 30720	09/20/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10034	The Lock Guys	417 N Glenwood AVE Dalton, GA 30721	09/21/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10867	Dalton Funeral Home	620 S Glenwood AVE Dalton, GA 30720	09/21/2021	Blankenship, Donnie	Corrective Action Plan Given	
11381	Bigham Discount Music	409 N Glenwood AVE Dalton, GA 30721	09/21/2021	Stratton, Dale Lee	Passed	Corrective action plan has been provided.
10763	Simpson Machinery	211 Franklin (East) ST Dalton, GA 30720	09/22/2021	Blankenship, Donnie	Corrective Action Plan Given	
10788	Professional Testing Lab Inc.	714 Glenwood PL Dalton, GA 30720	09/22/2021	Blankenship, Donnie	Corrective Action Plan Given	
10863	Creative Machine Craft	700 Glenwood PL Dalton, GA 30720	09/23/2021	Blankenship, Donnie	Corrective Action Plan Given	
10862	Bio-Chem	636 Glenwood PL Dalton, GA 30720	09/23/2021	Blankenship, Donnie	Corrective Action Plan Given	
11382	Global Imports	701 N Glenwood AVE Dalton, GA 30721	09/23/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11378	Paniagua Auto Sales III	533 N Glenwood AVE Dalton, GA 30721	09/23/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
11377	Rush Tires	527 N Glenwood AVE Dalton, GA 30721	09/23/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11384	Bob's Towing	403 N Glenwood AVE Dalton, GA 30721	09/24/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11380	John's Bar-B-Q	411 N Glenwood AVE Dalton, GA 30721	09/28/2021	Stratton, Dale Lee	Passed	
10478	Wendy's	1140 N Glenwood AVE Dalton, GA 30720	09/28/2021	Hearn, Scott Raymond	Passed	
10445	Advance Auto Parts	1130 N Glenwood AVE Dalton, GA 30720	09/28/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10152	Performance Cycle	1008 N Glenwood AVE Dalton, GA 30720	09/28/2021	Hearn, Scott Raymond	Passed	
10135	Remax Select Realty	321 N Glenwood AVE Dalton, GA 30721	09/28/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10134	Langford Appliance	319 N Glenwood AVE Dalton, GA 30720	09/28/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10310	Floor Production LLC	414 W Hawthorne ST Dalton, GA 30720	09/30/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10501	First Baptist Church	311 N Thornton AVE Dalton, GA 30720	09/30/2021	Hearn, Scott Raymond	Passed	
10501 - 1	First Baptist Church Childrens Learning Center	311 N Thornton AVE Dalton, GA 30720	09/30/2021	Hearn, Scott Raymond	Passed	

Total # Inspections for Annual: 42

Inspection Type: Annual Apartment						
10149	T&Q Auto Repair	911 N Glenwood AVE Dalton, GA 30720	09/09/2021	Stratton, Dale Lee	Passed	

Total # Inspections for Annual Apartment: 1

Inspection Type: Fireworks						
10184	DPS-Morris Innovative High School	104 Fort Hill TER Dalton, GA 30720	09/15/2021	Stratton, Dale Lee	Passed with Comments	Inspected the site for fireworks layout, scheduled for 20210918.
10184	DPS-Morris Innovative High School	104 Fort Hill TER Dalton, GA 30720	09/18/2021	Stratton, Dale Lee	Passed	

Total # Inspections for Fireworks: 2

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: New Construction						
10896 - 11	Bath and Body Works	1318 W Walnut AVE #Suite 1 Dalton, GA 30720	09/09/2021	Hearn, Scott Raymond	Passed	
10192	Benjamin F Edwards & Co.	210 N Hamilton ST Dalton, GA 30720	09/28/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Address numbers and Knox Box.

Total # Inspections for New Construction: 2

Inspection Type: OTC						
10302 - 8	Kaya Flower Co.	305 E Hawthorne ST # H Dalton, GA 30720	09/01/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguisher and electrical drops.
10343	Whitfield Healthcare Foundation	507 S Thornton AVE Dalton, GA 30720	09/03/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Address on front of building.
11320 - 12	T- Mobile	1333 W Walnut AVE Dalton, GA 30720	09/09/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguisher needs inspection.
11369	Exclusive Auto Center	1127 N Glenwood AVE Dalton, GA 30721	09/09/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Add extinguisher.
10374 - 1	Social Lounge	511 E Morris ST #100 Dalton, GA 30720	09/16/2021	Hearn, Scott Raymond	Passed	
10896 - 11	Bath and Body Works	1318 W Walnut AVE #Suite 1 Dalton, GA 30720	09/21/2021	Stratton, Dale Lee	Passed	
10192	Benjamin F Edwards & Co.	210 N Hamilton ST Dalton, GA 30720	09/28/2021	Hearn, Scott Raymond	Passed	
11385	Buenas Nuevas	1401 E Morris ST Dalton, GA 30720	09/30/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Add extinguishers.

Total # Inspections for OTC: 8

Inspection Type: Plan Review						
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	09/02/2021	Daniel, Matthew T.	Passed	HMC Cardiology Suite.
11268	Wal-Mart	815 Shugart RD Dalton, GA 30720	09/02/2021	Daniel, Matthew T.	Passed	Fire Alarm modification.
11218	Dalton Mall	816 Walnut Square BLVD Dalton, GA 30720	09/08/2021	Daniel, Matthew T.	Passed	Mall restroom renovations.
10883	Georgia Meat Distribution	645 S Hamilton ST Dalton, GA 30721	09/15/2021	Daniel, Matthew T.	Passed	Sprinkler plan review.

Total # Inspections for Plan Review: 4

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10388	Eclectic 79	315 E Morris ST Dalton, GA 30720	09/01/2021	Hearn, Scott Raymond	Passed with Comments	Discussed plan submissions and possible sprinkler requirements.
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	09/01/2021	Blankenship, Donnie	Passed with Comments	Met with EPD Representative John Maddox, Legal Council for the owner Martin A. Shelton, and Kemron Environmental Service Representative Don Rigger to discuss the clean up process of chemicals on site. They advised that they were going to secure the structure, and once the primary site in Catoosa County has been mitigated they will start the process on Virgil Drive. This could take place as early as next week. I advised Kemron to contact me prior to work being started so that we are prepared for response. I advised Mr. Shelton that a Knox Box would need to be installed on the building so that we had access.
10389	Core Scientific	206 Boring DR Dalton, GA 30721	09/02/2021	Blankenship, Donnie	Passed with Comments	Myself and Inspector Hearn performed an fire alarm test, and egress lighting test.
10289	Belk-Gallant Lofts	307 S Hamilton ST Dalton, GA 30721	09/02/2021	Blankenship, Donnie	Passed with Comments	I accompanied Building Inspector Josh Burgess on a wall cover up inspection on the third floor. There were a few concerns with the fire wall and it was addressed with the contractor. We discussed the HVAC duct that penetrates both sides of the fire wall with the general contractor and HVAC contractor, the HVAC contractor advised that he would get with his superiors to review the concerns.
10739	Walnut Creek	1115 W Walnut AVE Dalton, GA 30720	09/03/2021	Blankenship, Donnie	Passed	Installed keys in Knox Box.
10687	DPS-Blue Ridge Elementary Schools	100 S Bogle ST Dalton, GA 30721	09/03/2021	Blankenship, Donnie	Passed with Comments	I met with Kevin Bruce to discuss installing a kiln.
10388 - 4	Freya	303 E Morris ST Dalton, GA 30720	09/06/2021	Daniel, Matthew T.	Passed	Building layout meeting.
10294	Kohl's	835 Shugart RD Dalton, GA 30720	09/07/2021	Blankenship, Donnie	Corrective Action Plan Given	
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	09/08/2021	Daniel, Matthew T.	Passed	Met with contractor on securing the structure.
11103	Global Textile Services	1301 S Thornton AVE Dalton, GA 30720	09/08/2021	Daniel, Matthew T.	Corrective Action Plan Given	Met with ASA Fire and discussed false alarm. The alarm went out of test unexpectedly.
10289	Belk-Gallant Lofts	307 S Hamilton ST Dalton, GA 30721	09/08/2021	Blankenship, Donnie	Passed	Met with the contractor to discuss the HVAC system penetrating fire walls.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10237	All Chem	437 N Hamilton ST Dalton, GA 30720	09/08/2021	Stratton, Dale Lee	Passed with Comments	Met with Paul Alderman to place keys in the Knox box.
11373	Dalton Utilities Transfer Station	915 Elk ST Dalton, GA 30720	09/08/2021	Daniel, Matthew T.	Passed	Verified there was no further installation of three containers.
10909	Lynx Recycling	1019 S Hamilton ST Dalton, GA 30721	09/08/2021	Daniel, Matthew T.	Passed	Occupancy check. Verified no further recycled material had been placed in the structure.
10971	ProGlobal Products	2493 Abutment RD Dalton, GA 30720	09/08/2021	Blankenship, Donnie	Passed	Met with Mark Phillips to install keys in a Knox Box. Mr. Phillips request for me to walk through the building, and advise of any code issues found. I advised Mr. Phillips to have the fire alarm inspected, add emergency lighting, add exit signage, and have sprinkler system deficiencies corrected.
10388 - 4	Freya	303 E Morris ST Dalton, GA 30720	09/09/2021	Daniel, Matthew T.	Passed	Spray foam inspection and test.
11250	Holiday Inn Express	934 Market ST Dalton, GA 30720	09/13/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Repair camera. Repair detector.
11331 - 1	Innovative Risk Services	405 N Hamilton ST #1 Dalton, GA 30720	09/14/2021	Hearn, Scott Raymond	Passed	
11343	Brian R. Chan & Associates	319 N Selvidge ST Dalton, GA 30720	09/14/2021	Blankenship, Donnie	Passed with Comments	Myself, Chief Daniel, and Building Official Mike Fowler met with the property owner in regards to turning the building into a Bed and Breakfast. We advised them on code requirements.
11218 - 37	Chick-Fil-A	816 Walnut Square BLVD #Suite 54 Dalton, GA 30720	09/14/2021	Hearn, Scott Raymond	Passed	
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	09/15/2021	Blankenship, Donnie	Passed	Met with Scott of TU Parks in regards to firewalls being sealed properly. All work appeared to be code compliant.
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	09/15/2021	Blankenship, Donnie	Passed	Met with Charles from Brassfield & Gore in regards to construction that was fixing to begin in the SICU.
10504	Oakhaven	216 Fort Hill TER Dalton, GA 30720	09/16/2021	Hearn, Scott Raymond	Passed	
10956 - 16	Balance Food Co.	509 Benjamin WAY #500 Dalton, GA 30721	09/16/2021	Hearn, Scott Raymond	Passed	
10675	The Cliffs Apartments	818 Shugart RD Dalton, GA 30720	09/16/2021	Hearn, Scott Raymond	Corrective Action Plan Given	We need a meeting.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
11375	Monarch Day Spa	308 S Hamilton ST Dalton, GA 30720	09/16/2021	Hearn, Scott Raymond	Passed	
10279	Vacant	308 N Hamilton ST Dalton, GA 30720	09/16/2021	Hearn, Scott Raymond	Passed	
10473	GW Global	705 Straight ST Dalton, GA 30720	09/16/2021	Hearn, Scott Raymond	Passed	
10332	Christian Heritage Elementary School	1600 MLK Jr. BLVD Dalton, GA 30720	09/17/2021	Hearn, Scott Raymond	Passed	
10389	Core Scientific	206 Boring DR Dalton, GA 30721	09/17/2021	Hearn, Scott Raymond	Passed	
10343	Whitfield Healthcare Foundation	507 S Thornton AVE Dalton, GA 30720	09/17/2021	Stratton, Dale Lee	Passed with Comments	Placed building access key in the Knox Box.
11084	Dalton State College	650 College DR Dalton, GA 30720	09/20/2021	Daniel, Matthew T.	Passed	FOIA Roadrunner place.
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	09/20/2021	Daniel, Matthew T.	Passed	Checked site security and knoxbox.
10034	The Lock Guys	417 N Glenwood AVE Dalton, GA 30721	09/21/2021	Stratton, Dale Lee	Passed	Placed keys in the Knox Box: 1) interior offices 2) key FOB to operate the magnetic lock to the front door.
10061	Farmers	108 N Pentz ST Dalton, GA 30720	09/22/2021	Blankenship, Donnie	Corrective Action Plan Given	
10990	The New Flat Rate	404 McGhee DR Dalton, GA 30720	09/22/2021	Blankenship, Donnie	Passed	
10568	Extruded Fiber's Warehouse	101 Westcott WAY Dalton, GA 30720	09/23/2021	Stratton, Dale Lee	Passed	Placed keys to the building in the Knox Box.
10570	Extruded Fibers	112 Westcott WAY Dalton, GA 30720	09/23/2021	Stratton, Dale Lee	Passed	Placed keys to the building in the Knox Box.
10252	Bear Paper Tube	817 N Hamilton ST Dalton, GA 30720	09/23/2021	Stratton, Dale Lee	Passed	Placed keys to the building in the Knox Box.
10528	Whitfield County Public Schools	201 E Tyler ST Dalton, GA 30720	09/23/2021	Stratton, Dale Lee	Corrective Action Plan Given	Existing fire alarm must be maintained in proper working condition. Knox box must be keyed for City of Dalton Fire Department.
11208	R. E. Carroll Inc.	1507 Byron ST Dalton, GA 30720	09/24/2021	Stratton, Dale Lee	Passed with Comments	Inspectors Stratton and Blankenship, attended a meeting conducted by RE Carroll company representatives to discuss tank storage requirements and state submission requirements.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10876	Lisa's Café	410 S Hamilton ST Dalton, GA 30720	09/24/2021	Stratton, Dale Lee	Passed	Placed keys to the building in the Knox Box.
10289	Belk-Gallant Lofts	307 S Hamilton ST Dalton, GA 30721	09/27/2021	Daniel, Matthew T.	Passed	Fire wall inspection second floor no issues.
11094	Greater Works of Dalton	1001 S Thornton AVE Dalton, GA 30720	09/27/2021	Daniel, Matthew T.	Passed	Discussed alcohol license requirements for adjacent property with property owner.
10293 - 11	Vacant	111 W King ST Dalton, GA 30720	09/27/2021	Daniel, Matthew T.	Passed	Discussed sprinkler system requirements for the building.
10498	Taco Bell	1242 N Glenwood AVE Dalton, GA 30721	09/27/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.
11239	Bojangle's	1253 N Glenwood AVE Dalton, GA 30721	09/27/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.
10418	Popeyes	1247 N Glenwood AVE Dalton, GA 30720	09/27/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.
10459	First Methodist Church	500 S Thornton AVE Dalton, GA 30720	09/30/2021	Hearn, Scott Raymond	Passed	
10770	Cargill Chemical	208 Brookhollow Ind. BLVD Dalton, GA 30720	09/30/2021	Blankenship, Donnie	Passed	Performed in service testing on new pre-action/deluge fire sprinkler systems.

Total # Inspections for Site Visit:

50

Inspection Type: Sprinkler System						
10770	Cargill Chemical	208 Brookhollow Ind. BLVD Dalton, GA 30720	09/30/2021	Daniel, Matthew T.	Passed	

Total # Inspections for Sprinkler System:

1

TOTAL # INSPECTIONS: 111

Includes LOCKED inspections for both archived and unarchived occupancy records.



Dalton Fire Department

Dalton, GA

This report was generated on 10/13/2021 8:25:49 AM



Occupancy Inspection History per Occupancy with Violations

Inspection Observations: CORRECTIVE ACTION PLAN, FAIL | Occupancy Categories: All Categories | Start Date: 09/01/2021 | End Date: 09/30/2021

INSPECTION DATE	INSPECTION TYPE	RESULT	NOTES	QUESTION	REMARKS	OBSERVATION
Engine 1 A Shift						
Dollar General Store - 511 N Glenwood AVE						
09/20/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install blank in open space in the electrical panel.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN
Floor Production LLC - 414 W Hawthorne ST - 706.529.4812						
09/30/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?		CORRECTIVE ACTION PLAN
				Are exits, other than main exits properly marked?		CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace emergency lighting.	CORRECTIVE ACTION PLAN
				Are doors, passages, or stairways that could be mistaken as an exit marked NO EXIT?		CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
The Lock Guys - 417 N Glenwood AVE - 706.581.7215						
09/21/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN
Engine 1 B Shift						

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



901-907 N. Glenwood Ave Property - 907 N Glenwood AVE						
09/14/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN
Benjamin F Edwards & Co. - 210 N Hamilton ST						
09/28/2021	New Construction	Corrective Action Plan Given	Address numbers and Knox Box.	Is address signage correct and in place?	Add numbers.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
Elder Law - 400 N Selvidge ST - 706-428-0888						
09/15/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Secure light fixture properly. Extension cords should only be used for temporary power. Secure electrical outlet to wall. Install blank in electrical panel.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Contact a GA licensed fire extinguisher contractor to install approved fire extinguisher.	CORRECTIVE ACTION PLAN
Exclusive Auto Center - 1127 N Glenwood AVE						
09/09/2021	OTC	Corrective Action Plan Given	Add extinguisher.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add extinguisher.	CORRECTIVE ACTION PLAN
Georgia Nutrition - 901 N Glenwood AVE						
09/10/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panel. Install junction box covers on open junction boxes containing electrical wire splices.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguisher requires a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Langford Appliance - 319 N Glenwood AVE - 706-278-6399

09/28/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Material Handling Inc. - 631 N Glenwood AVE

09/15/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Remove all foreign attachments and impingements from natural gas supply piping.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	1) Multi plug adapters shall not be plugged into multi plug adapters. Extension cords shall not be plugged into multi plug adapters. Extension cords shall not be plugged into extension cords. 2) Blanks must be installed in open spaces in electrical panels. 3) Junction boxes containing electrical wire splices must be properly covered with a junction box cover. 4) Extension cords shall not substitute permanent electrical wiring.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Ensure stairwells remain free of obstructions.	CORRECTIVE ACTION PLAN
				Are the installed sprinkler systems code compliant?	1) Install RISER ROOM sign on the door to the room concealing the sprinkler riser. 2) Hydraulic calculation plate must be stamped or etched. 3) Remove all foreign attachments and impingements from sprinkler supply piping.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Paeteria Y Neveria - 907 N Glenwood AVE

09/14/2021	Annual	Corrective Action Plan Given	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Maintain 36" clearance in front of electrical panel. Install switch plate cover. Extension cords shall not be plugged into extension cords. Extension cords shall not substitute permanent electrical wiring.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	---	--	--	------------------------

Remax Select Realty - 321 N Glenwood AVE - 706-277-3434

09/28/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all exit signs and emergency lighting that does not operate as designed. Remove exit sign obstructions.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install ELECTRICAL ROOM sign on the door concealing the electrical panel.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Multi plug adapters shall be mounted according to manufacturers recommended specifications. Ensure proper installment of electrical outlets. Install outlet covers on all electrical outlets.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Replace address numbers.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Exit doors must remain unlocked while the building is occupied.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Robert Jenkins Law Firm - 408 N Selvidge ST

09/15/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Multiplug adapters should be secured instead of laying on the floor. Install cover over electrical outlet. Combustibles should be at least 3 feet from electrical panels.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Address signage should be visible from the road fronting the property.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Contact a GA licensed fire extinguisher contractor to install approved fire extinguisher.	CORRECTIVE ACTION PLAN

Tercero - 903 N Glenwood AVE

09/10/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Multi plug adapters must be mounted according to manufacturers recommended specifications. Multi plug adapters shall not be plugged into multi plug adapters. Extension cords shall not be plugged into multi plug adapters.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install a fire extinguisher. The fire extinguisher must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Engine 1 C Shift

Global Imports - 701 N Glenwood AVE - 706-529-2886

09/23/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install address sign.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Maintain clear paths of egress.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguisher requires a current annual. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Rush Tires - 527 N Glenwood AVE - 706-529-6412

09/23/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Cover exposed electrical wiring.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Replace address signage on the mailbox.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers must be accessible. Fire extinguishers require a current annual inspection tag. The extinguisher must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Engine 2 A Shift

Simpson Machinery - 211 Franklin (East) ST - 706-529-9446

09/22/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Repair or replace emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace exit signage.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Extension cords should only be used for temporary power. Remove combustibles near electrical panels. Exposed electrical wiring should be in conduit.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have a GA licensed fire extinguisher contractor perform a annual inspection on all extinguishers. Hang fire extinguishers.	CORRECTIVE ACTION PLAN

Engine 4 A Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Bio-Chem - 636 Glenwood PL - 1-844-900-2244

09/23/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Remove dead electrical wiring. Extension cords should only be used for temporary power. Keep combustibles a minimum of 3 feet from electrical panels.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Ensure egress doors operate properly in case of emergency.	CORRECTIVE ACTION PLAN
				Have sprinklers been maintained and in operational condition?	Have fire sprinkler system inspected by a GA licensed contractor.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have a GA licensed fire extinguisher contractor perform a annual inspection on all fire extinguishers.	CORRECTIVE ACTION PLAN

Creative Machine Craft - 700 Glenwood PL - 706-516-0077

09/23/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Repair or replace emergency lighting	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace exit signage.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Extension cords should only be used for temporary power.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Dalton Funeral Home - 620 S Glenwood AVE - 706-529-5371

09/21/2021	Annual	Corrective Action Plan Given		Have all applicable code requirements been met?	Install Riser room signage on door.	CORRECTIVE ACTION PLAN
				Is a fire alarm installed where required by the Code?	Fire alarm pull stations shall be accessible. Email a copy of the fire alarm inspection report.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Mount multiplug adapters to keep them off the floor.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box on the building.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Remove tree in front of egress doors.	CORRECTIVE ACTION PLAN
				Have sprinklers been maintained and in operational condition?	Email a copy of the current fire sprinkler report.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Don't block fire extinguishers.	CORRECTIVE ACTION PLAN

T- Mobile - 1333 W Walnut AVE - 706-529-7999

09/09/2021	OTC	Corrective Action Plan Given	Extinguisher needs inspection.	Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have current inspection.	CORRECTIVE ACTION PLAN
				Do the fire extinguishers have the appropriate inspection tag required by law?		CORRECTIVE ACTION PLAN

Engine 4 C Shift

Whitfield Healthcare Foundation - 507 S Thornton AVE

09/03/2021	OTC	Corrective Action Plan Given	Address on front of building.	Is address signage correct and in place?	Add address numbers to building.	CORRECTIVE ACTION PLAN
------------	-----	------------------------------	-------------------------------	--	----------------------------------	------------------------

Engine 5 A Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Jake's Enterprise, LLC - 707 N Glenwood AVE

09/16/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Multi plug adapters shall not be plugged into multi plug adapters. Extension cords shall not be plugged into multi plug adapters. Extension cords shall not be plugged into extension cords. Multi plug adapters must be mounted according to manufacturers recommended specifications. Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Engine 5 B Shift

Advance Auto Parts - 1130 N Glenwood AVE - 706-279-3632

09/28/2021	Annual	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	--	--	---------------------------	------------------------

Dalton Food and Tobacco - 601 N Glenwood AVE

09/20/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguisher must be properly mounted. Fire extinguisher requires a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Taco Bell - 1242 N Glenwood AVE - 706-259-3390

09/27/2021	Site Visit	Passed with Comments	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.	Have all applicable code requirements been met?	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.	CORRECTIVE ACTION PLAN
------------	------------	----------------------	---	---	---	------------------------

Engine 5 C Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Bojangle's - 1253 N Glenwood AVE - 706-226-7975

09/27/2021	Site Visit	Passed with Comments	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.	Have all applicable code requirements been met?	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.	CORRECTIVE ACTION PLAN
------------	------------	----------------------	---	---	---	------------------------

Paniagua Auto Sales III - 533 N Glenwood AVE - 706-529-6412

09/23/2021	Annual	Passed with Comments	Corrective action plan has been provided	Is address signage correct and in place?	Install address sign as discussed.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	--	--	------------------------------------	------------------------

Popeyes - 1247 N Glenwood AVE - 706-400-6355

09/27/2021	Site Visit	Passed with Comments	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.	Have all applicable code requirements been met?	Site visit conducted to ensure restaurant doors remain unlocked while customers are present in the dining facility.	CORRECTIVE ACTION PLAN
------------	------------	----------------------	---	---	---	------------------------

Professional Testing Lab Inc. - 714 Glenwood PL - 706-226-3283

09/22/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Install emergency lighting as needed.	CORRECTIVE ACTION PLAN
				Are exits, other than main exits properly marked?	Install exit signage above egress door.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install blanks in electrical panels. Combustibles shall be a minimum of 3 feet away from the electrical panels. Extension cords should only be used for temporary power.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have a Ga licensed fire extinguisher contractor perform a annual inspection on all fire extinguishers. Hang fire extinguishers. Travel distance to fire extinguishers shall not exceed 75 feet.	CORRECTIVE ACTION PLAN

Ladder 3 A Shift

D&S Monuments, LLC - 925 N Glenwood AVE - 706-270-9777

09/09/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	---	--	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Ladder 3 B Shift**Le's Indoor Flea Market - 911 N Glenwood AVE**

09/09/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Electrical wiring must be installed in conduit or covered by the appropriate materials.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install a fire extinguisher. The extinguisher must be mounted. The extinguisher must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

The Cliffs Apartments - 818 Shugart RD - 706-271-7265

09/16/2021	Site Visit	Corrective Action Plan Given	We need a meeting.	Have all applicable code requirements been met?	Need a meeting ASAP in regards to contact information.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--------------------	---	--	------------------------

Ladder 3 C Shift**Kohl's - 835 Shugart RD - 706-272-0015**

09/07/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Spoke with Madelyn, and advised her that duct detectors shall be set to a supervisory signal instead of alarm.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	--	------------------------

M&M Recycling - 923 N Glenwood AVE - 706-272-3127

09/09/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install outlet covers and switch plate covers. Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

The Haymes Group Accounting/Tax Service - 407 N Thornton AVE #Suite 2- 7062261858

09/10/2021	Annual	Passed		Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add extinguisher to building.	CORRECTIVE ACTION PLAN
------------	--------	--------	--	---	-------------------------------	------------------------

Squad 1 A Shift**All Chem - 437 N Hamilton ST - 706-226-4080**

09/08/2021	Site Visit	Passed with Comments	Met with Paul Alderman to place keys in the knox box.	Have all applicable code requirements been met?	Met with Paul Alderman to place keys in the knox box.	CORRECTIVE ACTION PLAN
------------	------------	----------------------	---	---	---	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Bigham Discount Music - 409 N Glenwood AVE

09/21/2021	Annual	Passed	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panels. Maintain 36" clearance around electrical panels. Multi plug adapters must be mounted according to manufacturers recommended specifications. Multi plug adapters shall not be plugged into multi plug adapters. Extension cords shall not be plugged into multi plug adapters. Extension cords shall not be plugged into extension cords.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install and mount a fire extinguisher. The extinguisher must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Kaya Flower Co. - 305 E Hawthorne ST # H

09/01/2021	OTC	Corrective Action Plan Given	Extinguisher and electrical drops.	Are there any identifiable electrical hazards?	Add electrical.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add extinguisher from a licensed Georgia contractor.	CORRECTIVE ACTION PLAN

Squad 1 B Shift

Auto Zone - 505 N Glenwood AVE - 706-226-7688

09/20/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Bob's Towing - 403 N Glenwood AVE - 706-529-2627

09/24/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Is address signage correct and in place?	Install address signage as discussed.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers must be mounted. Fire extinguishers must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Squad 1 C Shift

Color Express Inc. - 711 N Glenwood AVE - 706-278-0158

09/14/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install outlet covers and switch plate covers. Wire splices must be installed in a junction box. Junction boxes containing electrical wire splices must be properly covered with a junction box cover.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	--	--	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Whitfield County Public Schools - 201 E Tyler ST - 706-876-3955

09/16/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Is required emergency lighting in place?	Install emergency lighting in stairwells. Install emergency lighting throughout the warehouse.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all exit signs that do not operate as designed. Install exit signs in warehouse storage partitions	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install railing on second floor stairwell landing.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Multi plug adapters must be mounted according to manufacturers recommended specifications. Multi plug adapters shall not be plugged into multi plug adapters. Extension cords shall not be plugged into multi plug adapters. Extension cords shall not be plugged into extension cords. Install outlet covers on all electrical outlets. Extension cords shall not substitute permanent electrical wiring. Install junction box covers on all junction boxes containing electrical wire splices. Maintain proper clearance in front of electrical panels.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Remove all obstructions from stairwell egress.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Extinguishers must be properly mounted. Remove all fire extinguisher obstructions.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



09/23/2021	Site Visit	Corrective Action Plan Given	Existing fire alarm must be maintained in proper working condition. Knox box must be keyed for City of Dalton Fire Department.	Have all applicable code requirements been met?	Existing fire alarm must be maintained in proper working condition. Knox Box must be keyed for the City of Dalton.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	---	---	---	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Dalton Fire Department

Dalton, GA

This report was generated on 10/13/2021 8:27:51 AM



Count of Occupancies Inspected per Occupancy Type per Inspection Type for Date Range

Start Date: 09/01/2021 | End Date: 09/30/2021

OCCUPANCY	COUNT
INSPECTION TYPE: Alcohol	
A-2 • Eating, drinking places, (other)	1
INSPECTION TYPE: Annual	
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	2
A-3 • Funeral parlors	1
A-3 • Places of religious worship	1
B • Business office	6
B • Motor vehicle or boat sales, services, repair	6
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	3
B • Specialty shop	2
E • Day care, in commercial property	1
F-1 • Manufacturing, processing	3
F-1: Moderate-hazard factory industrial	1
F-2: Low-hazard factory industrial	1
M • Convenience stores	2
M • General retail, (other)	1
M • Greenhouses for display and sale of plants that provide public access	1
M • Grocery store	3
M • Household goods, sales, repairs	1
M • Retail or wholesale stores	3
M • Service station, gas station	1
M: Mercantile (other)	2
S-1 • Warehouse	1
INSPECTION TYPE: Annual Apartment	
M • Service station, gas station	1
INSPECTION TYPE: Fireworks	
E • High school/junior high school/middle school	2
INSPECTION TYPE: New Construction	
B • Business office	1
M • Department stores	1
INSPECTION TYPE: OTC	
A-3 • Pool and billiard parlors	1
B • Business office	2
B • Motor vehicle or boat sales, services, repair	1
B • Specialty shop	1
M • Markets	1
M • Department stores	1

Locked inspections only.



emergencyreporting.com

Doc Id: 1132

Page # 1 of 2

OCCUPANCY	COUNT
M: Mercantile (other)	1
INSPECTION TYPE: Plan Review	
B • Business, (other)	2
I-2 • Hospitals	1
M • General retail, (other)	1
INSPECTION TYPE: Site Visit	
A-2 • Eating, drinking places, (other)	4
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	3
A-3 • Places of religious worship	1
B • Business office	6
B • Business, (other)	1
B • Educational occupancies for students above the 12th grade (college)	1
B • Electronic data processing	2
B • Personal service, including barber & beauty shops	3
B • Specialty shop	1
E • Elementary school, including kindergarten	2
F-1 • Carpets and rugs (includes cleaning)	1
F-1 • Manufacturing, processing	3
H-4 • Highly toxic materials	1
I-2 • Hospitals	2
M • General retail, (other)	1
M • Household goods, sales, repairs	1
R-1 • Hotels (transient)	1
R-2 • Apartment houses	1
R-2 • Multifamily dwelling	3
R-4 • Residential board and care facilities	1
R-4 • Social rehabilitation facilities	1
S-1 • Warehouse	4
S-1: Storage, Moderate-hazard	4
U • Electrical distribution	1
U • Mixed use	1
INSPECTION TYPE: Sprinkler System	
H-4 • Highly toxic materials	1
Total # of Inspections:	111

Locked inspections only.

