

# Dalton Fire Department

Dalton, GA

This report was generated on 9/10/2021 3:56:05 PM



## Incident Statistics

Zone(s): All Zones | Start Date: 08/01/2021 | End Date: 08/31/2021

INCIDENT COUNT			
INCIDENT TYPE		# INCIDENTS	
EMS		275	
FIRE		136	
<b>TOTAL</b>		<b>411</b>	
TOTAL TRANSPORTS (N2 and N3)			
APPARATUS	# of APPARATUS TRANSPORTS	# of PATIENT TRANSPORTS	TOTAL # of PATIENT CONTACTS
<b>TOTAL</b>			
PRE-INCIDENT VALUE		LOSSES	
<b>\$5,426,400.00</b>		<b>\$240,600.00</b>	
CO CHECKS			
424 - Carbon monoxide incident		2	
736 - CO detector activation due to malfunction		1	
<b>TOTAL</b>		<b>3</b>	
MUTUAL AID			
Aid Type		Total	
Aid Given		12	
Aid Received		5	
OVERLAPPING CALLS			
# OVERLAPPING		% OVERLAPPING	
130		31.63	
LIGHTS AND SIREN - AVERAGE RESPONSE TIME (Dispatch to Arrival)			
Station	EMS	FIRE	
Station 1	0:03:45	0:04:21	
Station 2	0:04:32	0:06:12	
Station 3	0:04:21	0:06:12	
Station 4	0:05:16	0:04:15	
Station 5	0:04:57	0:05:13	
<b>AVERAGE FOR ALL CALLS</b>		<b>0:04:33</b>	
LIGHTS AND SIREN - AVERAGE TURNOUT TIME (Dispatch to Enroute)			
Station	EMS	FIRE	
Station 1	0:00:51	0:01:12	
Station 2	0:01:07	0:01:32	
Station 3	0:01:02	0:01:19	

Only Reviewed Incidents included. EMS for Incident counts includes only 300 to 399 Incident Types. All other incident types are counted as FIRE. CO Checks only includes Incident Types: 424, 736 and 734. # Apparatus Transports = # of incidents where apparatus transported. # Patient Transports = All patients transported by EMS. # Patient Contacts = # of PCR contacted by apparatus. This report now returns both NEMSIS 2 & 3 data as appropriate. For overlapping calls that span over multiple days, total per month will not equal Total count for year.

Station 4	0:01:12	0:00:58
Station 5	0:01:03	0:01:10
<b>AVERAGE FOR ALL CALLS</b>		<b>0:01:03</b>
<b>AGENCY</b>		<b>AVERAGE TIME ON SCENE (MM:SS)</b>
Dalton Fire Department		22:04

Only Reviewed Incidents included. EMS for Incident counts includes only 300 to 399 Incident Types. All other incident types are counted as FIRE. CO Checks only includes Incident Types: 424, 736 and 734. # Apparatus Transports = # of incidents where apparatus transported. # Patient Transports = All patients transported by EMS. # Patient Contacts = # of PCR contacted by apparatus. This report now returns both NEMSIS 2 & 3 data as appropriate. For overlapping calls that span over multiple days, total per month will not equal Total count for year.

# Dalton Fire Department


Dalton, GA

This report was generated on 9/10/2021 3:57:31 PM



## Incidents by Day of the Week for Date Range

Start Incident Type: 100 | End Incident Type: 911 | Start Date: 08/01/2021 | End Date: 08/31/2021



DAY OF THE WEEK	# INCIDENTS
Sunday	71
Monday	72
Tuesday	62
Wednesday	48
Thursday	59
Friday	51
Saturday	48
<b>TOTAL</b>	<b>411</b>

Only Reviewed incidents included.



emergencyreporting.com

Doc Id: 1284

Page # 1 of 1

# Dalton Fire Department


Dalton, GA

This report was generated on 9/10/2021 3:58:04 PM



## Incidents per Hour for Incident Type Range for Date Range

Start Incident Type: 100 | End Incident Type: 911 | Start Date: 08/01/2021 | End Date: 08/31/2021



HOUR	# of CALLS
00:00 - 00:59	9
01:00 - 01:59	7
02:00 - 02:59	6
03:00 - 03:59	6
04:00 - 04:59	7
05:00 - 05:59	6
06:00 - 06:59	7
07:00 - 07:59	10
08:00 - 08:59	16
09:00 - 09:59	27
10:00 - 10:59	25
11:00 - 11:59	34
12:00 - 12:59	23
13:00 - 13:59	24
14:00 - 14:59	27
15:00 - 15:59	18
16:00 - 16:59	23
17:00 - 17:59	29
18:00 - 18:59	18
19:00 - 19:59	23
20:00 - 20:59	12
21:00 - 21:59	18
22:00 - 22:59	21
23:00 - 23:59	15
<b>TOTAL:</b>	<b>411</b>

Only REVIEWED incidents included.



# Dalton Fire Department

Dalton, GA

This report was generated on 9/10/2021 3:58:37 PM



## Incident Type Count per Station for Date Range

Start Date: 08/01/2021 | End Date: 08/31/2021

INCIDENT TYPE	# INCIDENTS
<b>Station: 1 - STATION 1</b>	
111 - Building fire	1
113 - Cooking fire, confined to container	1
311 - Medical assist, assist EMS crew	111
322 - Motor vehicle accident with injuries	7
323 - Motor vehicle/pedestrian accident (MV Ped)	1
324 - Motor vehicle accident with no injuries.	2
341 - Search for person on land	1
411 - Gasoline or other flammable liquid spill	1
424 - Carbon monoxide incident	1
444 - Power line down	2
445 - Arcing, shorted electrical equipment	2
500 - Service Call, other	5
553 - Public service	1
561 - Unauthorized burning	2
600 - Good intent call, other	1
611 - Dispatched & cancelled en route	13
622 - No incident found on arrival at dispatch address	3
735 - Alarm system sounded due to malfunction	2
736 - CO detector activation due to malfunction	1
743 - Smoke detector activation, no fire - unintentional	3
744 - Detector activation, no fire - unintentional	1
745 - Alarm system activation, no fire - unintentional	6
<b># Incidents for 1 - Station 1:</b>	<b>168</b>

<b>Station: 2 - STATION 2</b>	
111 - Building fire	3
311 - Medical assist, assist EMS crew	45
322 - Motor vehicle accident with injuries	7
324 - Motor vehicle accident with no injuries.	1
353 - Removal of victim(s) from stalled elevator	1
363 - Swift water rescue	1
400 - Hazardous condition, other	1
411 - Gasoline or other flammable liquid spill	1
421 - Chemical hazard (no spill or leak)	1
444 - Power line down	1
445 - Arcing, shorted electrical equipment	1

Only REVIEWED incidents included.



INCIDENT TYPE	# INCIDENTS
500 - Service Call, other	4
561 - Unauthorized burning	1
611 - Dispatched & cancelled en route	13
651 - Smoke scare, odor of smoke	2
671 - HazMat release investigation w/no HazMat	1
700 - False alarm or false call, other	1
733 - Smoke detector activation due to malfunction	2
743 - Smoke detector activation, no fire - unintentional	3

**# Incidents for 2 - Station 2: 90**

<b>Station: 3 - STATION 3</b>	
113 - Cooking fire, confined to container	1
311 - Medical assist, assist EMS crew	45
322 - Motor vehicle accident with injuries	5
324 - Motor vehicle accident with no injuries.	2
412 - Gas leak (natural gas or LPG)	1
424 - Carbon monoxide incident	1
521 - Water evacuation	1
522 - Water or steam leak	1
611 - Dispatched & cancelled en route	9
622 - No incident found on arrival at dispatch address	3
651 - Smoke scare, odor of smoke	2
711 - Municipal alarm system, malicious false alarm	1
733 - Smoke detector activation due to malfunction	3
743 - Smoke detector activation, no fire - unintentional	3
745 - Alarm system activation, no fire - unintentional	1

**# Incidents for 3 - Station 3: 79**

<b>Station: 4 - STATION 4</b>	
131 - Passenger vehicle fire	1
311 - Medical assist, assist EMS crew	23
322 - Motor vehicle accident with injuries	2
323 - Motor vehicle/pedestrian accident (MV Ped)	1
324 - Motor vehicle accident with no injuries.	1
412 - Gas leak (natural gas or LPG)	1
444 - Power line down	1
445 - Arcing, shorted electrical equipment	2
611 - Dispatched & cancelled en route	4
733 - Smoke detector activation due to malfunction	3
735 - Alarm system sounded due to malfunction	1
743 - Smoke detector activation, no fire - unintentional	4

**# Incidents for 4 - Station 4: 44**

Only REVIEWED incidents included.

INCIDENT TYPE	# INCIDENTS
<b>Station: 5 - STATION 5</b>	
142 - Brush or brush-and-grass mixture fire	1
311 - Medical assist, assist EMS crew	16
322 - Motor vehicle accident with injuries	2
323 - Motor vehicle/pedestrian accident (MV Ped)	1
411 - Gasoline or other flammable liquid spill	1
500 - Service Call, other	1
611 - Dispatched & cancelled en route	5
671 - HazMat release investigation w/no HazMat	1
735 - Alarm system sounded due to malfunction	1
743 - Smoke detector activation, no fire - unintentional	1

**# Incidents for 5 - Station 5:**

**30**

Only REVIEWED incidents included.



# Dalton Fire Department



Dalton, GA

This report was generated on 9/10/2021 3:59:04 PM



## Major Incident Types by Month for Date Range

Start Date: 08/01/2021 | End Date: 08/31/2021



INCIDENT TYPE	AUG	TOTAL
False Alarm & False Call	37	37
Fire	8	8
Good Intent Call	57	57
Hazardous Condition (No Fire)	18	18
Rescue & Emergency Medical Service Incident	275	275
Service Call	16	16
<b>Total</b>	<b>411</b>	<b>411</b>

Only REVIEWED incidents included



emergencyreporting.com

Doc Id: 495

Page # 1 of 1

# Dalton Fire Department


Dalton, GA

This report was generated on 9/10/2021 3:59:30 PM



## Count of Aid Given and Received for Incidents for Date Range

Start Date: 08/01/2021 | End Date: 08/31/2021



AID TYPE	TOTAL	% of TOTAL
Automatic aid received	5	1.2%
Automatic aid given	12	2.9%
None	394	95.9%

Only REVIEWED incidents included



# Dalton Fire Department

Dalton, GA

This report was generated on 9/10/2021 4:00:03 PM



## Detailed Fire Losses per Incident Type for Date Range

Start Date: 08/01/2021 | End Date: 08/31/2021

INCIDENT TYPE	COUNT	% OF INCIDENTS	TOTAL LOSSES (Sum of Property and Content Loss)	% OF TOTAL
111 - Building fire	4	66.67 %	\$239,700.00	99.63 %
113 - Cooking fire, confined to container	2	33.33 %	\$900.00	0.37 %

Only REVIEWED incidents included.



emergencyreporting.com

Doc Id: 1238

Page # 1 of 1

# Dalton Fire Department

Dalton, GA

This report was generated on 9/10/2021 4:00:40 PM



## Detailed Property And Contents Saved for Date Range

Start Date: 08/01/2021 | End Date: 08/31/2021

INCIDENT #	DATE	TYPE	LOCATION	PRE-INCIDENT PROPERTY	PRE-INCIDENT CONTENTS	PRE-INCIDENT TOTAL	PROP. SAVED	CONT. SAVED	TOTAL SAVED
2021-02208	08/01/2021	113 - Cooking fire, confined to container	702 HAMPTON CT Dalton	\$400.00	\$0.00	\$400.00	\$0.00	\$0.00	\$0.00
2021-02244	08/03/2021	113 - Cooking fire, confined to container	515 N Spencer ST Dalton	\$50,000.00	\$2,500.00	\$52,500.00	\$50,000.00	\$2,000.00	\$52,000.00
2021-02256	08/04/2021	111 - Building fire	1503 BYRON ST Dalton	\$48,500.00	\$10,000.00	\$58,500.00	\$48,000.00	\$9,800.00	\$57,800.00
2021-02358	08/12/2021	111 - Building fire	503 Anderson AVE Dalton	\$60,000.00	\$5,000.00	\$65,000.00	\$56,000.00	\$5,000.00	\$61,000.00
2021-02366	08/13/2021	111 - Building fire	1904 S HAMILTON ST Dalton	\$3,200,000.00	\$1,500,000.00	\$4,700,000.00	\$3,200,000.00	\$1,490,000.00	\$4,690,000.00
2021-02593	08/30/2021	111 - Building fire	703 W Walnut AVE Dalton	\$500,000.00	\$50,000.00	\$550,000.00	\$300,000.00	\$25,000.00	\$325,000.00

TOTAL PRE-INCIDENT PROPERTY	TOTAL PRE-INCIDENT CONTENT	TOTAL PRE-INCIDENT	TOTAL PROP. SAVED	TOTAL CONT. SAVED	TOTAL SAVED
\$3,858,900.00	\$1,567,500.00	\$5,426,400.00	\$3,654,000.00	\$1,531,800.00	\$5,185,800.00

# INCIDENTS	AVG. VAL.	AVERAGE SAVED
6	\$904,400.00	\$864,300.00

Only REVIEWED incidents included



emergencyreporting.com

Doc Id: 1834

Page # 1 of 1

# **Training Division Monthly Report**

## **August 2021**

### **Overview**

Recruit Class 2021-01 began on August 9<sup>th</sup> with 6 candidates enrolled. The department hosted the City of Marietta Fire Department's recruit class for above and below grade live fire training evolutions at the training center. The Training Division delivered a firefighter self-rescue course on rope bailouts. Following this training, new bailout kits were issued to all suppression personnel. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of August totaled 1,896.

### **Outside Schools**

One of the department's certified fire investigators attended the Georgia Fire Investigator's Association annual conference in Savannah, Georgia.

Three prospective members of the department's technical rescue team attended a 48-hour Technical Rescue Core Qualifications course at GPSTC.

Two personnel attended an asbestos inspector certification course at The Environmental Institute in Marietta, Georgia.

One firefighter attended Georgia Fire Academy's Acting Officer in Charge for the Fire Service course hosted by Gordon County Fire Rescue.

One Lieutenant attended Live Fire: Critical Actions for First Due Companies at Fire Department Instructor's Conference in Indianapolis, Indiana.

# Dalton Fire Department

Dalton, GA

This report was generated on 9/9/2021 9:13:24 AM



## Completed Inspections per Inspection Type for Date Range

Occupancy Status: All | Start Date: 08/01/2021 | End Date: 08/31/2021

ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Alcohol</b>						
11244	Dalton Beverages	1007 S Thornton AVE Dalton, GA 30720	08/23/2021	Hearn, Scott Raymond	Corrective Action Plan Given	

Total # Inspections for Alcohol:

1

<b>Inspection Type: Annual</b>						
10527 - 2	Griffin Company of Dalton	110 E Tyler ST #B Dalton, GA 30720	08/02/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10331	Boy's and Girls Club	1013 Underwood ST Dalton, GA 30720	08/02/2021	Blankenship, Donnie	Passed	
10527 - 1	Tyler Street Storage	110 E Tyler ST #A Dalton, GA 30720	08/02/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10074	Xtreme Audio and Accessories	400 S Hamilton ST Dalton, GA 30720	08/02/2021	Stratton, Dale Lee	Passed with Comments	Complete corrective actions.
10266	Three Oaks Custom Cabinets	638 Spring ST Dalton, GA 30720	08/03/2021	Blankenship, Donnie	Corrective Action Plan Given	
10843 - 2	Bryman's Leasing Office	210 W Franklin ST #2 Dalton, GA 30721	08/03/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan provided.
10784	Brymans Plaza North	100 W Walnut AVE Dalton, GA 30720	08/03/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10756	Aesops Inc.	301 Dayton ST Dalton, GA 30720	08/03/2021	Stratton, Dale Lee	Passed	
10583	Robertson & Company	313 N Selvidge ST #Suite 201 Dalton, GA 30720	08/04/2021	Blankenship, Donnie	Passed	
11337	Cowan Law Firm	315 N Selvidge ST Dalton, GA 30720	08/04/2021	Blankenship, Donnie	Corrective Action Plan Given	
10239	JAA Controls	441 N Hamilton ST Dalton, GA 30720	08/05/2021	Stratton, Dale Lee	Corrective Action Plan Given	
11338	Doggie Do's	601 N Hamilton ST Dalton, GA 30721	08/05/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10526	Techmer PM	105 E Tyler ST Dalton, GA 30720	08/05/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Annual</b>						
10459	First Methodist Church	500 S Thornton AVE Dalton, GA 30720	08/09/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10459 - 1	Dalton First United Methodist Christian Learning Center	500 S Thornton AVE Dalton, GA 30720	08/09/2021	Hearn, Scott Raymond	Passed	
10566	National Plumbing Service	107 E Waterworks ST Dalton, GA 30720	08/09/2021	Stratton, Dale Lee	Passed	
11340	La Esquinita	613 N Hamilton ST Dalton, GA 30720	08/09/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10349	Self Recycling Inc	1206 Lamar ST Dalton, GA 30720	08/10/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10235	Bucket List Antiques	300 N Hamilton ST Dalton, GA 30720	08/10/2021	Stratton, Dale Lee	Passed	
10271	Tacos Tu Go	807 N Hamilton ST Dalton, GA 30720	08/10/2021	Stratton, Dale Lee	Passed	
10568	Extruded Fiber's Warehouse	101 Westcott WAY Dalton, GA 30720	08/10/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10570	Extruded Fibers	112 Westcott WAY Dalton, GA 30720	08/11/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10304	Technicraft Services	111 Westcott WAY Dalton, GA 30720	08/11/2021	Stratton, Dale Lee	Corrective Action Plan Given	Corrective action plan has been provided.
11344	Ready Mix USA	419 N Selvidge ST Dalton, GA 30720	08/11/2021	Blankenship, Donnie	Passed	
11345	American Metal & Electric	109 W Tyler ST Dalton, GA 30720	08/12/2021	Hearn, Scott Raymond	Passed	
11346	American Metal & Electric	106 W Tyler ST Dalton, GA 30720	08/12/2021	Hearn, Scott Raymond	Passed with Comments	Add Knox Box to building.
11348	Pacheco LLC - Affordable Motor Service	710 N Hamilton ST #A Dalton, GA 30720	08/12/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10258	Expressway Samples	108 Westcott WAY Dalton, GA 30720	08/12/2021	Stratton, Dale Lee	Corrective Action Plan Given	Corrective action plan has been provided.
10345 - 1	Congressional Office	702 S Thornton AVE #A Dalton, GA 30720	08/13/2021	Hearn, Scott Raymond	Passed	
11205 - 7	JJY Liquor Store	101 W Walnut AVE #Suite 13 Dalton, GA 30720	08/17/2021	Blankenship, Donnie	Passed	
11351	Mapco	304 N Thornton AVE Dalton, GA 30720	08/18/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
11358	CJ Poag	1217 Lamar ST Dalton, GA 30720	08/18/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10461	Harvest Carpet	924 N Selvidge ST Dalton, GA 30720	08/18/2021	Hearn, Scott Raymond	Corrective Action Plan Given	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Annual</b>						
10522	Dalton Diagnostic	820 Tinsley ST Dalton, GA 30720	08/19/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10470	Custom Graphic	226 Springdale RD Dalton, GA 30720	08/19/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10353	Bill Mitchell Construction	201 E Long ST Dalton, GA 30720	08/19/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted in lieu of annual inspection. The building has no power and is being utilized as a personal space.
10354	Vacant	203 E Long ST Dalton, GA 30720	08/19/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted in leu of annual inspection because the occupancy is vacant.
10276	Triple E Properties	201 S Hamilton ST Dalton, GA 30720	08/20/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
11361	System Concepts Plus	205 E Matilda ST Dalton, GA 30720	08/23/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10163 - 3	Irene's Cakes	304 Springdale RD #3 Dalton, GA 30720	08/23/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10477	Check Into Cash Title Pawn	1133 N Glenwood AVE Dalton, GA 30721	08/23/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10476	Reyes Auto Repair	1119 N Glenwood AVE Dalton, GA 30721	08/24/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10674	Kirk's Cycle	929 N Glenwood AVE Dalton, GA 30721	08/24/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10698	La Parisienne Uniform	927 N Glenwood AVE Dalton, GA 30721	08/24/2021	Stratton, Dale Lee	Passed	
10471	Miscelanea Polvos	238 Springdale RD Dalton, GA 30720	08/24/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10163 - 1	Imperial Del Arte	304 Springdale RD #1 Dalton, GA 30720	08/24/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10001	El Patron Feed Store	1019 N Glenwood AVE Dalton, GA 30721	08/24/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11347	Morales Auto Center	701 N Hamilton ST Dalton, GA 30720	08/26/2021	Stratton, Dale Lee	Passed	
10254	Shaw Plant WM	902 N Hamilton ST Dalton, GA 30720	08/27/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
10539	North Georgia Highlands Center	900 Shugart RD Dalton, GA 30720	08/31/2021	Stratton, Dale Lee	Passed with Comments	Corrective action plan has been provided.
11355	McCurry Law Firm	402 N Selvidge ST Dalton, GA 30720	08/31/2021	Hearn, Scott Raymond	Corrective Action Plan Given	

Total # Inspections for Annual:

51

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Complaint</b>						
10675	The Cliffs Apartments	818 Shugart RD Dalton, GA 30720	08/02/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Fix the water issues.
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	08/19/2021	Hearn, Scott Raymond	Passed	
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	08/19/2021	Stratton, Dale Lee	Passed with Comments	Inspectors Hearn and Stratton chained open the check valve and the main control valves at the standpipe.
00001 - 2	509 Lester	509 Lester AVE Dalton, GA 30721	08/20/2021	Hearn, Scott Raymond	Complaint cleared by Contact	
10469	Dalton Village Apartments	1809 Shadow LN Dalton, GA 30720	08/20/2021	Hearn, Scott Raymond	Corrective Action Plan Given	

Total # Inspections for Complaint: 5

<b>Inspection Type: Fire Alarm</b>						
10332	Christian Heritage Elementary School	1600 MLK Jr. BLVD Dalton, GA 30720	08/10/2021	Daniel, Matthew T.	Passed	

Total # Inspections for Fire Alarm: 1

<b>Inspection Type: Kitchen Hood Installation</b>						
10390	Coronita Market	1001 E Morris ST Dalton, GA 30720	08/13/2021	Hearn, Scott Raymond	Passed	

Total # Inspections for Kitchen Hood Installation: 1

<b>Inspection Type: New Construction</b>						
10739	Walnut Creek	1115 W Walnut AVE Dalton, GA 30720	08/20/2021	Blankenship, Donnie	Passed	
10985	Decorative Concepts	1803 Abutment RD Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Corrective Action Plan Given	

Total # Inspections for New Construction: 2

<b>Inspection Type: OTC</b>						
10129 - 4	VIP Tobacco #2	314 N Glenwood AVE #5 Dalton, GA 30720	08/03/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Add Knox Box to building.
11331 - 2	Paradise Mental Health Center	405 N Hamilton ST #2 Dalton, GA 30720	08/04/2021	Hearn, Scott Raymond	Passed	
11171 - 7	Pearle Vision	1207 W Walnut AVE Dalton, GA 30720	08/09/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Service extinguishers and add Knox Box to building.
10688	Stubbs Prosthetics & Orthotics Inc.	1213 Broadrick DR Dalton, GA 30720	08/09/2021	Blankenship, Donnie	Corrective Action Plan Given	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: OTC</b>						
10456 - 8	City Postal Service	1219 N Glenwood AVE Dalton, GA 30721	08/09/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguishers, rear exit, emergency lighting.
10503	Ga Extreme Curbing and Landscape Supply	913 N Glenwood AVE Dalton, GA 30720	08/09/2021	Hearn, Scott Raymond	Passed	
10327 - 3	Hinojosa Carpet	809 S Hamilton ST #3 Dalton, GA 30720	08/10/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Electrical, emergency lights, Knox Box.
10287	Dalton Antique Market	330 S Hamilton ST Dalton, GA 30720	08/12/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10327 - 3	Hinojosa Carpet	809 S Hamilton ST #3 Dalton, GA 30720	08/13/2021	Hearn, Scott Raymond	Passed	
10128	Tequila's Liquor	312 N Glenwood AVE Dalton, GA 30721	08/16/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Add Knox Box to building.
10302 - 1	Tienda La Barata	305 E Hawthorne ST #Suite A Dalton, GA 30720	08/30/2021	Hearn, Scott Raymond	Passed	
10318 - 2	Southern Roofing & Exteriors	1225 Coronet DR #2 Dalton, GA 30720	08/31/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguishers and blanks.

Total # Inspections for OTC:

12

<b>Inspection Type: Plan Review</b>						
11218 - 37	Chick-Fil-A	816 Walnut Square BLVD #Suite 54 Dalton, GA 30720	08/09/2021	Blankenship, Donnie	Passed	Approval of Kitchen Hood System Plans.
11142	Krystal	1909 E Walnut AVE Dalton, GA 30721	08/09/2021	Blankenship, Donnie	Passed	Approval of Kitchen Hood System Plans
11142	Krystal	1909 E Walnut AVE Dalton, GA 30721	08/09/2021	Stratton, Dale Lee	Passed with Comments	Assisted inspector Blankenship reviewing submitted plans for the repair/replacement of the hood and ventilation systems.
10546	All Seasons Self Storage	1060 Vista DR Dalton, GA 30720	08/10/2021	Hearn, Scott Raymond	Passed with Comments	
10407	Core Scientific	202 Boring DR Dalton, GA 30721	08/11/2021	Daniel, Matthew T.	Passed	Fire Alarm
10406	Core Scientific	201 Boring DR Dalton, GA 30721	08/11/2021	Daniel, Matthew T.	Passed	Fire Alarm
10943	Shaw Plant # 80	2230 S Hamilton EXT Dalton, GA 30721	08/12/2021	Daniel, Matthew T.	Passed	Fire Alarm
10389	Core Scientific	206 Boring DR Dalton, GA 30721	08/12/2021	Daniel, Matthew T.	Passed	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Plan Review</b>						
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	08/12/2021	Daniel, Matthew T.	Passed	SICU Renovation
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	08/12/2021	Daniel, Matthew T.	Passed	HMC Residency
11218 - 37	Chick-Fil-A	816 Walnut Square BLVD #Suite 54 Dalton, GA 30720	08/17/2021	Daniel, Matthew T.	Passed	Sprinkler plan review.
10389	Core Scientific	206 Boring DR Dalton, GA 30721	08/17/2021	Daniel, Matthew T.	Passed	Fire Hydrant Underground
11218 - 37	Chick-Fil-A	816 Walnut Square BLVD #Suite 54 Dalton, GA 30720	08/19/2021	Hearn, Scott Raymond	Passed	
10351	El Milagro #2	101 E Long ST Dalton, GA 30720	08/19/2021	Hearn, Scott Raymond	Passed	
10960	Shaw Industries	2305 Abutment RD Dalton, GA 30720	08/24/2021	Daniel, Matthew T.	Passed	Rack Sprinklers.
11368	Santa Rosa Clinic	1417 Chattanooga AVE Dalton, GA 30720	08/25/2021	Daniel, Matthew T.	Passed	Building plan review.
11218 - 37	Chick-Fil-A	816 Walnut Square BLVD #Suite 54 Dalton, GA 30720	08/27/2021	Daniel, Matthew T.	Passed	Interior remodel.
11070	State Farm	1904 Shields RD Dalton, GA 30720	08/27/2021	Daniel, Matthew T.	Passed	Interior Review.
10068	Whitfield County Courthouse	205 N Selvidge St. Dalton, GA 30720	08/27/2021	Daniel, Matthew T.	Passed	Sprinkler Plan review.

Total # Inspections for Plan Review:

19

<b>Inspection Type: Site Visit</b>						
10326 - 2	Hamilton Diabetes and Endocrinology	475 Reed RD #3 Dalton, GA 30720	08/02/2021	Hearn, Scott Raymond	Passed	
10326 - 3	Georgia Board of Workers Compensation	475 Reed RD Dalton, GA 30720	08/02/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10784	Brymans Plaza North	100 W Walnut AVE Dalton, GA 30720	08/03/2021	Blankenship, Donnie	Passed	Assisted Inspector Stratton with follow up inspection in regards to renumbering the suites.
10896 - 11	Bath and Body Works	1318 W Walnut AVE #Suite 1 Dalton, GA 30720	08/03/2021	Blankenship, Donnie	Passed	Reviewed construction progress.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Site Visit</b>						
10739	Walnut Creek	1115 W Walnut AVE Dalton, GA 30720	08/03/2021	Blankenship, Donnie	Corrective Action Plan Given	
10739	Walnut Creek	1115 W Walnut AVE Dalton, GA 30720	08/03/2021	Blankenship, Donnie	Passed	Reviewed construction progress.
10326 - 1	Dixie Group	475 Reed RD Dalton, GA 30720	08/03/2021	Hearn, Scott Raymond	Passed	
10738	Fairfield Inn & Suites	786 College DR Dalton, GA 30720	08/03/2021	Hearn, Scott Raymond	Passed	
10302	Ramirez Property 305 E Hawthorne Street	305 E Hawthorne ST Dalton, GA 30720	08/04/2021	Blankenship, Donnie	Corrective Action Plan Given	
10739	Walnut Creek	1115 W Walnut AVE Dalton, GA 30720	08/04/2021	Blankenship, Donnie	Corrective Action Plan Given	
10784	Brymans Plaza North	100 W Walnut AVE Dalton, GA 30720	08/04/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to gather information to correct suite addressing.
11205	Brymans Plaza South	101 W Walnut AVE Dalton, GA 30720	08/04/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to gather information to correct suite addressing.
10738	Fairfield Inn & Suites	786 College DR Dalton, GA 30720	08/04/2021	Hearn, Scott Raymond	Passed	
10188	267 N. Hamilton St. Property	267 N Hamilton ST Dalton, GA 30720	08/06/2021	Blankenship, Donnie	Passed with Comments	Met with a potential occupant who wanted to know if the building met code requirements for a cigar lounge.
10369	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	08/06/2021	Blankenship, Donnie	Passed with Comments	Met with staff in regards to evacuations for fire drills, and areas of safety for severe weather.
10369	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	08/06/2021	Stratton, Dale Lee	Passed with Comments	Met with staff in regards to evacuations for fire drills, and areas of safety for severe weather.
10657	Stone Brooke Apartment Homes	1912 Heathcliff DR Dalton, GA 30720	08/09/2021	Blankenship, Donnie	Passed	Management contacted us in regards to a stove fire that happened over the weekend. The fire was extinguished by the occupant. Due to the extent of the damage to the stove, I advised them to disconnect the stove and replace it. The cause of the fire was undetermined.
10254	Shaw Plant WM	902 N Hamilton ST Dalton, GA 30720	08/09/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to set up and inspection date and time. Point of contact was Kenny Dillard.
10468	J&M Gifts and Accessories/ Titan Phone Repair	1104 N Glenwood AVE Dalton, GA 30720	08/09/2021	Hearn, Scott Raymond	Failed	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Site Visit</b>						
10188	267 N. Hamilton St. Property	267 N Hamilton ST Dalton, GA 30720	08/10/2021	Blankenship, Donnie	Passed with Comments	Myself along with Chief Daniel met with the architect, contractor, and sprinkler contractor in regards to the apartment additions in the building.
10103	JOHN EDWARD INVESTMENT LLC 301 &305 N Hamilton/ 100,102,&106 W Waugh	301 N Hamilton ST Dalton, GA 30720	08/10/2021	Blankenship, Donnie	Passed with Comments	Myself and Chief Daniel met with the building owner in regards to a new business coming.
11341	Burgess Family Investments LLC	1128 Lamar ST Dalton, GA 30720	08/11/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to verify vacancy.
11342	Gregg Sims Architect	304 N Selvidge ST Dalton, GA 30720	08/11/2021	Blankenship, Donnie	Passed with Comments	Spoke to occupant about code related issues.
10304	Technicraft Services	111 Westcott WAY Dalton, GA 30720	08/11/2021	Blankenship, Donnie	Passed with Comments	Was asked by the occupant to assist with building classification.
10675	The Cliffs Apartments	818 Shugart RD Dalton, GA 30720	08/11/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10306	Vacant	221 W Cuyler ST Dalton, GA 30720	08/12/2021	Hearn, Scott Raymond	Passed	
10336	DPS-Park Creek Elementary School	1500 Hale-Bowen DR Dalton, GA 30720	08/12/2021	Blankenship, Donnie	Passed with Comments	Reviewed the evacuation process during a fire drill. I advised the principal of the importance of closing doors, and the issues concerning desk in the exit corridors.
11349	618 5th Avenue Apartments	618 5th AVE Dalton, GA 30721	08/12/2021	Daniel, Matthew T.	Corrective Action Plan Given	Met with building owner about the condition of apartment 1. An additional inspection is to be scheduled. The Health Department is being requested.
10526	Techmer PM	105 E Tyler ST Dalton, GA 30720	08/12/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to place a riser room key in the Knox Box.
11349	618 5th Avenue Apartments	618 5th AVE Dalton, GA 30721	08/12/2021	Blankenship, Donnie	Passed with Comments	Assisted FM Daniel with reviewing the property.
11347	Morales Auto Center	701 N Hamilton ST Dalton, GA 30720	08/12/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to contact information and business information. Annual inspection to be scheduled at a later date per owner request.
11350	RAINSTONE DEVELOPERS LLC - Apartments	612 5th AVE Dalton, GA 30721	08/12/2021	Blankenship, Donnie	Passed with Comments	Assisted FM Daniel with reviewing the property.
11350	RAINSTONE DEVELOPERS LLC - Apartments	612 5th AVE Dalton, GA 30721	08/12/2021	Daniel, Matthew T.	Passed	The structure appears to have been renovated. It is unclear if the intent is a small strip mall or triplex. Blankenship will be conducting a follow up inspection with the building owner.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Site Visit</b>						
10660	DPS-Dalton Middle School	1250 Cross Plains TRL Dalton, GA 30720	08/13/2021	Blankenship, Donnie	Passed with Comments	Myself and Chief Daniel visited the school to observe a fire drill. We reviewed the evacuation sites in regards to DFD response.
10660	DPS-Dalton Middle School	1250 Cross Plains TRL Dalton, GA 30720	08/13/2021	Daniel, Matthew T.	Passed	Fire Drill
10524	DPS-Westwood Elementary School	708 Trammell ST Dalton, GA 30720	08/13/2021	Stratton, Dale Lee	Passed with Comments	Observed fire drill with Inspector Hearn.
10524	DPS-Westwood Elementary School	708 Trammell ST Dalton, GA 30720	08/13/2021	Hearn, Scott Raymond	Passed	
10687	DPS-Blue Ridge Elementary Schools	100 S Bogle ST Dalton, GA 30721	08/13/2021	Blankenship, Donnie	Passed with Comments	Myself and Chief Daniel visited the school to observe a fire drill. We reviewed the evacuation sites in regards to DFD response.
10687	DPS-Blue Ridge Elementary Schools	100 S Bogle ST Dalton, GA 30721	08/13/2021	Daniel, Matthew T.	Passed	Fire Drill
10369	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	08/13/2021	Stratton, Dale Lee	Passed with Comments	Observed the scheduled fire drill with Inspector Hearn. Evacuation at the rear of the school was complete in 3:15 (minutes: seconds)
10369	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	08/13/2021	Hearn, Scott Raymond	Passed	
11350	RAINSTONE DEVELOPERS LLC - Apartments	612 5th AVE Dalton, GA 30721	08/16/2021	Blankenship, Donnie	Passed with Comments	Met with the owner of the property in regards to a structure on the property being used as residential. I advised the owner that once I had reviewed the codes to ensure compliance I would advise him if any action is required.
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	08/16/2021	Blankenship, Donnie	Passed with Comments	Dalton Fire Department was contacted by John Maddox of Georgia Environmental Protection Division in regards to hazardous materials from this location being discarded at a site in Catoosa County. DFD personnel along with Mr. Maddox and Chris Hester of Whitfield County Storm water met at the property. No immediate life safety concerns were found at the location, and the property was turned over to Mr. Maddox.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Site Visit</b>						
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	08/16/2021	Blankenship, Donnie	Passed with Comments	Dalton Fire Department was contacted by John Maddox of Georgia Environmental Protection Division in regards to hazardous materials from this location being discarded at a site in Catoosa County. DFD personnel along with Mr. Maddox and Chris Hester of Whitfield County Storm water met at the property. No immediate life safety concerns were found at the location, and the property was turned over to Mr. Maddox.
10539	North Georgia Highlands Center	900 Shugart RD Dalton, GA 30720	08/17/2021	Blankenship, Donnie	Passed	Checked on the progress of having limbs cut at the bottom entrance for apparatus access. Limbs have been removed.
10407	Core Scientific	202 Boring DR Dalton, GA 30721	08/18/2021	Blankenship, Donnie	Passed with Comments	Assisted Chief Daniel with a fire alarm inspection.
10407	Core Scientific	202 Boring DR Dalton, GA 30721	08/18/2021	Daniel, Matthew T.	Passed	Fire Alarm Inspection
10992	City of Refuge	416 S Glenwood AVE Dalton, GA 30720	08/18/2021	Blankenship, Donnie	Passed with Comments	Myself, Chief Daniel, and Building Inspector Mike Fowler, met with a contractor in regards to a proposed addition onto the building.
10992	City of Refuge	416 S Glenwood AVE Dalton, GA 30720	08/18/2021	Daniel, Matthew T.	Passed	Myself, Insp Blankenship and Building Inspector Mike Fowler, met with a contractor in regards to a proposed addition onto the building.
11349	618 5th Avenue Apartments	618 5th AVE Dalton, GA 30721	08/18/2021	Blankenship, Donnie	Passed with Comments	Assisted Chief Daniel with a site inspection in regards to a single family dwelling converted into a triplex.
10390	Coronita Market	1001 E Morris ST Dalton, GA 30720	08/18/2021	Blankenship, Donnie	Passed with Comments	Myself and Chief Daniel visited the property to look at the construction progress.
10390	Coronita Market	1001 E Morris ST Dalton, GA 30720	08/18/2021	Daniel, Matthew T.	Passed	Looked at construction progress. Hood system needs to be submitted.
11349	618 5th Avenue Apartments	618 5th AVE Dalton, GA 30721	08/18/2021	Daniel, Matthew T.	Corrective Action Plan Given	
10809	DPS-Brookwood Elementary School	501 Central AVE Dalton, GA 30720	08/19/2021	Blankenship, Donnie	Passed with Comments	Myself and Chief Daniel observed a fire drill, reviewing evacuation procedures.
10332	Christian Heritage Elementary School	1600 MLK Jr. BLVD Dalton, GA 30720	08/19/2021	Hearn, Scott Raymond	Passed	
11349	618 5th Avenue Apartments	618 5th AVE Dalton, GA 30721	08/19/2021	Blankenship, Donnie	Passed with Comments	Assisted Chief Daniel with inspecting Apartment 1 due to the fact they were unavailable yesterday.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Site Visit</b>						
11349	618 5th Avenue Apartments	618 5th AVE Dalton, GA 30721	08/19/2021	Daniel, Matthew T.	Corrective Action Plan Given	
11121	Waco Chemical	455 Virgil DR Dalton, GA 30720	08/19/2021	Blankenship, Donnie	Passed with Comments	Myself and Chief Daniel met with Georgia EPD officers in regards to chemicals being stored at the property.
11360	Goldstar Investment Group	932 W Lake ST NE Dalton, GA 30720	08/19/2021	Blankenship, Donnie	Passed with Comments	Myself, Chief Daniel, Building Inspector Mike Fowler, and officials with Georgia EPD met with the owner Mr. Ali in regards to a building located on an adjacent property on Strain Street. This was inspected to ensure hazardous materials was not being stored in this location.
11360	Goldstar Investment Group	932 W Lake ST NE Dalton, GA 30720	08/19/2021	Daniel, Matthew T.	Passed	Myself, Insp Blankenship, Building Inspector Mike Fowler, and officials with Georgia EPD met with the owner Mr. Ali in regards to a building located on an adjacent property on Strain Street. This was inspected to ensure hazardous materials was not being stored in this location.
10316	American Import Auto Parts LLC.	412 N Hamilton ST Dalton, GA 30720	08/19/2021	Daniel, Matthew T.	Corrective Action Plan Given	
11250	Holiday Inn Express	934 Market ST Dalton, GA 30720	08/20/2021	Hearn, Scott Raymond	Passed	
10343	Whitfield Healthcare Foundation	507 S Thornton AVE Dalton, GA 30720	08/23/2021	Hearn, Scott Raymond	Passed with Comments	Add exit signs.
10343	Whitfield Healthcare Foundation	507 S Thornton AVE Dalton, GA 30720	08/24/2021	Hearn, Scott Raymond	Passed	
10388	Eclectic 79	315 E Morris ST Dalton, GA 30720	08/24/2021	Hearn, Scott Raymond	Passed	
10432	Christian Heritage High School	1601 MLK Jr. BLVD Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
11074	Camelot Building	1514 W Walnut AVE Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed with Comments	Annual meeting inspection required.
11086	Verizon Wireless	1516 W Walnut AVE Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
10827	Days Inn	1518 W Walnut AVE Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Site Visit</b>						
10826	Vacant	1520 W Walnut AVE Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
10906	BP Gas station	1522 W Walnut AVE Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
10825	Vacant	1526 W Walnut AVE Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
11288	Home 2 Suites	865 Holiday Inn DR Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	No issues noted.
10779	Chilis	881 Holiday Inn DR Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
11170	Nareen Patel 920 Market St	920 Market ST Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
11250	Holiday Inn Express	934 Market ST Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed	
11366	929 Market Street LLC	929 Market ST Dalton, GA 30720	08/25/2021	Hearn, Scott Raymond	Passed with Comments	Large amounts of construction products lying about.
11362	Patel Lot 1	885 Holiday Inn DR Dalton, GA 30720	08/26/2021	Hearn, Scott Raymond	Passed	
10145	Hilton Garden Inn	879 Holiday Inn DR Dalton, GA 30720	08/26/2021	Hearn, Scott Raymond	Passed	
10289	Belk-Gallant Lofts	307 S Hamilton ST Dalton, GA 30721	08/26/2021	Hearn, Scott Raymond	Passed	
10068	Whitfield County Courthouse	205 N Selvidge St. Dalton, GA 30720	08/27/2021	Hearn, Scott Raymond	Passed with Comments	Will schedule a pressure test.
11079	Budgetel	609 S Thornton AVE Dalton, GA 30720	08/30/2021	Hearn, Scott Raymond	Passed with Comments	Discussed issues with the sprinkler system.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
<b>Inspection Type: Site Visit</b>						
11079	Budgetel	609 S Thornton AVE Dalton, GA 30720	08/30/2021	Blankenship, Donnie	Passed with Comments	<p>Inspector Hearn was contacted by a fire sprinkler contractor in regards to issues with the sprinkler system. Inspector Hearn asked for my assistance. The building is currently partially protected by a sprinkler system. The sprinkler system needs major upgrades to meet code requirements. I advised the sprinkler contractor that I would review code and give him a decision on what would be required. I later contacted the contractor and advised him that one of two acceptable options would be required:</p> <ol style="list-style-type: none"> <li>1) Correct the deficiencies of the current system, and sprinkle all areas of the building.</li> <li>2) Remove the sprinkler system due to the building only being used as a business occupancy, and due to the square footage would not require a sprinkler system. This would consist of the removal of all sprinkler piping and heads, and a cap at the valve inside the building. This would also require the roadway valve to be shut.</li> </ol> <p>If option 2 is chosen, and a change of occupancy occurs that requires a sprinkler system, the new system would be a completely new system meeting current code requirements.</p> <p>I advised the contractor to discuss the options with the building owner and advise me of the decision.</p>

Total # Inspections for Site Visit:

83

**TOTAL # INSPECTIONS: 175**

Includes LOCKED inspections for both archived and unarchived occupancy records.



# Dalton Fire Department

Dalton, GA

This report was generated on 9/9/2021 9:09:09 AM



## Occupancy Inspection History per Occupancy with Violations

Inspection Observations: CORRECTIVE ACTION PLAN, FAIL | Occupancy Categories: All Categories | Start Date: 08/01/2021 | End Date: 08/31/2021

INSPECTION DATE	INSPECTION TYPE	RESULT	NOTES	QUESTION	REMARKS	OBSERVATION
<b>Engine 1 A Shift</b>						
<b>McCurry Law Firm - 402 N Selvidge ST - 706-279-1174</b>						
08/31/2021	Annual	Corrective Action Plan Given		Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add fire extinguisher to business from a licensed Georgia contractor.	CORRECTIVE ACTION PLAN
<b>Xtreme Audio and Accessories - 400 S Hamilton ST - 706-529-8736</b>						
08/02/2021	Annual	Passed with Comments	Complete corrective actions.	Are there any identifiable electrical hazards?	1). Install appropriate switch covers and outlet covers. 2). Permanent electrical wiring shall be installed in electrical conduit or covered with the appropriate material.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox box	CORRECTIVE ACTION PLAN
<b>Engine 1 B Shift</b>						
<b>American Metal &amp; Electric - 106 W Tyler ST - 706-278-1333</b>						
08/12/2021	Annual	Passed with Comments	Add Knox Box to building.	Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



emergencyreporting.com

Doc Id: 1362

Page # 1 of 19

**Cowan Law Firm - 315 N Selvidge ST - 7062782099**

08/04/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Repair or replace emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace exit signage.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install electrical room signage on door.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Spliced electrical wiring should be in approved junction box.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install code compliant address signage.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Contact a Ga licensed fire extinguisher contractor to install approved fire extinguishers.	CORRECTIVE ACTION PLAN

**Doggie Do's - 601 N Hamilton ST**

08/05/2021	Annual	Corrective Action Plan Given		Have all applicable code requirements been met?	Dryer must be vented to the exterior of the structure.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Electrical outlets must be properly installed. Install electrical outlet covers. Wire splices must be installed in a junction box. Electrical wiring must be covered by the appropriate material or installed in conduit.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguishers. The fire extinguishers must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

**Harvest Carpet - 924 N Selvidge ST**

08/18/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Add blanks to panel. Do not use extension cords for permanent wiring.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have extinguishers inspected by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



<b>Tequila's Liquor - 312 N Glenwood AVE</b>						
08/16/2021	OTC	Corrective Action Plan Given	Add Knox Box to building.	Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
<b>VIP Tobacco #2 - 314 N Glenwood AVE #5</b>						
08/03/2021	OTC	Corrective Action Plan Given	Add Knox Box to building.	Is address signage correct and in place?	Suite 5	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
<b>Engine 1 C Shift</b>						
<b>Bucket List Antiques - 300 N Hamilton ST - (706) 428-9590</b>						
08/10/2021	Annual	Passed		Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN
<b>Dalton Antique Market - 330 S Hamilton ST - (706) 529-4903</b>						
08/12/2021	OTC	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Add plug in above door.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
<b>Mapco - 304 N Thornton AVE</b>						
08/18/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Insure all electrical issues are repaired.	CORRECTIVE ACTION PLAN
<b>Triple E Properties - 201 S Hamilton ST</b>						
08/20/2021	Annual	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
<b>Engine 2 B Shift</b>						
<b>618 5th Avenue Apartments - 618 5th AVE - 706-428-1352</b>						
08/12/2021	Site Visit	Corrective Action Plan Given	Met with building owner about the condition of apartment 1. An additional inspection is to be scheduled. The Health Department is being requested.	Have all applicable code requirements been met?		CORRECTIVE ACTION PLAN
				If a change of occupancy has occurred, does the building comply with current code requirements?		CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



08/18/2021	Site Visit	Corrective Action Plan Given		If a change of occupancy has occurred, does the building comply with current code requirements?	The single family dwelling has been separated into four apartments. Building owner Jamal Awad was instructed to have an electrician look at the structure and reduce to a duplex.	FAIL
08/19/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Met with occupants in apartment one, Daniel Porter. All rooms inside the apartment were unfit for habitation. There was trash, food, soiled clothing and dog feces everywhere. The tenants were instructed to clean the apartment or they would have to leave. DPD was also on scene.	FAIL

**Brymans Plaza North - 100 W Walnut AVE**

08/03/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Is required emergency lighting in place?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Components required to be fire or smoke resistant are properly maintained?	Replace all missing ceiling tiles. Install cover on water flow alarm. Place a sprinkler wrench in the sprinkler cabinet.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install junction box covers on open junction boxes containing electrical wire splices. Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN

**Three Oaks Custom Cabinets - 638 Spring ST**

08/03/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Extension cords should only be used for temporary power. Don't plug extension cords into other extension cords. Keep 36 inch clearance around electrical panels.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Keep egress paths clear.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Engine 2 C Shift**

**Bryman's Leasing Office - 210 W Franklin ST #2**

08/03/2021	Annual	Passed with Comments	Corrective action plan provided.	Is required emergency lighting in place?	Repair or replace all non operational emergency lighting and exit signs.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install address signage.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguisher. Fire extinguishers must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

**Engine 4 A Shift**

**Fairfield Inn & Suites - 786 College DR - 7062757215**

08/04/2021	Site Visit	Passed		Have all applicable code requirements been met?	Add sprinkler heads to each landing in stairwells. NFPA 13 requires heads at each landing for combustibile stairwell.	CORRECTIVE ACTION PLAN
------------	------------	--------	--	---	---	------------------------

**Hinojosa Carpet - 809 S Hamilton ST #3**

08/10/2021	OTC	Corrective Action Plan Given	Electrical, emergency lights, Knox Box.	Is required emergency lighting in place?	Repair or replace emergency lighting.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Add approved electrical plug ins.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
08/13/2021	OTC	Passed		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN

**Walnut Creek - 1115 W Walnut AVE**

08/03/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Spray foam was used for penetrations and smoke wall it should not be used in a commercial building. Egress doors swing inward and should swing outward.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	---	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



08/04/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	<p>Myself along with Building Inspector Mike Fowler visited the property to look at the progress of construction. The following items were notated and explained to the contractor.</p> <ol style="list-style-type: none"> <li>1. Exit signage needed in hallway</li> <li>2. Exit door needs proper handle</li> <li>3. Dryer vents should be hard ducted</li> <li>4. Exhaust over cooking equipment should be hard ducted to the exterior</li> <li>5. Heater needed in riser room</li> <li>6. FACP, Riser Room, and Electrical Room signage needed</li> <li>7. Proper ADA grab bars needed on toilets as required</li> <li>8. Knox Box needed</li> </ol>	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	--	------------------------

**Engine 4 C Shift**

**Pearle Vision - 1207 W Walnut AVE - 706-226-2722**

08/09/2021	OTC	Corrective Action Plan Given	Service extinguishers and add Knox Box to building.	Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Extinguishers need current inspection.	CORRECTIVE ACTION PLAN

**Waco Chemical - 455 Virgil DR - 706-277-3939**

08/16/2021	Site Visit	Passed with Comments	Dalton Fire Department was contacted by John Maddox of Georgia Environmental Protection Division in regards to hazardous materials from this location being discarded at a site in Catoosa County. DFD personnel along with Mr. Maddox and Chris Hester of Whitfield County Storm water met at the property. No immediate life safety concerns were found at the location, and the property was turned over to Mr. Maddox.	Have all applicable code requirements been met?	Chemicals not stored and labeled in their proper container. Various chemicals leaking in and around the property. Property was turned over to Marion Environmental and EPD.	FAIL
				08/19/2021	Complaint	Passed with Comments

**Engine 5 A Shift**

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**CJ Poag - 1217 Lamar ST**

08/18/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguisher requires a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	---	--	------------------------

**Engine 5 B Shift**

**Dalton Beverages - 1007 S Thornton AVE - 706-278-1755**

08/23/2021	Alcohol	Corrective Action Plan Given		Does the emergency lighting system work correctly?	Insure emergency lighting works.	CORRECTIVE ACTION PLAN
				Are exit signs properly illuminated?	Insure exit signs are working properly.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Add address numbers to building.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add three extinguishers from a licensed Georgia contractor.	CORRECTIVE ACTION PLAN

**Extruded Fibers - 112 Westcott WAY - (706) 226-2275**

08/11/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Is required emergency lighting in place?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Replace ceiling tiles to maintain ceiling assembly continuity.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN
				Are proper clearances of combustible materials from ignition sources being maintained?	Combustibles must be 36" away from electrical panels	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Extruded Fiber's Warehouse - 101 Westcott WAY - 706.226.2275**

08/10/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install RISER ROOM sign above the door concealing the sprinkler riser.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	LP storage must be relocated away from means of egress.	CORRECTIVE ACTION PLAN

**System Concepts Plus - 205 E Matilda ST**

08/23/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panels.  Multi plug adapters must be mounted according to manufacturers recommended specifications.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

**Engine 5 C Shift**

**City Postal Service - 1219 N Glenwood AVE**

08/09/2021	OTC	Corrective Action Plan Given	Extinguishers, rear exit, emergency lighting.	Have all applicable code requirements been met?	Repair or replace emergency lights.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Bar across rear exit must be removed during operating hours.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Ensure extinguishers have been inspected by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN

**Custom Graphic - 226 Springdale RD - 706-278-3021**

08/19/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	-------------------------	---	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Ladder 3 A Shift**

**Georgia Board of Workers Compensation - 475 Reed RD**

08/02/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Have key made for Knox Box.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	-----------------------------	------------------------

**Kirk's Cycle - 929 N Glenwood AVE - 706-226-4090**

08/24/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Electrical wiring must be installed in conduit or properly covered.	CORRECTIVE ACTION PLAN

**North Georgia Highlands Center - 900 Shugart RD - 706-270-5005**

08/31/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all exit signs and emergency lighting that does not operate as designed.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install FACP sign on the door concealing the fire alarm control panel.	CORRECTIVE ACTION PLAN
					Residential dryer must be vented to the exterior of the structure.	
					Multi plug adapters shall not be plugged into multi plug adapters. Extension cords shall not be plugged into multi plug adapters. Extension cords shall not be plugged into extension cords.	
				Multi plug adapters must be mounted according to manufacturers recommended specifications.		
Are proper clearances of combustible materials from ignition sources being maintained?	Maintain clearance between combustibles and potential ignition sources.	CORRECTIVE ACTION PLAN				
Are the means of egress free of obstructions or impediments?	Remove all storage from stairwells.	CORRECTIVE ACTION PLAN				

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.

**Southern Roofing & Exteriors - 1225 Coronet DR #2- 706-271-0038**

08/31/2021	OTC	Corrective Action Plan Given	Extinguishers and blanks.	Are there any identifiable electrical hazards?	Add blank to panel.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add extinguishers to building by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN

**Stubbs Prosthetics & Orthotics Inc. - 1213 Broadrick DR**

08/09/2021	OTC	Corrective Action Plan Given		Is required emergency lighting in place?	Repair or replace emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Install approved exit signage.	CORRECTIVE ACTION PLAN
				Is a fire alarm installed where required by the Code?	Have fire alarm inspection done by a ga licensed contractor.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Remove combustibles near electrical panels. Add electrical room signage on door.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Ensure address is visible from the road fronting the building.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Remove items blocking egress.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Mount fire extinguishers at a height of 48 inches from the top of the extinguisher to the floor.	CORRECTIVE ACTION PLAN

**Ladder 3 B Shift**

**Check Into Cash Title Pawn - 1133 N Glenwood AVE - 706-226-0270**

08/23/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are proper clearances of combustible materials from ignition sources being maintained?	Maintain proper clearance of combustible materials in front of the electrical panel.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**The Cliffs Apartments - 818 Shugart RD**

08/02/2021	Complaint	Corrective Action Plan Given	Fix the water issues.	Have all applicable code requirements been met?	Water leaks have caused mold. Water has been leaking around electrical outlets.	CORRECTIVE ACTION PLAN
08/11/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Add appropriate extinguishers. ASA CARPET CAPITAL FIRE PROTECTION PYE-BARKER CHATTANOOGA FIRE PROTECTION DOUBLE D PIPING	CORRECTIVE ACTION PLAN

**Ladder 3 C Shift**

**Dalton Village Apartments - 1809 Shadow LN - 706-226-6424**

08/20/2021	Complaint	Corrective Action Plan Given		Have all applicable code requirements been met?	Insure private vehicles are parking in approved locations and to full fire department vehicle access.	CORRECTIVE ACTION PLAN
------------	-----------	------------------------------	--	---	---	------------------------

**Squad 1 A Shift**

**American Import Auto Parts LLC. - 412 N Hamilton ST**

08/19/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Mr Florez was advised he had too many vehicles obstructing Fire Department access, main entrance egress and the public way. He was instructed to start removing vehicles immediately. Mr Florex was advised a follow inspection would be conducted next week. DPD and County Building Inspector will be notified.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	---	------------------------

**La Esquinita - 613 N Hamilton ST**

08/09/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are there any identifiable electrical hazards?	Install blanks in open spaces in the electrical panel.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguisher requires a current annual inspection. Inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.

**Ramirez Property 305 E Hawthorne Street - 305 E Hawthorne ST - 706-218-2035**

08/04/2021	Site Visit	Corrective Action Plan Given		If a change of occupancy has occurred, does the building comply with current code requirements?	A site inspection was requested by an occupant looking at opening a dance hall. The occupant was told that the building didn't meet code requirements for a dance hall.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	---	------------------------

**Reyes Auto Repair - 1119 N Glenwood AVE - 706-529-5666**

08/24/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	---	--	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Self Recycling Inc - 1206 Lamar ST - 770-382-2320**

08/10/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Install emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Compressed gas cylinders must be properly secured. Repair all ceiling openings to maintain ceiling assembly continuity.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Extension cords shall not substitute permanent electrical wiring. Extension cords shall not be plugged into extension cords, extension cords shall not be plugged into multi plug adapters, multi plug adapters shall not be plugged into multi plug adapters.  Ensure proper closure of all disconnects and breaker boxes.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Remove all egress impediments.	CORRECTIVE ACTION PLAN
				Have sprinklers been maintained and in operational condition?	Sprinkler system requires a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.  Remove all foreign suspensions and attachments from all sprinkler piping.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Ensure all fire extinguishers are properly mounted.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Shaw Plant WM - 902 N Hamilton ST - 706-532-2500**

08/27/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Is required emergency lighting in place?	Install emergency lighting in stairwells and office space hallways.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install FDC sign. Remove all obstructions to fire control components. Install FACP sign at the entrance concealing the Fire Alarm Control Panel.	CORRECTIVE ACTION PLAN
				Is a fire alarm installed where required by the Code?	Fire alarms require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Multi plug adapters must be mounted according to manufacturers recommended specifications. Extension cords shall not be plugged into multi plug adapters. Install blanks in open spaces in electrical panels. Maintain 36" clearance in front of electrical panels.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Remove all fire extinguisher obstructions.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Technicraft Services - 111 Westcott WAY - 706-529-7568**

08/11/2021	Annual	Corrective Action Plan Given	Corrective action plan has been provided.	Have all applicable code requirements been met?	Remove compressed gas and flammable storage from beneath the stairwell.  Compressed gas cylinders must be secured.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	---	---	--	------------------------

**Squad 1 B Shift**

**Decorative Concepts - 1803 Abutment RD - 423-682-7257**

08/25/2021	New Construction	Corrective Action Plan Given		Have sprinklers been installed under fixed obstructions over 4 feet in width?	Add sprinklers to racks.	CORRECTIVE ACTION PLAN
				Have sprinklers been installed under open grating over 4 feet in width?		CORRECTIVE ACTION PLAN
				Are all required areas of the building sprinkled?		CORRECTIVE ACTION PLAN

**First Methodist Church - 500 S Thornton AVE - 706-278-8494**

08/09/2021	Annual	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
				Has the cooking equipment been inspected and cleaned by a properly trained individual?	Have system inspected.	CORRECTIVE ACTION PLAN
				Has the appropriately scheduled inspection of the entire exhaust system for grease buildup been conducted by a Georgia licensed contractor?	Have system inspected.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Griffin Company of Dalton - 110 E Tyler ST #B**

08/02/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Electrical wiring must be covered or installed in conduit. Install outlet covers and switch plate covers. Install covers on junction boxes containing electrical wire splices.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox box on the building portion that houses the riser.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require current annual inspection. Inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

**Imperial Del Arte - 304 Springdale RD #1**

08/24/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	-------------------------	---	------------------------

**Irene's Cakes - 304 Springdale RD #3**

08/23/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	-------------------------	---	------------------------

**JAA Controls - 441 N Hamilton ST - 706.278.8309**

08/05/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?		CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install outlet covers. Install cover on junction box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

**Miscelanea Polvos - 238 Springdale RD**

08/24/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Is required emergency lighting in place?	Install lighted exit signs with integrated emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Install lighted exit signs with integrated emergency lighting.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Tyler Street Storage - 110 E Tyler ST #A- 706-226-0503**

08/02/2021	Annual	Corrective Action Plan Given		Have all applicable code requirements been met?	Install FACP sign on door concealing the fire alarm control panel.	CORRECTIVE ACTION PLAN
				Is a detector present at the location of each control unit(s), notification appliance circuit power extender(s) and supervising station transmitting equipment of the fire alarm to provide notification?	Install smoke detector above fire alarm control panel.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install electrical outlet covers. Install junction box covers on open junction boxes containing electrical wire splices.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN

**Squad 1 C Shift**

**Dalton Diagnostic - 820 Tinsley ST - 7062590660**

08/19/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Have all applicable code requirements been met?	Replace FDC sign. Install a RISER ROOM sign.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Expressway Samples - 108 Westcott WAY - 706-280-1437 706-226-1818**

08/12/2021	Annual	Corrective Action Plan Given	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all emergency lighting and exit signs that do not operate as designed.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install FDC sign at the Fire Department Connection.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Extension cords shall not substitute permanent electrical wiring and shall not pass through walls.  Install junction box covers on all open junction boxes containing electrical wire splices.  Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Are proper clearances of combustible materials from ignition sources being maintained?	Maintain proper clearance of combustible materials from ignition sources.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Remove exterior hasps from egress doors.  LP storage must be relocated away from means of egress.  Remove all impediments from means of egress.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Remove all obstructions that block fire extinguisher access.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



**Techmer PM - 105 E Tyler ST - 706-226-8409**

08/05/2021	Annual	Passed with Comments	Corrective action plan has been provided.	Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install FACP sign on the door concealing the fire alarm control panel.	CORRECTIVE ACTION PLAN
				Components required to be fire or smoke resistant are properly maintained?	Replace all missing ceiling tiles to maintain ceiling assembly continuity.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	A key for the riser room must be installed in the Knox box.	CORRECTIVE ACTION PLAN
				Are the installed sprinkler systems code compliant?	Place a sprinkler wrench in the sprinkler cabinet. Install RISER ROOM sign.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



# Dalton Fire Department

Dalton, GA

This report was generated on 9/9/2021 9:12:02 AM



## Count of Occupancies Inspected per Occupancy Type per Inspection Type for Date Range

Start Date: 08/01/2021 | End Date: 08/31/2021

OCCUPANCY	COUNT
<b>INSPECTION TYPE: Alcohol</b>	
M • Drug stores	1
<b>INSPECTION TYPE: Annual</b>	
A-2 • Eating, drinking places, (other)	1
A-3 • Places of religious worship	1
B • Business office	7
B • Business, (other)	1
B • Motor vehicle or boat sales, services, repair	7
B • Personal service, including barber & beauty shops	2
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	3
B • Training and skill development not in a school or academic program (this shall include, but not be limited to, tutoring centers, martial arts studios, gymnastics and similar uses regardless of the ages served, and where not classified as a Group A occupancy)	1
E • Day care, in commercial property	1
F-1 • Carpets and rugs (includes cleaning)	4
F-1 • Clothing	1
F-1 • Electronics	1
F-1 • Manufacturing, processing	4
F-2 • Metal products (fabrication and assembly)	2
H-3 • Class I, II or IIIA flammable or combustible liquids that are used or stored in normally closed containers or systems pressurized at 15 pounds per square inch gauge (103.4 kPa) or less.	1
I-1 • Alcohol and drug centers	1
M • Convenience stores	1
M • General retail, (other)	2
M • Grocery store	1
M • Household goods, sales, repairs	2
M • Retail or wholesale stores	1
M • Service station, gas station	1
M: Mercantile (other)	1
S-1 • Motor vehicle repair garages	1
S-1 • Warehouse	1
S-1: Storage, Moderate-hazard	2
<b>INSPECTION TYPE: Complaint</b>	
R-2 • Apartment houses	1
R-2 • Multifamily dwelling	1
R-3 • 1 or 2 family dwelling	1
S-1: Storage, Moderate-hazard	2
<b>INSPECTION TYPE: Fire Alarm</b>	
E • Elementary school, including kindergarten	1

Locked inspections only.



emergencyreporting.com

Doc Id: 1132

Page # 1 of 3

OCCUPANCY	COUNT
<b>INSPECTION TYPE: Kitchen Hood Installation</b>	
M • Grocery store	1
<b>INSPECTION TYPE: New Construction</b>	
F-1 • Carpets and rugs (includes cleaning)	1
R-4 • Residential board and care facilities	1
<b>INSPECTION TYPE: OTC</b>	
B • Business office	2
B • Business, (other)	4
B • Clinic, outpatient	1
B • Post offices or mailing firms	1
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	1
M • Convenience stores	1
M • Retail or wholesale stores	1
M: Mercantile (other)	1
<b>INSPECTION TYPE: Plan Review</b>	
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	6
A-3 • Courthouse	1
B • Business office	1
B • Electronic data processing	4
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	1
F-1 • Manufacturing, processing	2
I-2 • Hospitals	2
M • Grocery store	1
S-1 • Self-service storage facility (mini-storage)	1
<b>INSPECTION TYPE: Site Visit</b>	
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	2
A-3 • Community halls	2
A-3 • Courthouse	1
B • Business office	10
B • Business, (other)	3
B • Clinic, outpatient	1
B • Electronic data processing	2
B • Motor vehicle or boat sales, services, repair	1
E • Elementary school, including kindergarten	7
E • High school/junior high school/middle school	7
F-1 • Carpets and rugs (includes cleaning)	2
F-1 • Manufacturing, processing	1
I-1 • Alcohol and drug centers	1
M • Grocery store	2
M • Household goods, sales, repairs	3
M • Retail or wholesale stores	3
M • Service station, gas station	1
M • Department stores	1
M: Mercantile (other)	3

Locked inspections only.



OCCUPANCY	COUNT
R-1 • Hotels (transient)	6
R-1 • Motels (transient)	1
R-2 • Apartment houses	10
R-2 • Motels (nontransient)	2
R-2 • Multifamily dwelling	2
R-4 • Residential board and care facilities	3
S-1: Storage, Moderate-hazard	3
U • Construction site	1
U • Mixed use	1
U • Vacant lot	1
<b>Total # of Inspections:</b>	<b>175</b>

Locked inspections only.

