

DALTON FIRE DEPARTMENT

TODD PANGLE
Fire Chief
Telephone 706-278-7363
Fax 706-272-7107
tpangle@daltonga.gov

404 School Street
Dalton, GA 30720



PUBLIC SAFETY COMMISSION
Bill Weaver
Terry Mathis
Anthony Walker
Luis Viamonte
Truman Whitfield

November 2020

Incident Response

Monthly Synopsis

<u>Category</u>	<u>Responses</u>	<u>Percentage</u>
Fire	18	5.80%
Overpressure Rupture, Overheat	0	0%
Rescue/Medical	197	63.54%
Hazardous Condition	10	3.22%
Service Call	12	3.87%
Good Intent	44	14.19%
False Alarm	29	9.35%

Total Responses	310
Average Response Time	3:16
Estimated Loss	\$46,900

DALTON

Incident Type Report (Monthly Summary)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
1 Fire				
111 Building fire	3	0.96%	\$24,000	51.17%
131 Passenger vehicle fire	2	0.64%	\$8,000	17.05%
132 Road freight or transport vehicle fire	1	0.32%	\$500	1.06%
137 Camper or recreational vehicle (RV) fire	2	0.64%	\$10,000	21.32%
143 Grass fire	1	0.32%	\$0	0.00%
151 Outside rubbish, trash or waste fire	4	1.29%	\$4,000	8.52%
154 Dumpster or other outside trash receptacle	5	1.61%	\$400	0.85%
	18	5.80%	\$46,900	100.00%
3 Rescue & Emergency Medical Service Incident				
311 Medical assist, assist EMS crew	173	55.80%	\$0	0.00%
322 Motor vehicle accident with injuries	12	3.87%	\$0	0.00%
323 Motor vehicle/pedestrian accident (MV Ped)	1	0.32%	\$0	0.00%
324 Motor Vehicle Accident with no injuries	11	3.54%	\$0	0.00%
	197	63.54%	\$0	0.00%
4 Hazardous Condition (No Fire)				
411 Gasoline or other flammable liquid spill	2	0.64%	\$0	0.00%
441 Heat from short circuit (wiring),	1	0.32%	\$0	0.00%
442 Overheated motor	2	0.64%	\$0	0.00%
444 Power line down	1	0.32%	\$0	0.00%
445 Arcing, shorted electrical equipment	2	0.64%	\$0	0.00%
461 Building or structure weakened or collapsed	2	0.64%	\$0	0.00%
	10	3.22%	\$0	0.00%
5 Service Call				
500 Service Call, other	1	0.32%	\$0	0.00%
522 Water or steam leak	1	0.32%	\$0	0.00%
531 Smoke or odor removal	2	0.64%	\$0	0.00%
551 Assist police or other governmental agency	2	0.64%	\$0	0.00%
553 Public service	2	0.64%	\$0	0.00%
554 Assist invalid	1	0.32%	\$0	0.00%
561 Unauthorized burning	3	0.96%	\$0	0.00%
	12	3.87%	\$0	0.00%
6 Good Intent Call				
611 Dispatched & cancelled en route	33	10.64%	\$0	0.00%
622 No Incident found on arrival at dispatch	5	1.61%	\$0	0.00%
631 Authorized controlled burning	2	0.64%	\$0	0.00%
651 Smoke scare, odor of smoke	1	0.32%	\$0	0.00%

DALTON

Incident Type Report (Monthly Summary)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
6 Good Intent Call				
671 HazMat release investigation w/no HazMat	3	0.96%	\$0	0.00%
	44	14.19%	\$0	0.00%
7 False Alarm & False Call				
715 Local alarm system, malicious false alarm	2	0.64%	\$0	0.00%
731 Sprinkler activation due to malfunction	1	0.32%	\$0	0.00%
732 Extinguishing system activation due to	1	0.32%	\$0	0.00%
733 Smoke detector activation due to	2	0.64%	\$0	0.00%
735 Alarm system sounded due to malfunction	5	1.61%	\$0	0.00%
743 Smoke detector activation, no fire -	13	4.19%	\$0	0.00%
744 Detector activation, no fire -	1	0.32%	\$0	0.00%
745 Alarm system activation, no fire -	3	0.96%	\$0	0.00%
746 Carbon monoxide detector activation, no CO	1	0.32%	\$0	0.00%
	29	9.35%	\$0	0.00%

Total Incident Count: 310

Total Est Loss:

\$46,900

DALTON

Dollar Value Saved & Loss Analysis (Monthly)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident Type	Count	Total Values	Total Losses	Total Saved	Percent Lost	Percent Saved
111 Building fire	3	\$183,500	\$24,000	\$159,500	13.08%	86.92%
131 Passenger vehicle fire	1	\$12,000	\$8,000	\$4,000	66.67%	33.33%
132 Road freight or	1	\$500	\$500	\$0	100.00%	0.00%
137 Camper or recreational	2	\$11,000	\$10,000	\$1,000	90.91%	9.09%
151 Outside rubbish, trash	1	\$5,000	\$4,000	\$1,000	80.00%	20.00%
154 Dumpster or other	1	\$0	\$400	\$-400	0.00%	0.00%
Grand Totals	9	\$212,000	\$46,900	\$165,100		

Total Percent Lost: 22.12%

Total Percent Saved: 77.88%

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002729	0	11/01/2020	01:35:59	1310 Vann	611 Dispatched & cancelled en route	
20-0002730	0	11/01/2020	01:43:47	319 Hamilton (North)	611 Dispatched & cancelled en route	
20-0002731	0	11/01/2020	02:53:41	812 Crawford (West)	311 Medical assist, assist EMS crew	
20-0002732	0	11/01/2020	04:21:51	1515 Cleveland	311 Medical assist, assist EMS crew	
20-0002733	0	11/01/2020	06:51:36	330 Langston	611 Dispatched & cancelled en route	
20-0002734	0	11/01/2020	10:33:45	1806 Bridgewater	651 Smoke scare, odor of smoke	
20-0002735	0	11/01/2020	11:01:32	MM337 I-75 S. Bound	631 Authorized controlled burning	
20-0002736	0	11/01/2020	12:01:13	1897 Middle Summit	311 Medical assist, assist EMS crew	
20-0002737	0	11/01/2020	16:16:59	609 Thornton (South)	311 Medical assist, assist EMS crew	
20-0002738	0	11/01/2020	17:35:04	1200 James	311 Medical assist, assist EMS crew	
20-0002739	0	11/01/2020	20:02:31	1116 Willowdale	611 Dispatched & cancelled en route	
20-0002740	0	11/01/2020	22:45:42	519 Hawthorne (West)	311 Medical assist, assist EMS crew	
20-0002741	0	11/02/2020	01:40:39	1116 Willowdale	311 Medical assist, assist EMS crew	
20-0002742	0	11/02/2020	10:26:02	104 Fort Hill	743 Smoke detector activation, no fire	
20-0002743	0	11/02/2020	16:40:10	Vann	311 Medical assist, assist EMS crew	
20-0002744	0	11/02/2020	18:17:16	518 Vernon	311 Medical assist, assist EMS crew	
20-0002745	0	11/02/2020	20:52:48	580 Walnut (East)	461 Building or structure weakened or	
20-0002746	0	11/03/2020	00:20:17	I-75 S. Bound	611 Dispatched & cancelled en route	
20-0002747	0	11/03/2020	04:49:31	1300 Waugh (West)	311 Medical assist, assist EMS crew	
20-0002748	0	11/03/2020	10:13:34	302 Davidson	311 Medical assist, assist EMS crew	
20-0002749	0	11/03/2020	11:52:54	401 Fredrick (North)	311 Medical assist, assist EMS crew	
20-0002750	0	11/03/2020	12:01:44	1116 Willowdale	311 Medical assist, assist EMS crew	
20-0002751	0	11/03/2020	12:02:23	98 Walnut (West)	411 Gasoline or other flammable liquid	
20-0002752	0	11/03/2020	12:37:19	1013 Lakeshore (East)	311 Medical assist, assist EMS crew	
20-0002753	0	11/03/2020	14:03:41	2305 Abutment	311 Medical assist, assist EMS crew	
20-0002754	0	11/03/2020	14:09:21	724 Skylark	311 Medical assist, assist EMS crew	
20-0002755	0	11/03/2020	21:46:18	706 Holland	111 Building fire	\$3,000
20-0002756	0	11/03/2020	23:41:41	808 Beirut	311 Medical assist, assist EMS crew	
20-0002757	0	11/04/2020	04:24:44	430 Underwood	611 Dispatched & cancelled en route	
20-0002758	0	11/04/2020	08:32:23	1200 Glenwood (North)	324 Motor Vehicle Accident with no	
20-0002759	0	11/04/2020	08:54:58	1906 Cameron	311 Medical assist, assist EMS crew	
20-0002760	0	11/04/2020	10:13:10	521 Eleventh	611 Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002761	0	11/04/2020	12:25:38	815 Shugart	311 Medical assist, assist EMS crew	
20-0002762	0	11/04/2020	22:51:53	310 Chestnut	311 Medical assist, assist EMS crew	
20-0002763	0	11/05/2020	00:06:57	1306 Underwood	311 Medical assist, assist EMS crew	
20-0002764	0	11/05/2020	01:23:50	1712 Violet	735 Alarm system sounded due to	
20-0002765	0	11/05/2020	11:28:50	Heritage	551 Assist police or other	
20-0002766	0	11/05/2020	14:02:24	1327 Walnut (West)	311 Medical assist, assist EMS crew	
20-0002767	0	11/05/2020	14:28:11	1200 Memorial	743 Smoke detector activation, no fire	
20-0002768	0	11/05/2020	15:41:08	204 Industrial (West)	611 Dispatched & cancelled en route	
20-0002769	0	11/05/2020	15:56:26	1000 May	311 Medical assist, assist EMS crew	
20-0002770	0	11/05/2020	17:09:55	Chattanooga	322 Motor vehicle accident with	
20-0002771	0	11/05/2020	17:39:07	1014 Lavert	311 Medical assist, assist EMS crew	
20-0002772	0	11/05/2020	20:27:44	1008 Richards	611 Dispatched & cancelled en route	
20-0002773	0	11/05/2020	22:32:59	105 Pine Hill	311 Medical assist, assist EMS crew	
20-0002774	0	11/05/2020	22:41:19	824 Shugart	311 Medical assist, assist EMS crew	
20-0002775	0	11/06/2020	07:51:11	Reed	611 Dispatched & cancelled en route	
20-0002776	0	11/06/2020	07:58:42	Hawthorne (East)	322 Motor vehicle accident with	
20-0002777	0	11/06/2020	08:39:31	Walnut (East)	311 Medical assist, assist EMS crew	
20-0002778	0	11/06/2020	11:57:46	1200 Glenwood (North)	324 Motor Vehicle Accident with no	
20-0002779	0	11/06/2020	12:21:34	2311 Chattanooga	311 Medical assist, assist EMS crew	
20-0002780	0	11/06/2020	13:45:04	1102 Burleyson	311 Medical assist, assist EMS crew	
20-0002781	0	11/06/2020	14:59:52	450 Conway	151 Outside rubbish, trash or waste	
20-0002782	0	11/06/2020	16:58:17	1020 Dude	311 Medical assist, assist EMS crew	
20-0002783	0	11/06/2020	18:21:34	875 Shugart	311 Medical assist, assist EMS crew	
20-0002784	0	11/06/2020	19:26:07	1320 Winton	311 Medical assist, assist EMS crew	
20-0002785	0	11/06/2020	19:55:02	1203 Glenwood (North)	311 Medical assist, assist EMS crew	
20-0002786	0	11/06/2020	20:52:03	219 Fredrick (North)	611 Dispatched & cancelled en route	
20-0002787	0	11/06/2020	23:58:46	227 Grace	311 Medical assist, assist EMS crew	
20-0002788	0	11/07/2020	15:40:55	652 Haigmill Lake	631 Authorized controlled burning	
20-0002789	0	11/07/2020	18:06:40	201 Cappes	551 Assist police or other	
20-0002790	0	11/07/2020	20:06:51	612 Dantzler	311 Medical assist, assist EMS crew	
20-0002791	0	11/07/2020	20:35:52	1116 Underwood	311 Medical assist, assist EMS crew	
20-0002791	1	11/25/2020	04:36:13	109 Waterworks (West)	137 Camper or recreational vehicle	\$4,000

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002792	0	11/07/2020	20:42:53	148 Castle	311 Medical assist, assist EMS crew	
20-0002793	0	11/07/2020	23:32:20	701 Clark	311 Medical assist, assist EMS crew	
20-0002794	0	11/08/2020	02:01:11	816 Shugart	311 Medical assist, assist EMS crew	
20-0002795	0	11/08/2020	02:55:30	I-75 N. Bound	324 Motor Vehicle Accident with no	
20-0002796	0	11/08/2020	03:47:12	740 McGhee	311 Medical assist, assist EMS crew	
20-0002797	0	11/08/2020	13:21:31	507 Morris (East)	311 Medical assist, assist EMS crew	
20-0002798	0	11/08/2020	13:59:19	1365 Walnut (West)	411 Gasoline or other flammable liquid	
20-0002799	0	11/08/2020	14:27:04	I-75 S. Bound	143 Grass fire	
20-0002800	0	11/08/2020	16:08:18	1300 Underwood	311 Medical assist, assist EMS crew	
20-0002801	0	11/08/2020	20:29:06	406 Cuyler (west)	311 Medical assist, assist EMS crew	
20-0002802	0	11/09/2020	11:11:53	1320 Winton	311 Medical assist, assist EMS crew	
20-0002803	0	11/09/2020	11:28:49	704 Betty	311 Medical assist, assist EMS crew	
20-0002804	0	11/09/2020	12:28:02	I-75 S. Bound	622 No Incident found on arrival at	
20-0002805	0	11/09/2020	13:04:58	1308 Walnut (West)	745 Alarm system activation, no fire -	
20-0002806	0	11/09/2020	15:03:38	1300 Walnut (West)	442 Overheated motor	
20-0002807	0	11/09/2020	15:28:20	1210 Royal	732 Extinguishing system activation	
20-0002808	0	11/09/2020	16:26:27	1320 Winton	311 Medical assist, assist EMS crew	
20-0002809	0	11/09/2020	17:39:43	1200 James	311 Medical assist, assist EMS crew	
20-0002810	0	11/09/2020	17:47:45	301 Waugh (West)	311 Medical assist, assist EMS crew	
20-0002811	0	11/09/2020	18:34:20	706 Valley	311 Medical assist, assist EMS crew	
20-0002812	0	11/09/2020	20:53:47	210 Easterling (North)	311 Medical assist, assist EMS crew	
20-0002813	0	11/09/2020	21:57:06	519 Hawthorne (West)	743 Smoke detector activation, no fire	
20-0002814	0	11/10/2020	00:07:19	1220 Broadrick	311 Medical assist, assist EMS crew	
20-0002815	0	11/10/2020	01:24:06	308 Paige	531 Smoke or odor removal	
20-0002816	0	11/10/2020	01:35:06	1407 Mack	311 Medical assist, assist EMS crew	
20-0002817	0	11/10/2020	03:50:01	302 Davidson	311 Medical assist, assist EMS crew	
20-0002818	0	11/10/2020	04:11:22	925 Shugart	131 Passenger vehicle fire	\$8,000
20-0002819	0	11/10/2020	04:41:10	125 Morris (East)	622 No Incident found on arrival at	
20-0002820	0	11/10/2020	09:06:25	1500 Manly	442 Overheated motor	
20-0002821	0	11/10/2020	10:44:20	101 Thornton (North)	311 Medical assist, assist EMS crew	
20-0002822	0	11/10/2020	11:52:40	Chattanooga	611 Dispatched & cancelled en route	
20-0002823	0	11/10/2020	12:52:01	430 Fourth	611 Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002824	0	11/10/2020	15:43:51	2315 Sir Lancelot	311 Medical assist, assist EMS crew	
20-0002825	0	11/10/2020	18:48:01	609 Thornton (South)	311 Medical assist, assist EMS crew	
20-0002826	0	11/10/2020	20:38:16	I-75 S. Bound	611 Dispatched & cancelled en route	
20-0002827	0	11/10/2020	21:14:22	108 Tibbs (North)	531 Smoke or odor removal	
20-0002828	0	11/10/2020	21:41:22	103 Harvard	311 Medical assist, assist EMS crew	
20-0002829	0	11/11/2020	06:57:04	1210 Royal	735 Alarm system sounded due to	
20-0002830	0	11/11/2020	10:12:44	805 Professional	611 Dispatched & cancelled en route	
20-0002831	0	11/11/2020	10:48:15	1287 Glenwood (North)	311 Medical assist, assist EMS crew	
20-0002832	0	11/11/2020	11:58:21	1200 Memorial	611 Dispatched & cancelled en route	
20-0002833	0	11/11/2020	12:16:03	1504 Cleo	311 Medical assist, assist EMS crew	
20-0002834	0	11/11/2020	12:51:42	1205 Glenwood (North)	311 Medical assist, assist EMS crew	
20-0002835	0	11/11/2020	16:15:45	1092 Helton	311 Medical assist, assist EMS crew	
20-0002836	0	11/11/2020	16:38:58	301 Jones	311 Medical assist, assist EMS crew	
20-0002837	0	11/11/2020	17:55:31	1302 Moice	311 Medical assist, assist EMS crew	
20-0002838	0	11/11/2020	18:36:57	1000 Vista	311 Medical assist, assist EMS crew	
20-0002839	0	11/11/2020	18:51:01	1320 Winton	744 Detector activation, no fire -	
20-0002840	0	11/11/2020	18:53:47	400 Glenwood (North)	324 Motor Vehicle Accident with no	
20-0002841	0	11/11/2020	19:30:41	Cleveland	611 Dispatched & cancelled en route	
20-0002842	0	11/11/2020	21:54:53	710 Boundary (west)	311 Medical assist, assist EMS crew	
20-0002843	0	11/12/2020	04:26:33	1307 Georgian	311 Medical assist, assist EMS crew	
20-0002844	0	11/12/2020	07:50:58	1016 Vista	445 Arcing, shorted electrical	
20-0002845	0	11/12/2020	11:21:39	Fields	622 No Incident found on arrival at	
20-0002846	0	11/12/2020	11:36:16	917 Lake	561 Unauthorized burning	
20-0002847	0	11/12/2020	13:17:32	1200 Memorial	735 Alarm system sounded due to	
20-0002848	0	11/12/2020	14:14:38	1600 Beechland	311 Medical assist, assist EMS crew	
20-0002849	0	11/12/2020	14:55:27	1134 Boylston	311 Medical assist, assist EMS crew	
20-0002850	0	11/12/2020	21:44:40	340 I-75 N. Bound	611 Dispatched & cancelled en route	
20-0002851	0	11/13/2020	00:43:20	1101 Rio Vista	743 Smoke detector activation, no fire	
20-0002852	0	11/13/2020	01:33:06	428 Barbara	311 Medical assist, assist EMS crew	
20-0002853	0	11/13/2020	12:43:08	2315 Sir Lancelot	611 Dispatched & cancelled en route	
20-0002854	0	11/13/2020	14:10:02	815 Shugart	311 Medical assist, assist EMS crew	
20-0002855	0	11/13/2020	14:42:23	1102 Thornton (North)	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002856	0	11/13/2020	14:43:21	601 Glenwood (South)	311 Medical assist, assist EMS crew	
20-0002857	0	11/13/2020	17:14:48	425 Lester	311 Medical assist, assist EMS crew	
20-0002858	0	11/13/2020	17:38:36	621 Frazier	311 Medical assist, assist EMS crew	
20-0002859	0	11/13/2020	18:42:37	1800 Tolchester	743 Smoke detector activation, no fire	
20-0002860	0	11/13/2020	19:35:00	1502 Anthony	311 Medical assist, assist EMS crew	
20-0002861	0	11/13/2020	19:38:31	112 Cappes	311 Medical assist, assist EMS crew	
20-0002862	0	11/13/2020	20:39:43	616 Fourth	311 Medical assist, assist EMS crew	
20-0002863	0	11/13/2020	22:01:58	626 Fourth	311 Medical assist, assist EMS crew	
20-0002864	0	11/14/2020	01:03:14	Franklin (West)	154 Dumpster or other outside trash	
20-0002865	0	11/14/2020	01:48:45	220 Pentz (North)	154 Dumpster or other outside trash	
20-0002866	0	11/14/2020	01:56:23	214 Hamilton (South)	154 Dumpster or other outside trash	\$400
20-0002867	0	11/14/2020	02:16:34	519 Oxford	154 Dumpster or other outside trash	
20-0002868	0	11/14/2020	02:41:15	113 Gordon (West)	154 Dumpster or other outside trash	
20-0002869	0	11/14/2020	07:56:15	1212 Broadrick	311 Medical assist, assist EMS crew	
20-0002870	0	11/14/2020	14:24:48	302 Red Cross	735 Alarm system sounded due to	
20-0002871	0	11/14/2020	14:31:45	1701 North Summit	311 Medical assist, assist EMS crew	
20-0002872	0	11/14/2020	18:59:16	802 Red Clay	311 Medical assist, assist EMS crew	
20-0002873	0	11/14/2020	19:26:21	1001 Frazier	311 Medical assist, assist EMS crew	
20-0002874	0	11/14/2020	21:15:05	1809 Shadow	311 Medical assist, assist EMS crew	
20-0002875	0	11/15/2020	00:22:08	1116 Willowdale	311 Medical assist, assist EMS crew	
20-0002876	0	11/15/2020	02:52:27	907 Grandfield	311 Medical assist, assist EMS crew	
20-0002877	0	11/15/2020	07:44:06	209 Griffin	311 Medical assist, assist EMS crew	
20-0002878	0	11/15/2020	10:23:20	2331 Mount Haven	444 Power line down	
20-0002879	0	11/15/2020	11:24:43	I-75 N. Bound	322 Motor vehicle accident with	
20-0002880	0	11/15/2020	14:20:01	1404 Sheryl	311 Medical assist, assist EMS crew	
20-0002881	0	11/15/2020	15:22:44	124 Grimes (North)	311 Medical assist, assist EMS crew	
20-0002882	0	11/15/2020	17:21:22	2224 Chattanooga	671 HazMat release investigation w/no	
20-0002883	0	11/15/2020	17:31:37	913 Lakemont	671 HazMat release investigation w/no	
20-0002884	0	11/15/2020	18:59:19	1343 Walnut (West)	131 Passenger vehicle fire	
20-0002885	0	11/15/2020	23:19:03	205 Fields	311 Medical assist, assist EMS crew	
20-0002886	0	11/16/2020	11:19:17	800 Professional	311 Medical assist, assist EMS crew	
20-0002887	0	11/16/2020	12:02:15	Glenwood (North)	324 Motor Vehicle Accident with no	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002888	0	11/16/2020	14:56:39	510 Fairview	554 Assist invalid	
20-0002889	0	11/16/2020	21:50:06	1115 Roan	311 Medical assist, assist EMS crew	
20-0002890	0	11/17/2020	00:47:48	1312 Felice	311 Medical assist, assist EMS crew	
20-0002891	0	11/17/2020	02:31:17	2669 Abutment	311 Medical assist, assist EMS crew	
20-0002892	0	11/17/2020	04:58:51	1015 New South Harris	311 Medical assist, assist EMS crew	
20-0002893	0	11/17/2020	10:25:38	1102 Waugh (West)	611 Dispatched & cancelled en route	
20-0002894	0	11/17/2020	11:11:49	MLK Jr.	323 Motor vehicle/pedestrian accident	
20-0002895	0	11/17/2020	11:46:58	230 Brickyard	311 Medical assist, assist EMS crew	
20-0002896	0	11/17/2020	13:01:17	Thornton (North)	324 Motor Vehicle Accident with no	
20-0002897	0	11/17/2020	14:22:12	226 Grace	324 Motor Vehicle Accident with no	
20-0002898	0	11/17/2020	16:50:26	Underwood	324 Motor Vehicle Accident with no	
20-0002899	0	11/17/2020	19:54:49	610 Audubon	311 Medical assist, assist EMS crew	
20-0002900	0	11/17/2020	23:17:47	620 Emmons	611 Dispatched & cancelled en route	
20-0002901	0	11/18/2020	08:55:04	1115 Professional	311 Medical assist, assist EMS crew	
20-0002902	0	11/18/2020	09:31:11	2209 Seminole	611 Dispatched & cancelled en route	
20-0002903	0	11/18/2020	13:19:30	1320 Winton	611 Dispatched & cancelled en route	
20-0002904	0	11/19/2020	05:48:58	1300 Waugh (West)	311 Medical assist, assist EMS crew	
20-0002905	0	11/19/2020	07:00:47	510 Shugart	311 Medical assist, assist EMS crew	
20-0002906	0	11/19/2020	09:24:52	314 Sparks	311 Medical assist, assist EMS crew	
20-0002907	0	11/19/2020	10:50:39	612 Callahan	311 Medical assist, assist EMS crew	
20-0002908	0	11/19/2020	11:39:00	1320 Winton	743 Smoke detector activation, no fire	
20-0002909	0	11/19/2020	12:01:45	I-75 S. Bound	132 Road freight or transport vehicle	\$500
20-0002910	0	11/19/2020	15:30:06	1320 Winton	311 Medical assist, assist EMS crew	
20-0002911	0	11/19/2020	16:41:06	111 Pentz (North)	611 Dispatched & cancelled en route	
20-0002912	0	11/19/2020	19:08:54	1021 Riverburch	671 HazMat release investigation w/no	
20-0002913	0	11/20/2020	00:47:12	Glenwood (North)	611 Dispatched & cancelled en route	
20-0002914	0	11/20/2020	11:06:08	900 Shugart	746 Carbon monoxide detector	
20-0002915	0	11/20/2020	17:01:07	1104 Walston	733 Smoke detector activation due to	
20-0002916	0	11/20/2020	17:39:06	Underwood	322 Motor vehicle accident with	
20-0002917	0	11/21/2020	03:15:06	222 Cuyler (west)	611 Dispatched & cancelled en route	
20-0002918	0	11/21/2020	07:52:59	806 Harris	611 Dispatched & cancelled en route	
20-0002919	0	11/21/2020	08:37:02	606 Clark	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002920	0	11/21/2020	08:41:34	Thornton (North)	324 Motor Vehicle Accident with no	
20-0002921	0	11/21/2020	09:48:04	2321 Sir Lancelot	311 Medical assist, assist EMS crew	
20-0002922	0	11/21/2020	11:01:18	1107 Hair	611 Dispatched & cancelled en route	
20-0002923	0	11/21/2020	11:49:35	Dozier	322 Motor vehicle accident with	
20-0002924	0	11/21/2020	15:30:57	311 Spencer (North)	561 Unauthorized burning	
20-0002925	0	11/21/2020	20:34:47	1107 Hair	311 Medical assist, assist EMS crew	
20-0002926	0	11/21/2020	21:01:22	I-75 N. Bound	324 Motor Vehicle Accident with no	
20-0002927	0	11/22/2020	01:00:26	1107 Hair	311 Medical assist, assist EMS crew	
20-0002928	0	11/22/2020	03:46:58	605 Stone	445 Arcing, shorted electrical	
20-0002929	0	11/22/2020	05:38:22	908 Elk	731 Sprinkler activation due to	
20-0002930	0	11/22/2020	05:42:49	609 Thornton (South)	715 Local alarm system, malicious	
20-0002931	0	11/22/2020	10:57:24	2201 Chattanooga	611 Dispatched & cancelled en route	
20-0002932	0	11/22/2020	11:06:32	413 Vann	311 Medical assist, assist EMS crew	
20-0002933	0	11/22/2020	14:43:13	508 Fairview	622 No Incident found on arrival at	
20-0002934	0	11/22/2020	14:54:23	900 Shugart	715 Local alarm system, malicious	
20-0002935	0	11/22/2020	17:15:21	1300 Vernon	561 Unauthorized burning	
20-0002936	0	11/22/2020	17:36:02	Canterbury	743 Smoke detector activation, no fire	
20-0002937	0	11/22/2020	17:39:50	519 Hawthorne (West)	311 Medical assist, assist EMS crew	
20-0002938	0	11/22/2020	21:10:33	519 Hawthorne (West)	622 No Incident found on arrival at	
20-0002939	0	11/23/2020	00:36:43	519 Hawthorne (West)	311 Medical assist, assist EMS crew	
20-0002940	0	11/23/2020	02:23:37	219 Fredrick (North)	311 Medical assist, assist EMS crew	
20-0002941	0	11/23/2020	03:58:01	1955 Sourwood	311 Medical assist, assist EMS crew	
20-0002942	0	11/23/2020	10:29:31	4 Brothers	311 Medical assist, assist EMS crew	
20-0002943	0	11/23/2020	10:45:23	Shugart	322 Motor vehicle accident with	
20-0002944	0	11/23/2020	11:31:50	1709 Westchester	311 Medical assist, assist EMS crew	
20-0002945	0	11/23/2020	14:42:06	1300 Waugh (West)	311 Medical assist, assist EMS crew	
20-0002946	0	11/23/2020	15:24:55	1300 Waugh (West)	311 Medical assist, assist EMS crew	
20-0002947	0	11/23/2020	15:59:58	1308 Beverly	311 Medical assist, assist EMS crew	
20-0002948	0	11/23/2020	17:51:10	101 Walnut (West)	311 Medical assist, assist EMS crew	
20-0002949	0	11/23/2020	18:23:20	810 Beirut	311 Medical assist, assist EMS crew	
20-0002950	0	11/23/2020	18:40:25	210 South	500 Service Call, other	
20-0002951	0	11/23/2020	19:50:36	1300 Waugh (West)	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002952	0	11/23/2020	21:39:52	801 Red Clay	311 Medical assist, assist EMS crew	
20-0002953	0	11/24/2020	03:14:05	3008 Brookhaven (East)	311 Medical assist, assist EMS crew	
20-0002954	0	11/24/2020	06:36:00	711 Hamilton (South)	311 Medical assist, assist EMS crew	
20-0002955	0	11/24/2020	07:57:41	1509 Thistle	311 Medical assist, assist EMS crew	
20-0002956	0	11/24/2020	08:34:09	805 Professional	311 Medical assist, assist EMS crew	
20-0002957	0	11/24/2020	11:10:24	2206 Old Ivy	311 Medical assist, assist EMS crew	
20-0002958	0	11/24/2020	12:48:52	Thornton (South)	322 Motor vehicle accident with	
20-0002959	0	11/24/2020	13:09:12	1401 Rosewood	311 Medical assist, assist EMS crew	
20-0002960	0	11/24/2020	14:17:04	1012 May	311 Medical assist, assist EMS crew	
20-0002961	0	11/24/2020	15:01:12	1012 May	311 Medical assist, assist EMS crew	
20-0002962	0	11/24/2020	16:07:19	938 Market	311 Medical assist, assist EMS crew	
20-0002963	0	11/24/2020	16:33:28	1756 Brighton	311 Medical assist, assist EMS crew	
20-0002964	0	11/24/2020	16:47:06	815 Shugart	311 Medical assist, assist EMS crew	
20-0002965	0	11/24/2020	18:07:33	Alex	611 Dispatched & cancelled en route	
20-0002966	0	11/24/2020	18:10:12	Walnut (East)	322 Motor vehicle accident with	
20-0002967	0	11/24/2020	19:55:04	1237 Covie	311 Medical assist, assist EMS crew	
20-0002968	0	11/24/2020	19:58:52	911 Stoneleigh	311 Medical assist, assist EMS crew	
20-0002969	0	11/24/2020	20:22:32	1004 Willow Park Lane	311 Medical assist, assist EMS crew	
20-0002970	0	11/24/2020	21:45:55	330 Hamilton (South)	611 Dispatched & cancelled en route	
20-0002971	0	11/25/2020	04:36:13	109 Waterworks (West)	151 Outside rubbish, trash or waste	\$4,000
20-0002972	0	11/25/2020	07:17:20	109 Waterworks (West)	137 Camper or recreational vehicle	\$6,000
20-0002973	0	11/25/2020	09:10:30	1933 Shields	745 Alarm system activation, no fire -	
20-0002974	0	11/25/2020	11:26:51	1001 Market	611 Dispatched & cancelled en route	
20-0002975	0	11/25/2020	12:55:28	815 Shugart	311 Medical assist, assist EMS crew	
20-0002976	0	11/25/2020	13:45:09	North Bypass	322 Motor vehicle accident with	
20-0002977	0	11/25/2020	15:05:45	1200 Memorial	733 Smoke detector activation due to	
20-0002978	0	11/25/2020	15:19:53	1303 Moice	311 Medical assist, assist EMS crew	
20-0002979	0	11/25/2020	17:25:05	1919 Richland	743 Smoke detector activation, no fire	
20-0002980	0	11/25/2020	18:26:31	1320 Winton	311 Medical assist, assist EMS crew	
20-0002981	0	11/25/2020	19:48:21	118 Tibbs (North)	311 Medical assist, assist EMS crew	
20-0002982	0	11/25/2020	20:11:31	500 Brittney	311 Medical assist, assist EMS crew	
20-0002983	0	11/26/2020	02:19:37	148 Castle	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0002984	0	11/26/2020	02:43:31	1708 Chestnut Oak	311 Medical assist, assist EMS crew	
20-0002985	0	11/26/2020	09:06:34	519 Hawthorne (West)	743 Smoke detector activation, no fire	
20-0002986	0	11/26/2020	11:03:22	Underwood	611 Dispatched & cancelled en route	
20-0002987	0	11/26/2020	13:42:18	1320 Winton	743 Smoke detector activation, no fire	
20-0002988	0	11/26/2020	18:51:27	1503 Morris (East)	735 Alarm system sounded due to	
20-0002989	0	11/26/2020	20:39:34	1407 Vann	311 Medical assist, assist EMS crew	
20-0002990	0	11/27/2020	10:29:16	1320 Glenwood (North)	461 Building or structure weakened or	
20-0002991	0	11/27/2020	11:25:10	1220 Broadrick	522 Water or steam leak	
20-0002992	0	11/27/2020	13:12:19	824 Beirut	311 Medical assist, assist EMS crew	
20-0002993	0	11/27/2020	13:44:55	1822 Dug Gap	311 Medical assist, assist EMS crew	
20-0002994	0	11/27/2020	14:23:12	218 Spencer (North)	311 Medical assist, assist EMS crew	
20-0002995	0	11/27/2020	15:04:00	Morris (East)	322 Motor vehicle accident with	
20-0002996	0	11/27/2020	17:35:00	1234 Glenwood (North)	311 Medical assist, assist EMS crew	
20-0002997	0	11/27/2020	17:44:54	2032 Dug Gap	311 Medical assist, assist EMS crew	
20-0002998	0	11/27/2020	18:34:45	1310 Walnut (West)	311 Medical assist, assist EMS crew	
20-0002999	0	11/27/2020	19:50:52	902 Hamilton (North)	311 Medical assist, assist EMS crew	
20-0003000	0	11/27/2020	22:34:29	1721 Brighton	311 Medical assist, assist EMS crew	
20-0003001	0	11/28/2020	00:08:14	306 Paige	311 Medical assist, assist EMS crew	
20-0003002	0	11/28/2020	01:13:25	319 Hamilton (North)	745 Alarm system activation, no fire -	
20-0003003	0	11/28/2020	03:02:13	824 Beirut	311 Medical assist, assist EMS crew	
20-0003004	0	11/28/2020	03:38:02	623 Pine	111 Building fire	\$3,500
20-0003005	0	11/28/2020	06:37:49	555 Stillwood	311 Medical assist, assist EMS crew	
20-0003006	0	11/28/2020	07:37:54	623 Pine	111 Building fire	\$17,500
20-0003007	0	11/28/2020	07:51:42	1625 Ryman Ridge	311 Medical assist, assist EMS crew	
20-0003008	0	11/28/2020	10:06:39	1237 Covie	311 Medical assist, assist EMS crew	
20-0003009	0	11/28/2020	12:38:57	1320 Winton	311 Medical assist, assist EMS crew	
20-0003010	0	11/28/2020	15:20:24	Suitcase Simpson	311 Medical assist, assist EMS crew	
20-0003011	0	11/28/2020	15:56:34	314 Sycamore	441 Heat from short circuit (wiring),	
20-0003012	0	11/28/2020	17:33:50	218 Spencer (North)	311 Medical assist, assist EMS crew	
20-0003013	0	11/28/2020	18:47:07	411 Sassafras	151 Outside rubbish, trash or waste	
20-0003014	0	11/28/2020	22:20:57	2319 Sir Lancelot	311 Medical assist, assist EMS crew	
20-0003015	0	11/28/2020	23:13:24	512 Central	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {11/01/2020} And {11/30/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0003016	0	11/29/2020	00:11:56	708 Lance	311 Medical assist, assist EMS crew	
20-0003017	0	11/29/2020	02:35:18	306 Bowen	311 Medical assist, assist EMS crew	
20-0003018	0	11/29/2020	09:35:36	897 East Summit	553 Public service	
20-0003019	0	11/29/2020	10:18:47	813 Underwood	311 Medical assist, assist EMS crew	
20-0003020	0	11/29/2020	10:26:43	519 Hawthorne (West)	743 Smoke detector activation, no fire	
20-0003021	0	11/29/2020	10:48:50	Thornton (North)	324 Motor Vehicle Accident with no	
20-0003022	0	11/29/2020	11:50:08	Brooker	322 Motor vehicle accident with	
20-0003023	0	11/29/2020	13:51:37	2209 Rocky Face	743 Smoke detector activation, no fire	
20-0003024	0	11/29/2020	16:16:21	502 Judson	151 Outside rubbish, trash or waste	
20-0003025	0	11/29/2020	18:51:30	961 Avenue E	311 Medical assist, assist EMS crew	
20-0003026	0	11/29/2020	20:02:38	1322 Walnut (West)	311 Medical assist, assist EMS crew	
20-0003027	0	11/29/2020	21:24:01	1300 Waugh (West)	311 Medical assist, assist EMS crew	
20-0003028	0	11/29/2020	22:40:52	Glenwood (North)	322 Motor vehicle accident with	
20-0003029	0	11/30/2020	07:28:10	100 Bogle (South)	311 Medical assist, assist EMS crew	
20-0003030	0	11/30/2020	09:13:38	416 Cedar	311 Medical assist, assist EMS crew	
20-0003031	0	11/30/2020	11:06:10	107 Fernwood	553 Public service	
20-0003032	0	11/30/2020	13:18:56	1200 Memorial	743 Smoke detector activation, no fire	
20-0003033	0	11/30/2020	16:35:08	1010 Ponderosa	311 Medical assist, assist EMS crew	
20-0003034	0	11/30/2020	18:50:17	2103 Walnut (East)	311 Medical assist, assist EMS crew	
20-0003035	0	11/30/2020	19:08:23	1604 Underwood	311 Medical assist, assist EMS crew	
20-0003036	0	11/30/2020	19:11:05	1300 Waugh (West)	311 Medical assist, assist EMS crew	
20-0003037	0	11/30/2020	21:21:05	703 Corey	311 Medical assist, assist EMS crew	

Total Incident Count 310

Total Est Loss

\$46,900

DALTON

Incident Type Period Comparisons

Alarm Date Between {11/01/2020} and {11/30/2020}

Incident Type	11/01/2020	11/01/2019	11/01/2018	11/01/2017
	to 11/30/2020	to 11/30/2019	to 11/30/2018	to 11/30/2017
111 Building fire	3	2	3	5
113 Cooking fire, confined to container	0	2	2	1
131 Passenger vehicle fire	2	3	2	1
132 Road freight or transport vehicle fire	1	0	1	0
137 Camper or recreational vehicle (RV) fire	2	0	1	0
140 Natural vegetation fire, Other	0	0	1	0
141 Forest, woods or wildland fire	0	0	0	1
142 Brush or brush-and-grass mixture fire	0	1	0	2
143 Grass fire	1	0	1	0
151 Outside rubbish, trash or waste fire	4	0	1	2
154 Dumpster or other outside trash receptacle fire	5	0	0	0
251 Excessive heat, scorch burns with no ignition	0	1	1	0
311 Medical assist, assist EMS crew	173	182	187	183
322 Motor vehicle accident with injuries	12	12	8	1
323 Motor vehicle/pedestrian accident (MV Ped)	1	1	0	0
324 Motor Vehicle Accident with no injuries	11	13	9	1
352 Extrication of victim(s) from vehicle	0	0	1	0
353 Removal of victim(s) from stalled elevator	0	1	0	0
357 Extrication of victim(s) from machinery	0	1	0	0
410 Combustible/flammable gas/liquid condition,	0	0	0	1
411 Gasoline or other flammable liquid spill	2	0	2	1
412 Gas leak (natural gas or LPG)	0	2	1	0
413 Oil or other combustible liquid spill	0	0	1	0
421 Chemical hazard (no spill or leak)	0	0	1	0
423 Refrigeration leak	0	1	0	0
441 Heat from short circuit (wiring), defective/worn	1	0	1	3
442 Overheated motor	2	3	0	0
444 Power line down	1	1	3	0
445 Arcing, shorted electrical equipment	2	2	4	1
451 Biological hazard, confirmed or suspected	0	0	0	1

DALTON

Incident Type Period Comparisons

Alarm Date Between {11/01/2020} and {11/30/2020}

Incident Type	11/01/2020 to 11/30/2020	11/01/2019 to 11/30/2019	11/01/2018 to 11/30/2018	11/01/2017 to 11/30/2017
461 Building or structure weakened or collapsed	2	0	1	0
462 Aircraft standby	0	1	0	0
463 Vehicle accident, general cleanup	0	0	1	0
500 Service Call, other	1	1	0	1
510 Person in distress, Other	0	0	1	0
511 Lock-out	0	0	0	1
512 Ring or jewelry removal	0	0	0	1
522 Water or steam leak	1	1	0	0
531 Smoke or odor removal	2	1	0	1
542 Animal rescue	0	0	0	1
551 Assist police or other governmental agency	2	0	2	0
552 Police matter	0	0	1	0
553 Public service	2	1	2	7
554 Assist invalid	1	0	0	0
555 Defective elevator, no occupants	0	0	1	0
561 Unauthorized burning	3	4	0	2
600 Good intent call, Other	0	1	0	0
611 Dispatched & cancelled en route	33	36	38	27
622 No Incident found on arrival at dispatch address	5	4	3	5
631 Authorized controlled burning	2	1	1	0
651 Smoke scare, odor of smoke	1	3	5	3
671 HazMat release investigation w/no HazMat	3	0	1	3
715 Local alarm system, malicious false alarm	2	1	2	2
721 Bomb scare - no bomb	0	0	0	1
731 Sprinkler activation due to malfunction	1	1	0	1
732 Extinguishing system activation due to	1	0	0	1
733 Smoke detector activation due to malfunction	2	2	1	4
735 Alarm system sounded due to malfunction	5	5	5	4
736 CO detector activation due to malfunction	0	0	1	1
741 Sprinkler activation, no fire - unintentional	0	0	0	2

DALTON

Incident Type Period Comparisons

Alarm Date Between {11/01/2020} and {11/30/2020}

Incident Type	11/01/2020	11/01/2019	11/01/2018	11/01/2017
	to	to	to	to
	11/30/2020	11/30/2019	11/30/2018	11/30/2017
742 Extinguishing system activation	0	0	1	0
743 Smoke detector activation, no fire -	13	8	18	16
744 Detector activation, no fire - unintentional	1	0	4	3
745 Alarm system activation, no fire - unintentional	3	5	16	10
746 Carbon monoxide detector activation, no CO	1	0	2	0
Totals	<u>310</u>	<u>304</u>	<u>338</u>	<u>301</u>

Dalton Fire Department

Monthly Emergency Response Time Analysis

Emergency Responses

Response		Count	Percentage
Hrs	Mins		
	< 01	22	6.0%
	01	54	14.8%
	02	96	26.4%
	03	105	28.9%
	04	37	10.1%
	05	30	8.2%
	06	9	2.4%
	07	2	0.5%
	08	3	0.8%
	09	2	0.5%
	10	2	0.5%
	11	1	0.2%

Overall Average Response Time: 00:03:16

Dalton Fire Department

Monthly Non-Emergency Response Time Analysis

Non-Emergency Responses

Response		Count	Percentage
Hrs	Mins		
	< 01	4	6.3%
	01	2	3.1%
	02	10	15.8%
	03	9	14.2%
	04	13	20.6%
	05	10	15.8%
	06	9	14.2%
	07	3	4.7%
	09	1	1.5%
	10	1	1.5%
	14	1	1.5%

Overall Average Response Time: 00:04:36

**Dalton Fire Department
Medical Incident Study
EMS On scene/Not on scene Prior to DFD Comparison
11/1/20 –11/30/20**

Total incidents in time period – 197

EMS on-scene prior to DFD – 65

EMS not on-scene prior – 140

During the month of November, Dalton Fire Department arrived on-scene prior to Hamilton EMS on 71% of medical responses.

Training Division Monthly Report

November 2020

Overview

The department delivered annual hazardous materials recertification training to all personnel. Annual physical agility testing was conducted for all certified firefighters. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of November totaled 2,025.

Outside Schools

1 firefighter attended NPQ Instructor 1 at GPSTC.

Support Functions

- 184 hours were spent completing apparatus checks and equipment replenishment
- Cleaning and maintenance activities accounted for 753 hours in November
- 20 hours were attributed to hydrant detail
- 6 hours were dedicated to fire investigation and related activities
- SCBA maintenance consumed 12 hours during the month

Dalton Fire Department

Dalton, GA

This report was generated on 12/2/2020 4:12:07 PM



Completed Inspections per Inspection Type for Date Range

Occupancy Status: All | Start Date: 11/01/2020 | End Date: 11/30/2020

ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Alcohol						
20454	Tienda Tikal Y Cocina	616 Fourth AVE #Suites 4,5,6 Dalton, GA 30720	11/02/2020	Daniel, Matthew T.	Passed	
10546	Maganas	604 MLK Jr. BLVD Dalton, GA 30720	11/12/2020	Hearn, Scott Raymond	Passed	
40099 - 4	Pablito's	933 Market ST #Suite 14 A Dalton, GA 30720	11/16/2020	Daniel, Matthew T.	Passed	
30032	Los Pablos	2204 Chattanooga RD Dalton, GA 30720	11/19/2020	Daniel, Matthew T.	Passed with Comments	

Total # Inspections for Alcohol: 4

Inspection Type: Annual

10128	Arevalo's Tires	312 Glenwood (North) AVE Dalton, GA 30720	11/02/2020	Hearn, Scott Raymond	Passed	
10287	Beehive Book Shop	330 Hamilton (South) ST Dalton, GA 30720	11/03/2020	Hearn, Scott Raymond	Complaint cleared by Contact	
10285	American Pawn Brokers	322 Hamilton (South) ST Dalton, GA 30720	11/03/2020	Hearn, Scott Raymond	Passed	
10284	Citizens Finance	320 Hamilton (South) ST Dalton, GA 30720	11/03/2020	Hearn, Scott Raymond	Correction Notice Issued	
10645	ARC Studios Fine Art Photography	318 Hamilton (South) ST Dalton, GA 30720	11/03/2020	Hearn, Scott Raymond	Correction Notice Issued	
10259	Chamber of Commerce- Carpet Rug Institute	100 Hamilton (South) ST Dalton, GA 30720	11/03/2020	Stratton, Dale Lee	Correction Notice Issued	Please email photos of violation corrections to: dstratton @daltonga.gov
10286	Tijuana's Mexican Restaraunt	328 Hamilton (South) ST Dalton, GA 30720	11/03/2020	Hearn, Scott Raymond	Passed	
10283	Rust	316 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Hearn, Scott Raymond	Correction Notice Issued	
10280	Tasker's Barber and Salon	310 Hamilton (South) ST Dalton, GA 30720 10282	11/05/2020	Hearn, Scott Raymond	Correction Notice Issued	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
10282	Psychological Forensic Associates	314 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Hearn, Scott Raymond	Correction Notice Issued	
10274	Boy Scouts of America	202 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Blankenship, Donnie	Correction Notice Issued	
10272	Vapors Alley	204 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Blankenship, Donnie	Correction Notice Issued	
10571	Jack's Pawn Shop	214 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Blankenship, Donnie	Passed with Comments	
10279	Daffodil and Daisy Children's Boutique	308 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Hearn, Scott Raymond	Correction Notice Issued	
10270	Salon De Belleza	218 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Blankenship, Donnie	Correction Notice Issued	
10269	Big Rig Lending	220 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Blankenship, Donnie	Passed	
10261	Foster's Service Center	107 S Pentz ST Dalton, GA 30720	11/05/2020	Stratton, Dale Lee	Correction Notice Issued	
10278	Southern Accessories & Accents	304 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Hearn, Scott Raymond	Correction Notice Issued	
10288	Sweet Spot	336 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Hearn, Scott Raymond	Correction Notice Issued	
10620	Pam's Place	334 Hamilton (South) ST Dalton, GA 30720	11/05/2020	Hearn, Scott Raymond	Correction Notice Issued	
10160	Rock Bridge Community Church - The Gathering	100 Gordon (West) ST Dalton, GA 30720	11/05/2020	Stratton, Dale Lee	Correction Notice Issued	
10078	Dalton Print Shop	118 Cuyler (west) ST Dalton, GA 30720	11/06/2020	Blankenship, Donnie	Correction Notice Issued	
10433	Styles	201 Crawford (West) ST Dalton, GA 30720	11/06/2020	Stratton, Dale Lee	Correction Notice Issued	
10079	Top Dog Grooming	120 Cuyler (west) ST Dalton, GA 30720	11/06/2020	Blankenship, Donnie	Correction Notice Issued	
10428	Cornejo Law Firm	104 S Pentz ST Dalton, GA 30720	11/06/2020	Stratton, Dale Lee	Passed	
10430	Inkus Tattoos	108 S Pentz ST Dalton, GA 30720	11/06/2020	Stratton, Dale Lee	Passed	
10171	Rock bridge Community Church - The Stage	123 Gordon (West) ST Dalton, GA 30720	11/09/2020	Stratton, Dale Lee	Correction Notice Issued	
10055	Rock Bridge Community Church - The Wink	115 Crawford (West) ST Dalton, GA 30720	11/09/2020	Stratton, Dale Lee	Correction Notice Issued	
10077	Glaze Supply	117 Cuyler (west) ST Dalton, GA 30720	11/09/2020	Hearn, Scott Raymond	Correction Notice Issued	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
10060	Rock Bridge Community Church - Offices	121 Crawford (West) ST Dalton, GA 30720	11/09/2020	Stratton, Dale Lee	Correction Notice Issued	
10277	Earth's Remedies	300 Hamilton (South) ST Dalton, GA 30720	11/09/2020	Hearn, Scott Raymond	Correction Notice Issued	
10170	Rock Bridge Community Church - Woman's Enrichment Center	109 Gordon (West) ST Dalton, GA 30720	11/09/2020	Stratton, Dale Lee	Correction Notice Issued	
10275	St. Ives Realty	200 Hamilton (South) ST Dalton, GA 30720	11/09/2020	Blankenship, Donnie	Correction Notice Issued	
10166	Rock Bridge Community Church Children's Center	124 Gordon (West) ST Dalton, GA 30720	11/09/2020	Stratton, Dale Lee	Correction Notice Issued	
10076	Starr Mathews Agency	114 Cuyler (west) ST Dalton, GA 30720	11/09/2020	Blankenship, Donnie	Correction Notice Issued	
10076 - 1	Laird Litigation	114 W Cuyler ST #Suite 2 Dalton, GA 30720	11/09/2020	Blankenship, Donnie	Correction Notice Issued	
10646	Grace Christian Gift and Art gallery	111 Gordon (West) ST Dalton, GA 30720	11/09/2020	Blankenship, Donnie	Correction Notice Issued	
10281	Hamiltons at Home	312 Hamilton (South) ST Dalton, GA 30720	11/09/2020	Hearn, Scott Raymond	Correction Notice Issued	
10074	Downtown Nutrition Spot	107 Cuyler (west) ST Dalton, GA 30720	11/09/2020	Hearn, Scott Raymond	Passed	
10306	Vacant	221 W Cuyler ST Dalton, GA 30720	11/10/2020	Hearn, Scott Raymond	Passed	Building is vacant.
10039	Traci Laster Hair Artist Salon	107 Gordon (West) ST Dalton, GA 30720	11/10/2020	Blankenship, Donnie	Correction Notice Issued	
10636	Vacant	305 Thornton (South) AVE Dalton, GA 30720	11/10/2020	Hearn, Scott Raymond	Passed with Comments	Vacant
10057	Boyett & Foshee Insurance Agency	200 S Pentz ST Dalton, GA 30720	11/10/2020	Blankenship, Donnie	Correction Notice Issued	
10085	The Chop Shop	209 Cuyler (west) ST Dalton, GA 30720	11/10/2020	Hearn, Scott Raymond	Correction Notice Issued	
10177	North Georgia Buisness Machines	203 Gordon (West) ST Dalton, GA 30720	11/10/2020	Blankenship, Donnie	Correction Notice Issued	
10178	Bohemy Co Salon and Spa	205 Gordon (West) ST Dalton, GA 30720	11/10/2020	Blankenship, Donnie	Passed	
10509	Glaze Supply Warehouse	312 S Pentz ST Dalton, GA 30720	11/10/2020	Hearn, Scott Raymond	Passed	
10080	Oakwood Cafe	201 Cuyler (west) ST Dalton, GA 30720	11/11/2020	Hearn, Scott Raymond	Correction Notice Issued	Must have fire alarm operational within 7 days.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
10432	Shear Performance	203 Crawford (West) ST Dalton, GA 30720	11/11/2020	Stratton, Dale Lee	Correction Notice Issued	
10483		200 Gordon (West) ST #C Dalton, GA 30720	11/11/2020	Stratton, Dale Lee	Passed	Vacant/Secured
10175	vacant	202 Gordon (West) ST Dalton, GA 30720	11/11/2020	Stratton, Dale Lee	Passed	
10451	vacant	102 S Pentz ST Dalton, GA 30720	11/11/2020	Stratton, Dale Lee	Passed	
10172	Richard K Murray	200 Gordon (West) ST #Suite A Dalton, GA 30720	11/12/2020	Stratton, Dale Lee	Correction Notice Issued	
10176	Carpet Capital Association of Realtors	204 Gordon (West) ST Dalton, GA 30720	11/12/2020	Stratton, Dale Lee	Correction Notice Issued	
10181 - 1	Just Christi	211 Gordon (West) ST Dalton, GA 30720	11/13/2020	Blankenship, Donnie	Correction Notice Issued	
10181	HHC Mini Warehouse	211 Gordon (West) ST Dalton, GA 30720	11/13/2020	Blankenship, Donnie	Correction Notice Issued	
10181 - 2	Robo Trading	211 Gordon (West) ST Dalton, GA 30720	11/13/2020	Blankenship, Donnie	Correction Notice Issued	
10183	Finn and Hurtt	215 Gordon (West) ST Dalton, GA 30720	11/13/2020	Blankenship, Donnie	Correction Notice Issued	
10434	Phillips Production Studio	205 Crawford (West) ST Dalton, GA 30720	11/13/2020	Stratton, Dale Lee	Complaint cleared by Contact	
10631	Bank OZK	210 Morris (West) ST Dalton, GA 30720	11/16/2020	Hearn, Scott Raymond	Correction Notice Issued	
10069	Conasauga Accountability Courts	301 W Crawford ST Dalton, GA 30720	11/16/2020	Stratton, Dale Lee	Correction Notice Issued	
10680	Hamilton University/Winkler Building	1275 Elkwood DR Dalton, GA 30720	11/17/2020	Hearn, Scott Raymond	Correction Notice Issued	
10465	McDonald, Thames, and Ray	201 Selvidge St. (South) Dalton, GA 30720	11/17/2020	Blankenship, Donnie	Correction Notice Issued	
10086	American Floorcovering Alliance	210 Cuyler (west) ST Dalton, GA 30720	11/17/2020	Blankenship, Donnie	Correction Notice Issued	
10582	Tracy's Transmissions Plus	212 W Cuyler ST Dalton, GA 30720	11/17/2020	Blankenship, Donnie	Correction Notice Issued	
10191	Kellie Smith by Design	200 Hamilton (North) ST Dalton, GA 30720	11/17/2020	Hearn, Scott Raymond	Correction Notice Issued	Add carbon monoxide detectors.
10453	Domino's Pizza	222 W Cuyler ST Dalton, GA 30720	11/17/2020	Blankenship, Donnie	Correction Notice Issued	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
10452	Tate's Automotive	203 S Selvidge ST Dalton, GA 30720	11/17/2020	Blankenship, Donnie	Passed	
10581	Peach Realty Inc.	224 W Cuyler ST Dalton, GA 30720	11/17/2020	Blankenship, Donnie	Passed	
10680	Hamilton University/Winkler Building	1275 Elkwood DR Dalton, GA 30720	11/18/2020	Hearn, Scott Raymond	Passed	
10181	HHC Mini Warehouse	211 Gordon (West) ST Dalton, GA 30720	11/18/2020	Blankenship, Donnie	Passed	
10083	Raspberry Row	205 Cuyler (west) ST Dalton, GA 30720	11/18/2020	Hearn, Scott Raymond	Correction Notice Issued	Add Knox Box
10582	Tracy's Transmissions Plus	212 W Cuyler ST Dalton, GA 30720	11/18/2020	Blankenship, Donnie	Passed	
10509	Glaze Supply Warehouse	312 S Pentz ST Dalton, GA 30720	11/19/2020	Hearn, Scott Raymond	Passed	
10434	Phillips Production Studio	205 Crawford (West) ST Dalton, GA 30720	11/19/2020	Hearn, Scott Raymond	Passed	
10064	Studio 312 Hair Salon	215 Crawford (West) ST Dalton, GA 30720	11/19/2020	Stratton, Dale Lee	Correction Notice Issued	
10066	W. Lane Haley, P.C.	217 Crawford (West) ST Dalton, GA 30720	11/19/2020	Stratton, Dale Lee	Correction Notice Issued	
10224	Paper Princess	259 Hamilton (North) ST Dalton, GA 30720	11/23/2020	Hearn, Scott Raymond	Correction Notice Issued	Knox Box within a year.
10225	Fast Foto	261 Hamilton (North) ST Dalton, GA 30720	11/23/2020	Hearn, Scott Raymond	Correction Notice Issued	
10222	Fantasy Factory	257 Hamilton (North) ST Dalton, GA 30720	11/23/2020	Hearn, Scott Raymond	Correction Notice Issued	
10039	Traci Laster Hair Artist Salon	107 Gordon (West) ST Dalton, GA 30720	11/24/2020	Blankenship, Donnie	Passed	
10182	Acree Jinright & Co. Pc.	212 Gordon (West) ST Dalton, GA 30720	11/24/2020	Stratton, Dale Lee	Correction Notice Issued	
10035	Tenoch LLC	319 Hamilton (North) ST Dalton, GA 30720	11/24/2020	Blankenship, Donnie	Correction Notice Issued	
10260	Dalton Gold and Silver Exchange	108 Hamilton (South) ST Dalton, GA 30720	11/24/2020	Stratton, Dale Lee	Correction Notice Issued	
10067	Georgia Legal Services Program	219 Crawford (West) ST Dalton, GA 30720	11/24/2020	Stratton, Dale Lee	Correction Notice Issued	
10224	Paper Princess	259 Hamilton (North) ST Dalton, GA 30720	11/30/2020	Hearn, Scott Raymond	Passed with Comments	Add Knox Box within 1 year.

Total # Inspections for Annual:

86

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual Apartment						
10641	Cuyler Street Bungalows	203 Cuyler (west) ST Dalton, GA 30720	11/18/2020	Hearn, Scott Raymond	Passed	
Total # Inspections for Annual Apartment						1
Inspection Type: New Construction						
20292	Fashion Cleaners and Apartments	201 Morris (West) ST Dalton, GA 30720	11/19/2020	Stratton, Dale Lee	Correction Notice Issued	
20292	Fashion Cleaners and Apartments	201 Morris (West) ST Dalton, GA 30720	11/24/2020	Stratton, Dale Lee	Passed	
Total # Inspections for New Construction:						2
Inspection Type: New Kitchen Hood Installation						
50084	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	11/30/2020	Hearn, Scott Raymond	Correction Notice Issued	Several issues must be addressed in regards to shunts, makeup air and alarm interface.
50084	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	11/30/2020	Hearn, Scott Raymond	Correction Notice Issued	Took care of alarm on site. Makeup air shuts down.
Total # Inspections for New Kitchen Hood Installation:						2
Inspection Type: OTC						
20536	Logans Roadhouse	811 Walnut Square BLVD Dalton, GA 30720	11/04/2020	Daniel, Matthew T.	Passed	Owner change no violations.
40088	Moe's	1507 Walnut (West) AVE #Suite 1 Dalton, GA 30720	11/04/2020	Hearn, Scott Raymond	Passed	
20425 - 2	Couple of Mana Dorks	1011 Abutment RD Dalton, GA 30721	11/12/2020	Hearn, Scott Raymond	Passed	
30039 - 3	Dalton State College/Westcott Building/Book Store	650 College DR Dalton, GA 30720	11/16/2020	Daniel, Matthew T.	Passed	
10191	Kellie Smith by Design	200 Hamilton (North) ST Dalton, GA 30720	11/17/2020	Hearn, Scott Raymond	Correction Notice Issued	This will serve as the OTC inspection for Smithhoni LLC. Please use the annual inspection performed on 11/17/2020 for Kellie Smith Design as a reference.
10434	Phillips Production Studio	205 Crawford (West) ST Dalton, GA 30720	11/19/2020	Hearn, Scott Raymond	Passed	Business owner acquired OTC from city. See results from previous inspection.
40099 - 3	Pablito's	933 Market ST #Suite 14 Dalton, GA 30720	11/19/2020	Hearn, Scott Raymond	Passed	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: OTC						
20419 - 5	Money Saver Dollar Plus	1111 Walnut (East) AVE Dalton, GA 30720	11/19/2020	Hearn, Scott Raymond	Passed	
20597	Roadrunners of Dalton	652 S Hamilton ST Dalton, GA 30720	11/19/2020	Hearn, Scott Raymond	Passed	
10224	Paper Princess	259 Hamilton (North) ST Dalton, GA 30720	11/23/2020	Hearn, Scott Raymond	Passed with Comments	See annual inspection.
10026 - 26	Smash My Trash	100 N Hamilton ST Dalton, GA 30720	11/24/2020	Hearn, Scott Raymond	Passed	

Total # Inspections for OTC:

11

Inspection Type: Plan Review						
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	11/02/2020	Daniel, Matthew T.	Passed	
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	11/04/2020	Daniel, Matthew T.	Passed	
10441	M & M Building	412 School ST #104 Dalton, GA 30720	11/04/2020	Daniel, Matthew T.	Passed	
30051	Ford of Dalton	925 Shugart RD Dalton, GA 30720	11/12/2020	Daniel, Matthew T.	Passed	
20157	Tire Discounters	401 Hamilton (South) ST Dalton, GA 30720	11/19/2020	Daniel, Matthew T.	Passed	
30038	Shugart Center	841 Shugart RD Dalton, GA 30720	11/19/2020	Daniel, Matthew T.	Passed	
20493	Brymans Plaza South	101 W Walnut AVE Dalton, GA 30720	11/19/2020	Daniel, Matthew T.	Passed	
20066	Brymans Plaza North	100 W Walnut AVE Dalton, GA 30720	11/19/2020	Daniel, Matthew T.	Passed	

Total # Inspections for Plan Review:

8

Inspection Type: Reinspection						
10287	Beehive Book Shop	330 Hamilton (South) ST Dalton, GA 30720	11/11/2020	Hearn, Scott Raymond	Passed	
10080	Oakwood Cafe	201 Cuyler (west) ST Dalton, GA 30720	11/18/2020	Hearn, Scott Raymond	Correction Notice Issued	

Total # Inspections for Reinspection:

2

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10226	Bugs and Kisses	265 Hamilton (North) ST Dalton, GA 30720	11/04/2020	Blankenship, Donnie	Passed with Comments	Reviewed requirements for sprinklers in concealed ceilings.
50050	Circle K	1200 Glenwood (North) AVE Dalton, GA 30720	11/04/2020	Daniel, Matthew T.	Passed	Building was struck by vehicle no obvious damage to the structure.
40036	McDonalds	1523 Walnut (West) AVE Dalton, GA 30720	11/06/2020	Hearn, Scott Raymond	Passed with Comments	Site visit for remodel.
40043 - 1	Genesis Career College	2104 Fiber Park DR #A Dalton, GA 30720 4P004	11/12/2020	Stratton, Dale Lee	Passed with Comments	Spoke with Ms. Higgins about alarm requirements, Knox Box requirement and, required FACP sign. I emailed a PDF of the OTC report from Firehouse that listed the aforementioned code infractions.
30067 - 1	Park Canyon Apartment Homes	700 Park Canyon DR Dalton, GA 30720	11/12/2020	Daniel, Matthew T.	Passed	Building walk-through. Sprinklers and corridors.
40043 - 1	Genesis Career College	2104 Fiber Park DR #A Dalton, GA 30720 4P004	11/12/2020	Daniel, Matthew T.	Passed	
40043 - 2	Genesis Career College	2100 Fiber Park DR #B Dalton, GA 30720 4P004	11/12/2020	Daniel, Matthew T.	Passed	
30162	Tarkett	1104 Willowdale RD Dalton, GA 30720	11/13/2020	Blankenship, Donnie	Passed with Comments	Discussed removing exterior exit door. Discussed moving fire alarm pull station. Discussed additional exit lighting and exit signage. Discussed addition of sprinkler head and movement of sprinkler test valve.
20278	City of Refuge	416 Glenwood (South) AVE Dalton, GA 30720	11/19/2020	Daniel, Matthew T.	Passed with Comments	Discussed the use of the dormitory single room and the intent was for security and maintenance persons. That the use was not intended for family/apartment. Pamala was to contact zoning to propose change in the zoning.
20165	El Torito Foods	637 Hamilton (South) ST Dalton, GA 30720	11/19/2020	Blankenship, Donnie	Passed with Comments	Met with a potential owner about code requirements for bringing the building back to operational status as a restaurant. We advised them that they needed to submit plans for the structure, and kitchen hood system plans.
50084	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	11/20/2020	Blankenship, Donnie	Passed with Comments	
50084	DPS-Hammond Creek Middle School	330 Pleasant Grove DR NE Dalton, GA 30721	11/23/2020	Blankenship, Donnie	Passed	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10617	Condemned/Vacant	334 Hamilton (North) ST Dalton, GA 30720	11/23/2020	Blankenship, Donnie	Passed	
50107	Priority Care	1000 Riverburch PKY Dalton, GA 30720	11/23/2020	Hearn, Scott Raymond	Passed	Add key to Knox Box.
10359	Hamilton Medical Center	1200 Memorial DR Dalton, GA 30720	11/30/2020	Blankenship, Donnie	Passed with Comments	100% remodel inspection completed on the lab. Smoke damper in closet area didn't work properly. 100% remodel inspection on the OR. No issues found in the OR. 80% Inspection completed on PACU. Issues found included additional hangers needed on sprinkler piping.

Total # Inspections for Site Visit:

15

TOTAL # INSPECTIONS: 131

Includes LOCKED inspections for both archived and unarchived occupancy records.



Dalton Fire Department

Dalton, GA

This report was generated on 12/2/2020 4:10:38 PM



Occupancy Inspection History per Occupancy with Violations

Inspection Observations: FAIL | MultiOccupancyCategory: All Categories | Start Date: 11/01/2020 | End Date: 11/30/2020

INSPECTION DATE	INSPECTION TYPE	RESULT	NOTES	QUESTION	REMARKS	OBSERVATION
Citizens Financial - 320 Hamilton ST						
11/03/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add Knox Box	FAIL
11/05/2020	Annual	Correction Notice Issued		Is address signage correct and in place?	Add address numbers.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box.	FAIL
				Are the fire extinguishers installed in visible locations?	Remount fire extinguisher.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



emergencyreporting.com

Doc Id: 1362

Page # 1 of 28

American Floorcovering Alliance - 210 Cuyler (west) ST - 706.278.4101

11/17/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Install cover in electrical panel.	FAIL
				Are extension cords being used correctly?	Extension cords should be used for temporary power.	FAIL
				Are electrical rooms marked?	Mark electrical room.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove combustibles near electrical panels.	FAIL
				Are multiplug adapters code compliant and in proper use?	Mount multiplug adapters.	FAIL
				Are proper clearances of combustible materials from ignition sources being maintained?	Remove combustibles near gas water heater.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have Ga licensed fire extinguisher contractor service the fire extinguishers.	FAIL

Bank OZK - 210 Morris (West) ST - 706-279-1600

11/16/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?		FAIL
------------	--------	--------------------------	--	--	--	------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Conasauga Accountability Courts - 301 W Crawford ST - 706.281.4811

11/16/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Repair or replace exit lighting or emergency lighting that does not operate as designed.	FAIL
				Have all applicable code requirements been met?	Install covers on FDC	FAIL
				Are there any identifiable electrical hazards?	Install cover on open junction boxes. Install proper switch plate covers.	FAIL
				Are extension cords being used correctly?	Extension cords shall not pass through ceilings or walls. Extension cords shall not be plugged into other drop cords or power strip/multi plug adapters. Extension cords shall not substitute permanent electrical wiring.	FAIL
				Are multiplug adapters code compliant and in proper use?	Power strips must be mounted according to manufacturers specifications. Extension cords must not be plugged into power strips and power strips must not be plugged into extension cords.	FAIL
				Are rooms containing fire protection equipment properly marked ?	Install sign on RISER ROOM.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Dalton Print Shop - 118 Cuyler (west) ST - 7062261624

11/06/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Properly secure electrical outlet	FAIL
				Are extension cords being used correctly?	Extension cords should not be used for permanent power.	FAIL
				Are multiplug adapters code compliant and in proper use?	Mount multiplug adapters.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	FAIL
				Are the means of egress free of obstructions or impediments?	Remove items in means of egress.	FAIL
				Are the required number and type of fire extinguisher installed for the present hazard or condition?	Add additional fire extinguishers to ensure proper coverage	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have fire extinguishers serviced.	FAIL

Georgia Legal Services Program - 219 Crawford (West) ST - 706.272.2924

11/24/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Repair or replace exit sign. Repair or replace emergency lighting.	FAIL
				Are electrical rooms marked?	Install ELECTRICAL ROOM sign.	FAIL
				Are multiplug adapters code compliant and in proper use?	Multi plug adapters must be mounted according to manufacturers recommendations.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Fire extinguishers require current annual inspection, to be performed by a Georgia licensed contractor.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Glaze Supply - 117 Cuyler (west) ST - 706-278-3663						
11/09/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	FAIL
Laird Litigation - 114 W Cuyler ST #Suite 2 - 7065296880						
11/09/2020	Annual	Correction Notice Issued		Are the required number and type of fire extinguisher installed for the present hazard or condition?	Contact GA licensed fire extinguisher contractor to install proper extinguishers.	FAIL
Oakwood Cafe - 201 Cuyler (west) ST - 706-529-9663						
11/11/2020	Annual	Correction Notice Issued	Must have fire alarm operational within 7 days.	Is the required documentation located in the fire alarm document box?	No document box.	FAIL
				Has a current annual inspection of the fire alarm system been performed by a GA licensed contractor?	No power to alarm system.	FAIL
				Are there any identifiable electrical hazards?		FAIL
				Are extension cords being used correctly?	Cannot use extension cord for permanent wiring.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	FAIL
				Do doors open readily from the egress side?	Door leaf locked.	FAIL
				Are the means of egress free of obstructions or impediments?	Front door leaf locked.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/18/2020	Reinspection	Correction Notice Issued		Is the required documentation located in the fire alarm document box?	No document box.	FAIL
				Are there any identifiable electrical hazards?		FAIL
				Are extension cords being used correctly?	Cannot use extension cord for permanent wiring.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	FAIL
				Do doors open readily from the egress side?	Door leaf locked. Door leaf locked. 11/18/2020	FAIL
				Are the means of egress free of obstructions or impediments?	Front door leaf locked. Front door leaf locked. 11/18/2020	FAIL

Raspberry Row - 205 Cuyler (west) ST - 706.277.8500

11/18/2020	Annual	Correction Notice Issued	Add Knox Box	Has a Knox Box containing the property access keys been installed?	Add Knox Box to building within one year.	FAIL
------------	--------	--------------------------	--------------	--	---	------

Rock Bridge Community Church - Offices - 121 Crawford (West) ST - 706-279-3175

11/09/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Install appropriate switch plate and outlet covers.	FAIL
				Are electrical rooms marked?	Install sign stating ELECTRICAL ROOM or similar approved wording.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Maintain proper clearance in front of electrical panels.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Starr Mathews Agency - 114 Cuyler (west) ST - 7062780707

11/09/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Repair or replace emergency lighting.	FAIL
				Are exit signs properly illuminated?	Repair or replace exit signage.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove combustibles near electrical panels.	FAIL
				Is address signage correct and in place?	Install address signage on building as well as suite numbers on doors.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have a licensed contractor service the fire extinguisher.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Studio 312 Hair Salon - 215 Crawford (West) ST - 706-529-4400

11/19/2020	Annual	Correction Notice Issued		Does the business have a certificate of occupancy?	Contact city hall and ensure Certificate of Occupancy is current.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	FAIL
				Are boiler rooms, mechanical rooms, electrical rooms, and fire command centers free of combustible material storage?	Remove storage items.	FAIL
				Are fire extinguishers mounted at the proper height?		FAIL
				Are the fire extinguishers installed in visible locations?		FAIL
				Are the size and distribution of fire extinguishers code compliant?		FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?		FAIL
				Are the required number and type of fire extinguisher installed for the present hazard or condition?	Install and mount fire extinguisher.	FAIL
				Are the fire extinguishers unobstructed or unobscured from view?		FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Fire extinguisher must be inspected and tagged by a Georgia licensed contractor.	FAIL
				Do the fire extinguishers have the appropriate inspection tag required by law?		FAIL
				Are the fire extinguishers code compliant?		FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Tenoch LLC - 319 Hamilton (North) ST - 706.671.1009

11/24/2020	Annual	Correction Notice Issued		Has a current annual inspection of the fire alarm system been performed by a GA licensed contractor?	' Provide annual fire alarm inspection report.	FAIL
				Are extension cords being used correctly?	Extension cords should only be used for temporary power.	FAIL
				Are electrical rooms marked?	Mark electrical room.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove storage in electrical room.	FAIL
				Are the means of egress free of obstructions or impediments?	Remove fencing blocking egress.	FAIL
				Has the cooking equipment been inspected and cleaned by a properly trained individual?	Ensure cooking equipment is cleaned regularly.	FAIL
				Has the appropriately scheduled inspection of the entire exhaust system for grease buildup been conducted by a Georgia licensed contractor?	Provide documentation of hood cleaning.	FAIL
				Are deep-fat fryers a minimum of 16 inches away from surface flames?	Deep fryers are properly protected by the suppression system. Cooking equipment should be at least 6 inches inside hood.	FAIL
				Are the installed sprinkler systems code compliant?	Have annual inspection on sprinkler system performed by a GA licensed contractor.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have ' a GA licensed contractor service your fire extinguishers.	FAIL

The Chop Shop - 209 Cuyler (west) ST - 706.229.9377

11/10/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Must use blanks in empty spaces.	FAIL
------------	--------	--------------------------	--	--	----------------------------------	------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Top Dog Grooming - 120 Cuyler (west) ST - 7062723294

11/06/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Repair or replace emergency lighting.	FAIL
				Are exit signs properly illuminated?	Repair or replace exit signage	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	FAIL
				Are the means of egress free of obstructions or impediments?	Remove items blocking means of egress.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Contact a licensed fire extinguisher contractor to install correct extinguishers.	FAIL

Traci Laster Hair Artist Salon - 107 Gordon (West) ST - 7062802562

11/10/2020	Annual	Correction Notice Issued		Are fire extinguishers mounted at the proper height?	Hang fire extinguisher.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have extinguisher serviced by a GA licensed contractor.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/19/2020	Annual	Correction Notice Issued		Are extension cords being used correctly?	Extension cords must not be plugged into power strips.	FAIL
				Are multiplug adapters code compliant and in proper use?	Multi plug adapters must be mounted.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	FAIL
				Are fire extinguishers mounted at the proper height?		FAIL
				Are the fire extinguishers installed in visible locations?		FAIL
				Are the size and distribution of fire extinguishers code compliant?		FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?		FAIL
				Are the required number and type of fire extinguisher installed for the present hazard or condition?		FAIL
				Are the fire extinguishers unobstructed or unobscured from view?		FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Install fire extinguisher as discussed. Extinguisher must be inspected and tagged by a Georgia licensed contractor.	FAIL
				Do the fire extinguishers have the appropriate inspection tag required by law?		FAIL
Are the fire extinguishers code compliant?		FAIL				

Engine 1 B Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/02/2020	Annual	Passed		Is exterior tire storage the proper distance from lot lines and buildings?	Must move from lot lines.	FAIL
11/17/2020	Annual	Correction Notice Issued	Add carbon monoxide detectors.	Does the emergency lighting system work correctly?	Repair or replace emergency lighting.	FAIL
				Are exit signs properly illuminated?		FAIL
				Are there any identifiable electrical hazards?		FAIL
				Is a proper working space provided in front of electrical service equipment?	Must maintain clearance.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box Whittington the next year.	FAIL
				Are the means of egress free of obstructions or impediments?	Move cart from exit passageway.	FAIL
				Are the size and distribution of fire extinguishers code compliant?	Add 4 fire extinguishers from a licensed Georgi contractor.	FAIL
11/17/2020	OTC	Correction Notice Issued	This will serve as the OTC inspection for Smithhonig LLC. Please use the annual inspection performed on 11/17/2020 for Kellie Smith Design as a reference.	Does the emergency lighting system work correctly?	Repair or replace emergency lights.	FAIL
				Are exit signs properly illuminated?	Repair or replace exit signs.	FAIL
				Are there any identifiable electrical hazards?	See annual report for Kellie Smith Design.	FAIL
				Are the means of egress free of obstructions or impediments?	See annual report fo Kellie Smith Designs.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	See annual report for Kellie Smith Designs.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/24/2020	Annual	Correction Notice Issued	Are extension cords being used correctly?	Extension cords shall not be plugged into multi plug adapters. Extension cords shall not be plugged into extension cords. Extension cords shall not substitute permanent wiring. Extension cords shall not pass through walls or ceilings.	FAIL
			Are electrical rooms marked?		FAIL
			Is a proper working space provided in front of electrical service equipment?	Remove storage from in front of electrical panels.	FAIL
			Are multiplug adapters code compliant and in proper use?	Multi plug adapters shall not be plugged into multi plug adapters.	FAIL
			Are wiring splices concealed in a junction box and are open junction boxes covered with an approved junction box cover?	Open splices must be installed in approved junction boxes.	FAIL
			Is address signage correct and in place?	Install address signage.	FAIL
			Has a Knox Box containing the property access keys been installed?	Install Knox Box.	FAIL
			Are exits, or enclosures for stairways and ramps free of combustibles?		FAIL
			Are boiler rooms, mechanical rooms, electrical rooms, and fire command centers free of combustible material storage?		FAIL
			Is the headroom in the means of egress code compliant?	Repair stairwell ceiling.	FAIL
Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguishers as discussed.	FAIL			

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Boyett & Foshee Insurance Agency - 200 S Pentz ST - 7062782415

11/10/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Ensure all exit signage operates as designed.	FAIL
				Does the business have a certificate of occupancy?	Obtain occupational tax certificate from city hall.	FAIL
				Has a Knox Box containing the property access keys been installed?		FAIL
				Are fire extinguishers mounted at the proper height?	Mount fire extinguisher.	FAIL
				Are the size and distribution of fire extinguishers code compliant?	Install fire extinguisher at front entrance.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Fire extinguishers require current annual inspection to be performed by GA licensed contractor.	FAIL

Carpet Capital Association of Realtors - 204 Gordon (West) ST - 706-278-0297

11/12/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Repair or replace exit lighting that does not operate as designed.	FAIL
				Are electrical rooms marked?	Install sign stating ELECTRICAL ROOM or similar approved wording.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Maintain 3 feet clearance in front of electrical panel.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Finn and Hurtt - 215 Gordon (West) ST - 7062265425

11/13/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Electrical outlets should be in hard conduit. Install cover on electrical panel.	FAIL
				Are electrical rooms marked?	Mark electrical panel.	FAIL
				Are multiplug adapters code compliant and in proper use?	Mount multiplug adapters.	FAIL
				Are wiring splices concealed in a junction box and are open junction boxes covered with an approved junction box cover?	Install covers on junction boxes.	FAIL
				Is address signage correct and in place?	Install appropriate address signage.	FAIL
				Are the required number and type of fire extinguisher installed for the present hazard or condition?	Contact licensed fire extinguisher contractor to install appropriate fire extinguishers.	FAIL

Grace Christian Gift and Art gallery - 111 Gordon (West) ST - 7065295683

11/09/2020	Annual	Correction Notice Issued		Are extension cords being used correctly?	Drop cords should not be plugged into other drop cords. And should only be used for temporary power.	FAIL
				Have extension cords been properly maintained?	Remove damaged drop cord.	FAIL
				Are multiplug adapters code compliant and in proper use?	Mount multiplug adapters.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	FAIL
				Are the means of egress free of obstructions or impediments?	Remove items in means of egress path including curtains.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have a GA licensed contractor service the fire extinguishers.	FAIL
				Do the fire extinguishers have the appropriate inspection tag required by law?	A licensed fire extinguisher contractor should properly tag the fire extinguisher.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



HHC Mini Warehouse - 211 Gordon (West) ST - 7062780333						
11/13/2020	Annual	Correction Notice Issued		Are electrical rooms marked?	Mark electrical room.	FAIL
Just Christi - 211 Gordon (West) ST - 7065376277						
11/13/2020	Annual	Correction Notice Issued		Are multiplug adapters code compliant and in proper use?	Secure multiplug adapters off the floor.	FAIL
North Georgia Buisness Machines - 203 Gordon (West) ST - 7062785977						
11/10/2020	Annual	Correction Notice Issued		Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Fire extinguishers require current annual inspection to be completed by a GA licensed contractor.	FAIL
				Do the fire extinguishers have the appropriate inspection tag required by law?		FAIL
Richard K Murray - 200 Gordon (West) ST #Suite A - 706-272-3289						
11/12/2020	Annual	Correction Notice Issued		Is address signage correct and in place?	Install proper address identification.	FAIL
Robo Trading - 211 Gordon (West) ST - 7062788623						
11/13/2020	Annual	Correction Notice Issued		Are multiplug adapters code compliant and in proper use?	Mount multiplug adapters.	FAIL
Rock Bridge Community Church - The Gathering - 100 Gordon (West) ST - 931-797-9906						
11/05/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?		FAIL
				Are electrical rooms marked?		FAIL
				Is address signage correct and in place?		FAIL
				Has a Knox Box containing the property access keys been installed?		FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Rock bridge Community Church - The Stage - 123 Gordon (West) ST - 931-797-9906

11/09/2020	Annual	Correction Notice Issued		Does the breaker controlling the fire alarm have an approved locking device?		FAIL
				Does the circuit controlling the fire alarm have a red marking?		FAIL
				Are electrical rooms marked?		FAIL
				Are rooms containing fire protection equipment properly marked ?		FAIL

Rock Bridge Community Church - The Wink - 115 Crawford (West) ST - 931-797-9906

11/09/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Repair or replace emergency lighting/exit signage that does not operate as designed.	FAIL
				Are electrical rooms marked?	Install sign stating ELECTRICAL ROOM or similar approved wording.	FAIL
				Are wiring splices concealed in a junction box and are open junction boxes covered with an approved junction box cover?	Place approved covers on junction boxes.	FAIL
				Is address signage correct and in place?	Install address signage.	FAIL
				Are rooms containing fire protection equipment properly marked ?	Install RISER ROOM and fire alarm control panel (FACP) signage	FAIL

Rock Bridge Community Church - Woman's Enrichment Center - 109 Gordon (West) ST - 706-279-3175

11/09/2020	Annual	Correction Notice Issued		Are exits, other than main exits properly marked?	Install exit sign over rear exit.	FAIL
------------	--------	--------------------------	--	---	-----------------------------------	------

Rock Bridge Community Church Children's Center - 124 Gordon (West) ST - 706-279-3175

11/09/2020	Annual	Correction Notice Issued		Have all applicable code requirements been met?	Fire doors do not fully close as designed.	FAIL
				Are electrical rooms marked?	Install sign stating ELECTRICAL ROOM or similar approved wording.	FAIL
				Are exits, or enclosures for stairways and ramps free of combustibles?	Remove all storage from stairwells.	FAIL

Engine 1 C Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/03/2020	Annual	Complaint cleared by Contact		Does the business have a certificate of occupancy?	Will have by November 11-09-2020	FAIL
				Are the size and distribution of fire extinguishers code compliant?	Add fire extinguisher.	FAIL
11/03/2020	Annual	Correction Notice Issued	Please email photos of violation corrections to: dstratton @daltonga.gov	Does the emergency lighting system work correctly?		FAIL
				Are there any identifiable electrical hazards?	Open spaces in electrical panel must be covered.	FAIL
				Are electrical rooms marked?	Install electrical room signs.	FAIL
				Is a proper working space provided in front of electrical service equipment?		FAIL
11/03/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Open junction box.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box	FAIL
				Are boiler rooms, mechanical rooms, electrical rooms, and fire command centers free of combustible material storage?	Must have three feet of clearance.	FAIL
				Are fire extinguishers mounted at the proper height?	Not mounted	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Must be inspected once a year.	FAIL
11/05/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add Knox Box.	FAIL
11/09/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add Knox Box.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/23/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add within 1 year.	FAIL
				Are the fire extinguishers code compliant?	Have extinguishers updated and tagged by a licensed Georgia Contractor.	FAIL
11/23/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add within 1 year.	FAIL
				Are the fire extinguishers code compliant?	Have extinguisher updated.	FAIL
11/09/2020	Annual	Correction Notice Issued		Are the size and distribution of fire extinguishers code compliant?	Add extinguisher to rear exit.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Must be inspected annually.	FAIL
11/23/2020	Annual	Correction Notice Issued	Knox Box within a year.	Is a proper working space provided in front of electrical service equipment?	Maintain at least 30 inches of clearance.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box within 1 year.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add fire extinguisher.	FAIL
				Are the fire extinguishers code compliant?	Must be inspected by a licensed inspector.	FAIL
11/30/2020	Annual	Passed with Comments	Add Knox Box within 1 year.	Has a Knox Box containing the property access keys been installed?	Add Knox Box within 1 year.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/05/2020	Annual	Correction Notice Issued		Does the emergency lighting system work correctly?	Repair or replace.	FAIL
				Are exit signs visible?	Repair or replace.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box.	FAIL
				Are the size and distribution of fire extinguishers code compliant?	Need minimum 5lb. extinguisher, inspected by licensed contractor.	FAIL
11/05/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add Knox Box.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Out of date.	FAIL
11/05/2020	Annual	Correction Notice Issued		Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?		FAIL
11/09/2020	Annual	Correction Notice Issued		Are multiplug adapters code compliant and in proper use?	Mount multiplug adapters.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on building.	FAIL
11/05/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Add Knox Box.	FAIL
11/05/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Open spaces in panel.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove rack from in front of electrical panel.	FAIL
				Has a Knox Box containing the property access keys been installed?	Add Knox Box.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Boy Scouts of America - 202 Hamilton (South) ST - 7062727111

11/05/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Install blanks in electrical panel.	FAIL
				Are extension cords being used correctly?	Extension cords should only be used for temporary power.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove combustibles near electrical panels.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box. See attached PDF.	FAIL
				Are fire extinguishers mounted at the proper height?	Hang fire extinguisher.	FAIL

Dalton Gold and Silver Exchange - 108 Hamilton (South) ST - 706-226-3504

11/24/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Install approved cover over empty spaces in electrical panel.	FAIL
				Are electrical rooms marked?	Install electrical room sign.	FAIL
				Has a Knox Box containing the property access keys been installed?		FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Fire extinguishers require current annual inspection, to be performed by a Georgia licensed contractor.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Domino's Pizza - 222 W Cuyler ST - 7062261008

11/17/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Repair electrical wiring. Install blanks in electrical panel.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove combustibles near electrical panels.	FAIL
				Is address signage correct and in place?	Install new address signage.	FAIL
				Has the cooking equipment been inspected and cleaned by a properly trained individual?	Ensure cooking equipment is properly cleaned.	FAIL
				Has the appropriately scheduled inspection of the entire exhaust system for grease buildup been conducted by a Georgia licensed contractor?	Provide documentation of hood cleaning.	FAIL

Salon De Belleza - 218 Hamilton (South) ST - 7062758196

11/05/2020	Annual	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have fire extinguisher serviced.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Vapors Alley - 204 Hamilton (South) ST - 7065298683

11/05/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Install covers on electrical outlets.	FAIL
				Are extension cords being used correctly?	Extension cords should be used for temporary power only, and should be plugged directly into an outlet.	FAIL
				Are multiplug adapters code compliant and in proper use?	Attach multiplugs to the wall.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on building.	FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have fire extinguishers serviced.	FAIL

Engine 5 A Shift

Fashion Cleaners and Apartments - 201 Morris (West) ST - 7062788166

11/19/2020	New Construction	Correction Notice Issued		Has a Knox Box containing the property access keys been installed?	Install Knox Box.	FAIL
				Are normally open valves properly secured?	Sprinkler system control valves must be chained and locked in the OPEN position.	FAIL
				Where the FDC only supplies a portion of the building, is a sign in place to indicate the portion served?	Install FDC sign. FDC must be painted red.	FAIL
11/24/2020	New Construction	Passed		Has a Knox Box containing the property access keys been installed?	Install Knox Box.	FAIL

Engine 5 B Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/20/2020	Site Visit	Passed with Comments		Have all applicable code requirements been met?	Seal penetrations in riser room. Water motor bell not working. Gaps in fire doors need to be corrected. Add additional exit sign as discussed. Move exit signage as discussed. Add door closure in hallway door behind stage. Add Fireline signage. Strobes not working in bathroom on 600 hallway. Horns in bathroom need to be turned down. Fire door shall close properly. Replace paint sprinkler heads.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/30/2020	New Kitchen Hood Installation	Correction Notice Issued	Several issues must be addressed in regards to shunts, makeup air and alarm interface.	Have all applicable code requirements been met?	Add thermo-coupler.	FAIL
				Upon activation of the fire-extinguishing system, do all sources of fuel and electrical power to all heat producing equipment automatically shut off?	Must shunt power.	FAIL
				Does activation of the extinguishing system activate an audible or visual indicator?	Must activate alarm.	FAIL
				Are Class K fire extinguishers provided in cooking areas?	Add 1 Class K extinguisher to pizza oven area.	FAIL
				Does the hood exhaust fan start upon activation of the extinguishing system, and does the cooking equipment served by the fan shut-down?	Cooking equipment must shut dow.	FAIL
				Does make up air shut down upon activation of the extinguishing system?	Makeup air did not shut down.	FAIL
				The exhaust system operates during cooking operation, and if temperature or radiant energy sensors are used to activate the exhaust fan, the fan activates within 15 minutes after the first appliance has been turned on?	Add thermo-coupler.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/30/2020	New Kitchen Hood Installation	Correction Notice Issued	Took care of alarm on site. Makeup air shuts down.	Have all applicable code requirements been met?	Add thermo-coupler.	FAIL
				Upon activation of the fire-extinguishing system, do all sources of fuel and electrical power to all heat producing equipment automatically shut off?	Must shunt power.	FAIL
				Are Class K fire extinguishers provided in cooking areas?	Add 1 Class K extinguisher to pizza oven area.	FAIL
				Does the hood exhaust fan start upon activation of the extinguishing system, and does the cooking equipment served by the fan shut-down?	Cooking equipment must shut dow.	FAIL
				The exhaust system operates during cooking operation, and if temperature or radiant energy sensors are used to activate the exhaust fan, the fan activates within 15 minutes after the first appliance has been turned on?	Add thermo-coupler.	FAIL

Engine 5 C Shift

Foster's Service Center - 107 S Pentz ST - 706-673-7745

11/05/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Repair or replace lighting.	FAIL
				Are extension cords being used correctly?	Extension cords shall not replace permanent wiring.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?		FAIL
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?		FAIL

Ladder 3 A Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Hamilton University/Winkler Building - 1275 Elkwood DR - 706-272-6509

11/17/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Fill blank	FAIL
				Are electrical rooms marked?	Add marking.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Clean out room.	FAIL
11/18/2020	Annual	Passed		Are there any identifiable electrical hazards?	Fill blank	FAIL
				Are electrical rooms marked?	Add marking.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Clean out room.	FAIL

Ladder 3 C Shift

McDonald, Thames, and Ray - 201 Selvidge St. (South) - 7062788668

11/17/2020	Annual	Correction Notice Issued		Are electrical rooms marked?	Mark electrical panel location.	FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove combustibles near electrical panels.	FAIL
				Are multiplug adapters code compliant and in proper use?	Mount multiplug adapters.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Contact a GA licensed fire contractor for proper fire extinguishers.	FAIL

Squad 1 A Shift

Tracy's Transmissions Plus - 212 W Cuyler ST - 7062700300

11/17/2020	Annual	Correction Notice Issued		Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have fire extinguisher serviced.	FAIL
------------	--------	--------------------------	--	---	----------------------------------	------

Squad 1 B Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



11/13/2020	Annual	Complaint cleared by Contact		Does the business have a certificate of occupancy?	Acquire OTC from city hall.	FAIL
11/06/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Electrical wiring must be installed in conduit or properly covered.	FAIL
				Are electrical rooms marked?	Install Sign on electrical room.	FAIL
				Are wiring splices concealed in a junction box and are open junction boxes covered with an approved junction box cover?		FAIL
				Has a Knox Box containing the property access keys been installed?		FAIL
Shear Performance - 203 Crawford (West) ST - 706-226-1712						
11/11/2020	Annual	Correction Notice Issued		Are there any identifiable electrical hazards?	Install blanks in open spaces in electrical panel.	FAIL
				Are multiplug adapters code compliant and in proper use?	Supply cord for multi plug adapters or drop cords, shall not pass through walls. Multi plug adapters must be mounted according to manufacturer's recommended specifications.	FAIL
				Are wiring splices concealed in a junction box and are open junction boxes covered with an approved junction box cover?	Install approved cover on open junction box.	FAIL
Squad 1 C Shift						
Jack's Pawn Shop - 214 Hamilton (South) ST - 7062266432						
11/05/2020	Annual	Passed with Comments		Has a Knox Box containing the property access keys been installed?	Install Knox Box on building.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Dalton Fire Department

Dalton, GA

This report was generated on 12/2/2020 4:11:27 PM



StartDate: 11/01/2020 | EndDate: 11/30/2020

OCCUPANCY	COUNT
INSPECTION TYPE: Alcohol	
A • Assembly, (other)	1
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	1
M • Retail or wholesale stores	1
INSPECTION TYPE: Annual	
A-2 • Bars, taverns, or nightclubs	1
A-2 • Eating, drinking places, (other)	2
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	2
A-3 • Places of religious worship	3
B • Banks	1
B • Business office	19
B • Business, (other)	1
B • Food processing establishments and commercial kitchens not associated with restaurants, cafeterias and similar dining facilities not more than 2,500 square feet in area.	1
B • Motor vehicle or boat sales, services, repair	4
B • Personal service, including barber & beauty shops	12
B • Print shops	1
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	8
B • Professional supplies, services	3
B • Specialty shop	1
M • General retail, (other)	6
M • Household goods, sales, repairs	2
M • Recreational, hobby, home repair sales, pet store	3
M • Retail or wholesale stores	1
M • Textile, wearing apparel sales	1
S-1 • Furniture	2
S-1 • Motor vehicle repair garages	1
S-1 • Warehouse	2
INSPECTION TYPE: Annual Apartment	
R-2 • Multifamily dwelling	1
INSPECTION TYPE: New Construction	
R-2 • Apartment houses	2
INSPECTION TYPE: New Kitchen Hood Installation	
E • High school/junior high school/middle school	2
INSPECTION TYPE: OTC	
A • Assembly, (other)	1

Locked inspections only.



OCCUPANCY	COUNT
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	3
B • Business office	4
B • Business, (other)	1
M • General retail, (other)	2
INSPECTION TYPE: Plan Review	
B • Motor vehicle or boat sales, services, repair	1
B • Motor vehicle showrooms	1
I-2 • Hospitals	2
M • Retail or wholesale stores	2
R-2 • Apartment houses	1
U • Mixed use	1
INSPECTION TYPE: Reinspection	
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	1
INSPECTION TYPE: Site Visit	
A • Assembly, (other)	1
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	1
B • Educational occupancies for students above the 12th grade (college)	3
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	1
E • High school/junior high school/middle school	2
F-1 • Carpets and rugs (includes cleaning)	1
I-2 • Hospitals	1
M • Convenience stores	1
M: Mercantile (other)	1
R-2 • Apartment houses	1

Locked inspections only.

