

# DALTON FIRE DEPARTMENT

TODD PANGLE  
Fire Chief  
Telephone 706-278-7363  
Fax 706-272-7107  
tpangle@cityofdalton-ga.gov

404 School Street  
Dalton, GA 30720



PUBLIC SAFETY COMMISSION  
Bill Weaver  
Keith Whitworth  
Terry Mathis  
Kenneth E. Willis  
Anthony Walker

## City of Dalton Fire Department Monthly Response Synopsis February 2019

<u>Category</u>	<u>Responses</u>	<u>Percentage</u>
Fire	6	2.05%
Overpressure, Explosion, Overheat	2	0.68%
Rescue/Medical	205	70.20%
Hazardous Condition	11	3.76%
Service Call	3	1.02%
Good Intent	39	13.35%
False Alarm	26	8.90%
<b>Total Responses</b>	<b>292</b>	
<b>Average Response Time</b>	<b>3:28</b>	
<b>Estimated Loss</b>	<b>\$24,300.00</b>	

## DALTON

## Incident Type Report (Monthly Summary )

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
<b>1 Fire</b>				
111 Building fire	1	0.34%	\$14,000	57.61%
113 Cooking fire, confined to container	1	0.34%	\$0	0.00%
132 Road freight or transport vehicle fire	2	0.68%	\$10,000	41.15%
143 Grass fire	1	0.34%	\$0	0.00%
151 Outside rubbish, trash or waste fire	1	0.34%	\$300	1.23%
	<b>6</b>	<b>2.05%</b>	<b>\$24,300</b>	<b>100.00%</b>
<b>2 Overpressure Rupture, Explosion, Overheat(no fire)</b>				
251 Excessive heat, scorch burns with no	2	0.68%	\$0	0.00%
	<b>2</b>	<b>0.68%</b>	<b>\$0</b>	<b>0.00%</b>
<b>3 Rescue &amp; Emergency Medical Service Incident</b>				
311 Medical assist, assist EMS crew	180	61.64%	\$0	0.00%
322 Motor vehicle accident with injuries	13	4.45%	\$0	0.00%
323 Motor vehicle/pedestrian accident (MV Ped)	2	0.68%	\$0	0.00%
324 Motor Vehicle Accident with no injuries	8	2.73%	\$0	0.00%
331 Lock-in (if lock out , use 511 )	1	0.34%	\$0	0.00%
353 Removal of victim(s) from stalled elevator	1	0.34%	\$0	0.00%
	<b>205</b>	<b>70.20%</b>	<b>\$0</b>	<b>0.00%</b>
<b>4 Hazardous Condition (No Fire)</b>				
411 Gasoline or other flammable liquid spill	1	0.34%	\$0	0.00%
412 Gas leak (natural gas or LPG)	1	0.34%	\$0	0.00%
424 Carbon monoxide incident	2	0.68%	\$0	0.00%
440 Electrical wiring/equipment problem, Other	1	0.34%	\$0	0.00%
441 Heat from short circuit (wiring),	1	0.34%	\$0	0.00%
444 Power line down	1	0.34%	\$0	0.00%
445 Arcing, shorted electrical equipment	1	0.34%	\$0	0.00%
461 Building or structure weakened or collapsed	1	0.34%	\$0	0.00%
463 Vehicle accident, general cleanup	2	0.68%	\$0	0.00%
	<b>11</b>	<b>3.76%</b>	<b>\$0</b>	<b>0.00%</b>
<b>5 Service Call</b>				
542 Animal rescue	1	0.34%	\$0	0.00%
553 Public service	1	0.34%	\$0	0.00%
561 Unauthorized burning	1	0.34%	\$0	0.00%

DALTON

Incident Type Report (Monthly Summary )

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
5 Service Call	3	1.02%	\$0	0.00%
6 Good Intent Call				
611 Dispatched & cancelled en route	28	9.58%	\$0	0.00%
622 No Incident found on arrival at dispatch	6	2.05%	\$0	0.00%
651 Smoke scare, odor of smoke	3	1.02%	\$0	0.00%
653 Smoke from barbecue, tar kettle	1	0.34%	\$0	0.00%
671 HazMat release investigation w/no HazMat	1	0.34%	\$0	0.00%
	<b>39</b>	<b>13.35%</b>	<b>\$0</b>	<b>0.00%</b>
7 False Alarm & False Call				
715 Local alarm system, malicious false alarm	1	0.34%	\$0	0.00%
733 Smoke detector activation due to	2	0.68%	\$0	0.00%
735 Alarm system sounded due to malfunction	3	1.02%	\$0	0.00%
736 CO detector activation due to malfunction	1	0.34%	\$0	0.00%
743 Smoke detector activation, no fire -	10	3.42%	\$0	0.00%
744 Detector activation, no fire -	3	1.02%	\$0	0.00%
745 Alarm system activation, no fire -	6	2.05%	\$0	0.00%
	<b>26</b>	<b>8.90%</b>	<b>\$0</b>	<b>0.00%</b>

Total Incident Count: 292

Total Est Loss:

\$24,300

DALTON

Dollar Value Saved & Loss Analysis (Monthly)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident Type	Count	Total Values	Total Losses	Total Saved	Percent Lost	Percent Saved
111 Building fire	1	\$260,000	\$14,000	\$246,000	5.38%	94.62%
132 Road freight or	1	\$10,000	\$10,000	\$0	100.00%	0.00%
151 Outside rubbish, trash	1	\$0	\$300	\$-300	0.00%	0.00%
<b>Grand Totals</b>	<b>3</b>	<b>\$270,000</b>	<b>\$24,300</b>	<b>\$245,700</b>		

Total Percent Lost: 9.00 %

Total Percent Saved: 91.00 %

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000291	0	02/01/2019	06:47:04	Walnut (East)	322 Motor vehicle accident with	
19-0000292	0	02/01/2019	11:39:08	Gordon (East)	311 Medical assist, assist EMS crew	
19-0000293	0	02/01/2019	12:13:31	1302 Underwood	311 Medical assist, assist EMS crew	
19-0000294	0	02/01/2019	12:20:27	1001 Chattanooga	611 Dispatched & cancelled en route	
19-0000295	0	02/01/2019	14:37:22	612 Stone	311 Medical assist, assist EMS crew	
19-0000296	0	02/01/2019	14:45:37	1105 Brookwood	311 Medical assist, assist EMS crew	
19-0000297	0	02/01/2019	22:51:47	1242 Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000298	0	02/01/2019	23:56:09	North Bypass	324 Motor Vehicle Accident with no	
19-0000299	0	02/02/2019	00:26:16	1305 Walnut (West)	611 Dispatched & cancelled en route	
19-0000300	0	02/02/2019	07:39:45	601 Woodland (West)	611 Dispatched & cancelled en route	
19-0000301	0	02/02/2019	09:52:53	2220 Chattanooga	311 Medical assist, assist EMS crew	
19-0000302	0	02/02/2019	13:39:10	1609 Rio Vista	311 Medical assist, assist EMS crew	
19-0000303	0	02/02/2019	15:16:38	1312 Winton	311 Medical assist, assist EMS crew	
19-0000304	0	02/02/2019	15:56:05	Henderson (South)	143 Grass fire	
19-0000305	0	02/02/2019	17:42:06	519 Hawthorne (West)	743 Smoke detector activation, no fire	
19-0000306	0	02/02/2019	20:33:46	1225 Stacy	311 Medical assist, assist EMS crew	
19-0000307	0	02/02/2019	21:13:12	1600 Reinhardt	651 Smoke scare, odor of smoke	
19-0000308	0	02/03/2019	00:21:11	424 Underwood	311 Medical assist, assist EMS crew	
19-0000309	0	02/03/2019	00:55:03	Riverbend	622 No Incident found on arrival at	
19-0000310	0	02/03/2019	03:09:06	Morris (East)	322 Motor vehicle accident with	
19-0000311	0	02/03/2019	08:50:57	606 Maney	311 Medical assist, assist EMS crew	
19-0000312	0	02/03/2019	09:03:39	2220 Chattanooga	311 Medical assist, assist EMS crew	
19-0000313	0	02/03/2019	09:18:18	820 Vernon	311 Medical assist, assist EMS crew	
19-0000314	0	02/03/2019	14:06:53	1695 Willow Oak	440 Electrical wiring/equipment	
19-0000315	0	02/03/2019	15:04:53	Vernon	311 Medical assist, assist EMS crew	
19-0000316	0	02/03/2019	15:57:15	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0000317	0	02/03/2019	16:17:52	716 Juniper	311 Medical assist, assist EMS crew	
19-0000318	0	02/03/2019	18:08:26	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0000319	0	02/03/2019	18:38:44	1218 Broadrick	311 Medical assist, assist EMS crew	
19-0000320	0	02/03/2019	21:43:06	1212 Broadrick	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000321	0	02/04/2019	07:00:26	Chattanooga	611 Dispatched & cancelled en route	
19-0000322	0	02/04/2019	08:13:31	803 Jamestown	311 Medical assist, assist EMS crew	
19-0000323	0	02/04/2019	08:53:11	818 J & J	311 Medical assist, assist EMS crew	
19-0000324	0	02/04/2019	09:57:45	105 Thornton (North)	311 Medical assist, assist EMS crew	
19-0000325	0	02/04/2019	13:01:56	109 Long (East)	542 Animal rescue	
19-0000326	0	02/04/2019	13:09:43	1502 Coronet	743 Smoke detector activation, no fire	
19-0000327	0	02/04/2019	14:01:08	1907 Chattanooga	622 No Incident found on arrival at	
19-0000328	0	02/04/2019	15:19:39	1912 Chattanooga	622 No Incident found on arrival at	
19-0000329	0	02/04/2019	17:52:53	815 Shugart	311 Medical assist, assist EMS crew	
19-0000330	0	02/04/2019	19:59:14	708 Morris (East)	311 Medical assist, assist EMS crew	
19-0000331	0	02/05/2019	02:42:46	900 Shugart	611 Dispatched & cancelled en route	
19-0000332	0	02/05/2019	07:27:51	1218 Broadrick	611 Dispatched & cancelled en route	
19-0000333	0	02/05/2019	09:03:40	1549 Shady	311 Medical assist, assist EMS crew	
19-0000334	0	02/05/2019	11:05:04	1405 Vann	311 Medical assist, assist EMS crew	
19-0000335	0	02/05/2019	11:21:45	1933 Shields	311 Medical assist, assist EMS crew	
19-0000336	0	02/05/2019	13:37:15	1218 Broadrick	311 Medical assist, assist EMS crew	
19-0000337	0	02/05/2019	18:22:39	916 Vernon	311 Medical assist, assist EMS crew	
19-0000338	0	02/05/2019	19:15:18	803 Red Clay	311 Medical assist, assist EMS crew	
19-0000339	0	02/05/2019	21:51:42	609 Black Oak	311 Medical assist, assist EMS crew	
19-0000340	0	02/05/2019	22:35:37	1024 Abutment	311 Medical assist, assist EMS crew	
19-0000341	0	02/06/2019	01:46:39	306 Hightower	311 Medical assist, assist EMS crew	
19-0000342	0	02/06/2019	02:24:08	809 Chattanooga	311 Medical assist, assist EMS crew	
19-0000343	0	02/06/2019	06:21:00	700 Phoenix	311 Medical assist, assist EMS crew	
19-0000344	0	02/06/2019	07:25:10	905 Hamilton (South)	311 Medical assist, assist EMS crew	
19-0000345	0	02/06/2019	08:01:36	V.D.Parrott	463 Vehicle accident, general cleanup	
19-0000346	0	02/06/2019	14:30:23	1110 Burleyson	311 Medical assist, assist EMS crew	
19-0000347	0	02/06/2019	14:33:38	1021 Riverburch	311 Medical assist, assist EMS crew	
19-0000348	0	02/06/2019	16:10:34	1802 Brookland	743 Smoke detector activation, no fire	
19-0000349	0	02/06/2019	16:57:49	650 George Rice	424 Carbon monoxide incident	
19-0000350	0	02/06/2019	17:38:30	813 Battlefield Pk	611 Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000351	0	02/06/2019	20:34:23	376	Alex	311 Medical assist, assist EMS crew	
19-0000352	0	02/06/2019	22:40:22	800	Red Clay	311 Medical assist, assist EMS crew	
19-0000353	0	02/07/2019	08:07:02	1320	Winton	743 Smoke detector activation, no fire	
19-0000354	0	02/07/2019	08:20:55	950	Riverbend	311 Medical assist, assist EMS crew	
19-0000355	0	02/07/2019	10:45:14	1308	Walnut (West)	745 Alarm system activation, no fire -	
19-0000356	0	02/07/2019	11:07:14	1369	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000357	0	02/07/2019	11:23:41	606	Macon	311 Medical assist, assist EMS crew	
19-0000358	0	02/07/2019	12:41:46	2220	Chattanooga	311 Medical assist, assist EMS crew	
19-0000359	0	02/07/2019	13:26:43	432	Fourth	311 Medical assist, assist EMS crew	
19-0000360	0	02/07/2019	15:01:48		Walnut (East)	322 Motor vehicle accident with	
19-0000361	0	02/07/2019	16:14:03	2220	Chattanooga	611 Dispatched & cancelled en route	
19-0000362	0	02/07/2019	16:23:08	2315	Sir Lancelot	461 Building or structure weakened or	
19-0000363	0	02/07/2019	17:22:38	1202	Glenwood (North)	323 Motor vehicle/pedestrian accident	
19-0000364	0	02/07/2019	17:25:09	741	McGhee	111 Building fire	\$14,000
19-0000365	0	02/07/2019	18:42:11	301	Glenwood (North)	322 Motor vehicle accident with	
19-0000366	0	02/07/2019	21:22:23	100	Industrial (West)	611 Dispatched & cancelled en route	
19-0000367	0	02/07/2019	22:59:27	308	Sycamore	611 Dispatched & cancelled en route	
19-0000368	0	02/07/2019	23:23:20	1907	Chattanooga	311 Medical assist, assist EMS crew	
19-0000369	0	02/08/2019	05:10:44	703	Morningside	311 Medical assist, assist EMS crew	
19-0000370	0	02/08/2019	07:25:17	2220	Chattanooga	311 Medical assist, assist EMS crew	
19-0000371	0	02/08/2019	12:06:32	1808	Dug Gap	611 Dispatched & cancelled en route	
19-0000372	0	02/08/2019	12:47:24	1320	Winton	745 Alarm system activation, no fire -	
19-0000373	0	02/08/2019	13:11:53	711	Hamilton (South)	622 No Incident found on arrival at	
19-0000374	0	02/08/2019	15:40:56	1218	Broadrick	311 Medical assist, assist EMS crew	
19-0000375	0	02/08/2019	17:15:39	2139	Chatham	311 Medical assist, assist EMS crew	
19-0000376	0	02/08/2019	18:52:23	1320	Winton	743 Smoke detector activation, no fire	
19-0000377	0	02/08/2019	20:44:20	907	Liddell	311 Medical assist, assist EMS crew	
19-0000378	0	02/08/2019	22:59:33	502	Lester	311 Medical assist, assist EMS crew	
19-0000379	0	02/09/2019	01:24:54	1300	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000380	0	02/09/2019	05:29:55	408	Sixth	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000381	0	02/09/2019	10:03:44	1805 Ryman's Ridge	611 Dispatched & cancelled en route	
19-0000382	0	02/09/2019	10:15:17	2204 Seminole	311 Medical assist, assist EMS crew	
19-0000383	0	02/09/2019	12:03:14	2125 Arbordale	113 Cooking fire, confined to	
19-0000384	0	02/09/2019	13:16:52	1502 Coronet	744 Detector activation, no fire -	
19-0000385	0	02/09/2019	13:29:45	1275 Cross Plains	311 Medical assist, assist EMS crew	
19-0000386	0	02/09/2019	16:07:27	815 Shugart	311 Medical assist, assist EMS crew	
19-0000387	0	02/09/2019	20:26:40	811 Walnut Square	311 Medical assist, assist EMS crew	
19-0000388	0	02/09/2019	22:13:14	1116 Willowdale	311 Medical assist, assist EMS crew	
19-0000389	0	02/09/2019	22:19:15	1212 Broadrick	611 Dispatched & cancelled en route	
19-0000390	0	02/10/2019	00:14:57	1002 Wimbleton	311 Medical assist, assist EMS crew	
19-0000391	0	02/10/2019	01:17:32	1211 Applewood	611 Dispatched & cancelled en route	
19-0000392	0	02/10/2019	02:35:42	507 McAfee	311 Medical assist, assist EMS crew	
19-0000393	0	02/10/2019	08:49:31	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0000394	0	02/10/2019	09:45:41	311 Thornton (North)	311 Medical assist, assist EMS crew	
19-0000395	0	02/10/2019	13:47:19	Chattanooga	324 Motor Vehicle Accident with no	
19-0000396	0	02/10/2019	14:18:05	Chattanooga	311 Medical assist, assist EMS crew	
19-0000397	0	02/10/2019	15:40:35	Waugh (East)	311 Medical assist, assist EMS crew	
19-0000398	0	02/10/2019	15:59:50	317 Tibbs (North)	653 Smoke from barbecue, tar kettle	
19-0000399	0	02/10/2019	16:17:47	300 Fairview	561 Unauthorized burning	
19-0000400	0	02/10/2019	21:05:01	805 Professional	311 Medical assist, assist EMS crew	
19-0000401	0	02/10/2019	21:07:34	788 Bermuda	311 Medical assist, assist EMS crew	
19-0000402	0	02/11/2019	00:09:15	623 Campus	353 Removal of victim(s) from stalled	
19-0000403	0	02/11/2019	07:22:11	2080 Chattanooga	311 Medical assist, assist EMS crew	
19-0000404	0	02/11/2019	11:06:21	I-75 S. Bound	611 Dispatched & cancelled en route	
19-0000405	0	02/11/2019	16:15:06	629 Fireside	311 Medical assist, assist EMS crew	
19-0000406	0	02/11/2019	19:17:23	1232 Thornton (North)	311 Medical assist, assist EMS crew	
19-0000407	0	02/11/2019	22:40:57	506 Anderson	311 Medical assist, assist EMS crew	
19-0000408	0	02/12/2019	07:27:02	1212 Broadrick	311 Medical assist, assist EMS crew	
19-0000409	0	02/12/2019	08:21:47	1602 Southmont	733 Smoke detector activation due to	
19-0000411	0	02/12/2019	09:16:32	211 Fields	311 Medical assist, assist EMS crew	



DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000412	0	02/12/2019	09:59:59	402 Sequoyah	311 Medical assist, assist EMS crew	
19-0000413	0	02/12/2019	13:55:45	Thornton (North)	311 Medical assist, assist EMS crew	
19-0000414	0	02/12/2019	14:31:45	I-75 N. Bound	611 Dispatched & cancelled en route	
19-0000415	0	02/12/2019	14:35:19	939 Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000416	0	02/12/2019	16:51:45	1142 Thornton (North)	311 Medical assist, assist EMS crew	
19-0000417	0	02/12/2019	22:53:50	204 Industrial (West)	735 Alarm system sounded due to	
19-0000418	0	02/13/2019	03:36:19	814 Tyler (West)	311 Medical assist, assist EMS crew	
19-0000419	0	02/13/2019	04:27:14	1107 Hair	311 Medical assist, assist EMS crew	
19-0000420	0	02/13/2019	09:14:10	1108 Rio Vista	311 Medical assist, assist EMS crew	
19-0000421	0	02/13/2019	11:18:47	826 Beirut	311 Medical assist, assist EMS crew	
19-0000422	0	02/13/2019	11:39:34	405 School	745 Alarm system activation, no fire -	
19-0000423	0	02/13/2019	11:58:33	711 Hamilton (South)	311 Medical assist, assist EMS crew	
19-0000424	0	02/13/2019	11:59:33	1107 Memorial	311 Medical assist, assist EMS crew	
19-0000425	0	02/13/2019	12:37:52	2214 Walnut (East)	311 Medical assist, assist EMS crew	
19-0000426	0	02/13/2019	13:53:32	1301 Walnut (West)	311 Medical assist, assist EMS crew	
19-0000427	0	02/13/2019	16:58:34	1119 Hill	311 Medical assist, assist EMS crew	
19-0000428	0	02/13/2019	18:22:45	2217 Raintree	331 Lock-in (if lock out , use 511 )	
19-0000429	0	02/14/2019	06:12:30	613 Oxford	311 Medical assist, assist EMS crew	
19-0000430	0	02/14/2019	11:24:15	515 Pentz (South)	311 Medical assist, assist EMS crew	
19-0000431	0	02/14/2019	11:50:52	1001 Thornton (South)	311 Medical assist, assist EMS crew	
19-0000432	0	02/14/2019	15:06:39	2680 Abutment	611 Dispatched & cancelled en route	
19-0000433	0	02/14/2019	19:39:16	MLK Jr.	324 Motor Vehicle Accident with no	
19-0000434	0	02/14/2019	21:32:22	907 Liddell	311 Medical assist, assist EMS crew	
19-0000435	0	02/15/2019	09:52:13	107 Spencer (South)	311 Medical assist, assist EMS crew	
19-0000436	0	02/15/2019	11:41:31	Abutment	324 Motor Vehicle Accident with no	
19-0000437	0	02/15/2019	13:31:38	1918 Richland	611 Dispatched & cancelled en route	
19-0000438	0	02/15/2019	14:08:40	505 Shugart	671 HazMat release investigation w/no	
19-0000439	0	02/15/2019	19:03:54	Underwood	322 Motor vehicle accident with	
19-0000440	0	02/15/2019	20:53:10	1394 Dug Gap	311 Medical assist, assist EMS crew	
19-0000441	0	02/15/2019	22:46:23	906 Sierra	311 Medical assist, assist EMS crew	

## DALTON

## Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time		Location	Incident Type	Est Loss
19-0000442	0	02/15/2019	23:29:29	600	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000443	0	02/15/2019	23:40:54		Cleveland	323 Motor vehicle/pedestrian accident	
19-0000444	0	02/16/2019	06:08:21	MM	I-75 N. Bound	463 Vehicle accident, general cleanup	
19-0000445	0	02/16/2019	12:46:04	1349	Walnut (West)	311 Medical assist, assist EMS crew	
19-0000446	0	02/16/2019	17:33:00	712	Skylark	311 Medical assist, assist EMS crew	
19-0000447	0	02/16/2019	19:33:29	606	Clark	311 Medical assist, assist EMS crew	
19-0000448	0	02/16/2019	20:55:57	1807	Shadow	311 Medical assist, assist EMS crew	
19-0000449	0	02/16/2019	23:22:26	1309	Morris (East)	311 Medical assist, assist EMS crew	
19-0000450	0	02/17/2019	00:14:34	1210	Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000451	0	02/17/2019	00:37:54	1810	Bridgewater	311 Medical assist, assist EMS crew	
19-0000452	0	02/17/2019	01:22:26		North Bypass	322 Motor vehicle accident with	
19-0000453	0	02/17/2019	06:26:21	1300	Waugh (West)	311 Medical assist, assist EMS crew	
19-0000454	0	02/17/2019	09:29:17	518	Parkside	311 Medical assist, assist EMS crew	
19-0000455	0	02/17/2019	15:14:48	612	Stone	311 Medical assist, assist EMS crew	
19-0000456	0	02/17/2019	18:03:58	702	Courtland	651 Smoke scare, odor of smoke	
19-0000457	0	02/17/2019	18:41:27		I-75 S. Bound	311 Medical assist, assist EMS crew	
19-0000458	0	02/17/2019	19:01:42		I-75 N. Bound	611 Dispatched & cancelled en route	
19-0000459	0	02/17/2019	19:29:21	609	Thornton (South)	311 Medical assist, assist EMS crew	
19-0000460	0	02/17/2019	23:21:09	1511	Walnut (West)	411 Gasoline or other flammable liquid	
19-0000461	0	02/18/2019	07:13:17	712	Corey	311 Medical assist, assist EMS crew	
19-0000462	0	02/18/2019	08:52:21	508	Morris (East)	311 Medical assist, assist EMS crew	
19-0000463	0	02/18/2019	12:14:29	624	Fifth	311 Medical assist, assist EMS crew	
19-0000464	0	02/18/2019	14:55:57	129	Ella	324 Motor Vehicle Accident with no	
19-0000465	0	02/18/2019	14:58:51	1224	Riverbend	424 Carbon monoxide incident	
19-0000466	0	02/18/2019	16:37:11	1102	James	444 Power line down	
19-0000467	0	02/18/2019	18:25:12	1411	Sienna	311 Medical assist, assist EMS crew	
19-0000468	0	02/18/2019	19:30:00	2120	Holly	311 Medical assist, assist EMS crew	
19-0000469	0	02/18/2019	20:47:43	302	Red Cross	611 Dispatched & cancelled en route	
19-0000470	0	02/18/2019	21:55:03	713	Morris (East)	311 Medical assist, assist EMS crew	
19-0000471	0	02/19/2019	02:07:48	1104	Walston	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000472	0	02/19/2019	08:39:36	1107 Hair	311 Medical assist, assist EMS crew	
19-0000473	0	02/19/2019	10:37:46	2738 Underwood	744 Detector activation, no fire -	
19-0000474	0	02/19/2019	12:55:04	1012 Ponderosa	311 Medical assist, assist EMS crew	
19-0000475	0	02/19/2019	13:36:04	317 Matilda (East)	311 Medical assist, assist EMS crew	
19-0000476	0	02/19/2019	14:30:11	1104 Hair	441 Heat from short circuit (wiring),	
19-0000477	0	02/19/2019	15:24:07	Abutment	322 Motor vehicle accident with	
19-0000478	0	02/19/2019	16:09:54	307 Bowen	553 Public service	
19-0000479	0	02/19/2019	21:25:17	Abutment	622 No Incident found on arrival at	
19-0000480	0	02/20/2019	02:31:29	1116 Willowdale	311 Medical assist, assist EMS crew	
19-0000481	0	02/20/2019	07:44:38	1275 Elkwood	745 Alarm system activation, no fire -	
19-0000482	0	02/20/2019	09:27:58	505 Woodland (East)	311 Medical assist, assist EMS crew	
19-0000483	0	02/20/2019	10:33:24	418 Chattanooga	311 Medical assist, assist EMS crew	
19-0000484	0	02/20/2019	12:37:07	722 Skylark	311 Medical assist, assist EMS crew	
19-0000485	0	02/20/2019	12:47:41	708 Morris (East)	311 Medical assist, assist EMS crew	
19-0000486	0	02/20/2019	14:53:33	818 J & J	735 Alarm system sounded due to	
19-0000487	0	02/20/2019	15:37:21	310 Brookhollow Ind.	412 Gas leak (natural gas or LPG)	
19-0000488	0	02/20/2019	16:14:19	1500 Manly	743 Smoke detector activation, no fire	
19-0000489	0	02/20/2019	17:46:39	Frazier	324 Motor Vehicle Accident with no	
19-0000490	0	02/20/2019	21:15:31	1300 Waugh (West)	735 Alarm system sounded due to	
19-0000491	0	02/21/2019	06:19:47	1401 Vann	311 Medical assist, assist EMS crew	
19-0000492	0	02/21/2019	08:10:30	98 Walnut (West)	311 Medical assist, assist EMS crew	
19-0000493	0	02/21/2019	08:44:53	1306 Underwood	311 Medical assist, assist EMS crew	
19-0000494	0	02/21/2019	08:48:07	1906 Meadowbrook	311 Medical assist, assist EMS crew	
19-0000495	0	02/21/2019	09:13:38	1218 McDaniel	311 Medical assist, assist EMS crew	
19-0000496	0	02/21/2019	10:04:26	1700 Beechland	311 Medical assist, assist EMS crew	
19-0000497	0	02/21/2019	10:35:32	Walnut (West)	622 No Incident found on arrival at	
19-0000498	0	02/21/2019	10:40:35	North Park	311 Medical assist, assist EMS crew	
19-0000499	0	02/21/2019	11:07:09	800 Professional	611 Dispatched & cancelled en route	
19-0000500	0	02/21/2019	12:20:29	413 Glenwood (South)	445 Arcing, shorted electrical	
19-0000501	0	02/21/2019	12:25:35	501 Central	743 Smoke detector activation, no fire	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000502	0	02/21/2019	15:51:35	1300 Waugh (East)	311 Medical assist, assist EMS crew	
19-0000503	0	02/21/2019	17:22:07	710 North View	311 Medical assist, assist EMS crew	
19-0000504	0	02/21/2019	17:29:56	703 Burchfield	311 Medical assist, assist EMS crew	
19-0000505	0	02/21/2019	18:32:51	200 Industrial (West)	311 Medical assist, assist EMS crew	
19-0000506	0	02/21/2019	22:08:58	420 Benton	311 Medical assist, assist EMS crew	
19-0000507	0	02/22/2019	08:09:09	205 Selvidge St. (North)	311 Medical assist, assist EMS crew	
19-0000508	0	02/22/2019	08:25:44	2305 Ravine	743 Smoke detector activation, no fire	
19-0000509	0	02/22/2019	08:56:30	311 Grade (South)	311 Medical assist, assist EMS crew	
19-0000510	0	02/22/2019	09:21:31	1015 Lakeshore (East)	311 Medical assist, assist EMS crew	
19-0000511	0	02/22/2019	10:04:18	Chattanooga	322 Motor vehicle accident with	
19-0000512	0	02/22/2019	12:15:30	North Bypass	322 Motor vehicle accident with	
19-0000513	0	02/22/2019	13:25:34	705 Lumpkin	311 Medical assist, assist EMS crew	
19-0000514	0	02/22/2019	15:41:41	2440 Mountain Road	311 Medical assist, assist EMS crew	
19-0000515	0	02/22/2019	17:43:00	1211 Maple	736 CO detector activation due to	
19-0000516	0	02/22/2019	17:52:27	1320 Winton	251 Excessive heat, scorch burns with	
19-0000517	0	02/22/2019	18:19:11	1801 Beechland	311 Medical assist, assist EMS crew	
19-0000518	0	02/23/2019	02:51:09	Abutment	311 Medical assist, assist EMS crew	
19-0000519	0	02/23/2019	05:05:26	919 Hamilton (South)	311 Medical assist, assist EMS crew	
19-0000520	0	02/23/2019	07:57:46	1200 Lakeshore (West)	311 Medical assist, assist EMS crew	
19-0000521	0	02/23/2019	08:22:32	100 Hamilton (North)	745 Alarm system activation, no fire -	
19-0000522	0	02/23/2019	09:24:34	1218 Broadrick	311 Medical assist, assist EMS crew	
19-0000523	0	02/23/2019	11:17:41	1013 Trammell	151 Outside rubbish, trash or waste	\$300
19-0000524	0	02/23/2019	11:20:05	519 Hawthorne (West)	311 Medical assist, assist EMS crew	
19-0000525	0	02/23/2019	12:20:11	1302 Underwood	311 Medical assist, assist EMS crew	
19-0000526	0	02/23/2019	16:21:20	301 Waugh (West)	311 Medical assist, assist EMS crew	
19-0000527	0	02/23/2019	18:23:11	Walnut (West)	322 Motor vehicle accident with	
19-0000528	0	02/23/2019	19:52:30	1803 Ryman's Ridge	311 Medical assist, assist EMS crew	
19-0000529	0	02/23/2019	22:25:29	611 Sheridan	311 Medical assist, assist EMS crew	
19-0000530	0	02/23/2019	22:32:29	2220 Chattanooga	311 Medical assist, assist EMS crew	
19-0000531	0	02/23/2019	22:41:06	519 Hawthorne (West)	743 Smoke detector activation, no fire	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000532	0	02/24/2019	01:06:11	627 Strain	311 Medical assist, assist EMS crew	
19-0000533	0	02/24/2019	02:01:46	818 Shugart	311 Medical assist, assist EMS crew	
19-0000534	0	02/24/2019	06:08:41	907 Liddell	311 Medical assist, assist EMS crew	
19-0000535	0	02/24/2019	06:40:30	358 Castle	311 Medical assist, assist EMS crew	
19-0000536	0	02/24/2019	10:01:24	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0000537	0	02/24/2019	12:17:20	219 Fredrick (North)	311 Medical assist, assist EMS crew	
19-0000538	0	02/24/2019	16:54:32	816 Walnut Square	745 Alarm system activation, no fire -	
19-0000539	0	02/24/2019	17:15:32	1108 Walston	311 Medical assist, assist EMS crew	
19-0000540	0	02/24/2019	17:58:59	2211 Dug Gap Battle	311 Medical assist, assist EMS crew	
19-0000541	0	02/24/2019	18:21:58	1505 Coronet	132 Road freight or transport vehicle	\$10,000
19-0000542	0	02/24/2019	18:49:34	1203 Acme	651 Smoke scare, odor of smoke	
19-0000543	0	02/24/2019	21:13:24	1698 North Summit	743 Smoke detector activation, no fire	
19-0000544	0	02/24/2019	21:22:35	1306 Underwood	611 Dispatched & cancelled en route	
19-0000545	0	02/24/2019	21:58:02	Industrial (East)	324 Motor Vehicle Accident with no	
19-0000546	0	02/25/2019	12:11:01	Riverbend	322 Motor vehicle accident with	
19-0000547	0	02/25/2019	12:30:49	1203 Acme	311 Medical assist, assist EMS crew	
19-0000548	0	02/25/2019	12:55:21	1200 Glenwood (North)	311 Medical assist, assist EMS crew	
19-0000549	0	02/25/2019	13:20:51	100 Bogle (South)	311 Medical assist, assist EMS crew	
19-0000550	0	02/25/2019	13:23:31	511 Crawford (West)	311 Medical assist, assist EMS crew	
19-0000551	0	02/25/2019	18:09:33	2659 Abutment	311 Medical assist, assist EMS crew	
19-0000552	0	02/25/2019	20:15:12	1505 Coronet	132 Road freight or transport vehicle	
19-0000553	0	02/26/2019	06:32:15	405 Paige	611 Dispatched & cancelled en route	
19-0000554	0	02/26/2019	07:03:40	803 Tibbs (North)	311 Medical assist, assist EMS crew	
19-0000555	0	02/26/2019	07:41:29	1200 Memorial	611 Dispatched & cancelled en route	
19-0000556	0	02/26/2019	08:28:01	803 Tibbs (North)	311 Medical assist, assist EMS crew	
19-0000557	0	02/26/2019	09:50:25	104 Broadview	744 Detector activation, no fire -	
19-0000558	0	02/26/2019	10:39:21	2318 Sir Lancelot	311 Medical assist, assist EMS crew	
19-0000559	0	02/26/2019	14:48:39	2216 Chattanooga	311 Medical assist, assist EMS crew	
19-0000560	0	02/26/2019	16:33:41	622 Fifth	311 Medical assist, assist EMS crew	
19-0000561	0	02/26/2019	17:43:17	1203 Glenwood (North)	251 Excessive heat, scorch burns with	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {02/01/2019} And {02/28/2019}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
19-0000562	0	02/26/2019	18:33:42	103 Waugh (West)	311 Medical assist, assist EMS crew	
19-0000563	0	02/26/2019	19:01:44	400 Beech	311 Medical assist, assist EMS crew	
19-0000564	0	02/26/2019	19:15:38	1300 Waugh (West)	311 Medical assist, assist EMS crew	
19-0000565	0	02/26/2019	23:29:04	1320 Winton	311 Medical assist, assist EMS crew	
19-0000566	0	02/27/2019	04:19:56	1300 Waugh (West)	715 Local alarm system, malicious	
19-0000567	0	02/27/2019	05:41:43	414 Fredrick (North)	611 Dispatched & cancelled en route	
19-0000568	0	02/27/2019	08:21:49	Thornton (North)	322 Motor vehicle accident with	
19-0000569	0	02/27/2019	13:21:56	Thornton (North)	324 Motor Vehicle Accident with no	
19-0000570	0	02/27/2019	14:19:25	204 Walker	311 Medical assist, assist EMS crew	
19-0000571	0	02/27/2019	15:12:02	612 Foster	311 Medical assist, assist EMS crew	
19-0000572	0	02/27/2019	15:27:46	1200 Memorial	611 Dispatched & cancelled en route	
19-0000573	0	02/27/2019	16:47:47	201 Springdale	311 Medical assist, assist EMS crew	
19-0000574	0	02/27/2019	16:51:13	701 Chattanooga	733 Smoke detector activation due to	
19-0000575	0	02/27/2019	18:02:48	1695 Willow Oak	311 Medical assist, assist EMS crew	
19-0000576	0	02/27/2019	22:44:15	1411 Chattanooga	311 Medical assist, assist EMS crew	
19-0000577	0	02/28/2019	01:22:43	1218 Broadrick	311 Medical assist, assist EMS crew	
19-0000578	0	02/28/2019	07:09:03	1000 Abutment	311 Medical assist, assist EMS crew	
19-0000579	0	02/28/2019	07:21:25	Cleveland	611 Dispatched & cancelled en route	
19-0000580	0	02/28/2019	12:20:13	Veterans	611 Dispatched & cancelled en route	
19-0000581	0	02/28/2019	13:01:10	300 Autumn	311 Medical assist, assist EMS crew	
19-0000582	0	02/28/2019	18:23:49	700 Autumn	311 Medical assist, assist EMS crew	
19-0000583	0	02/28/2019	21:08:26	North Bypass	322 Motor vehicle accident with	
<b>Total Incident Count</b>						<b>292</b>
<b>Total Est Loss</b>						<b>\$24,300</b>

DALTON

Incident Type Period Comparisons

Alarm Date Between {02/01/2019} and {02/28/2019}

Incident Type	02/01/2019	02/01/2018	02/01/2017	02/01/2016
	to	to	to	to
	02/28/2019	02/28/2018	02/28/2017	02/28/2016
111 Building fire	1	3	2	4
113 Cooking fire, confined to container	1	1	4	2
114 Chimney or flue fire, confined to chimney or	0	0	0	2
118 Trash or rubbish fire, contained	0	1	0	0
131 Passenger vehicle fire	0	1	1	2
132 Road freight or transport vehicle fire	2	0	0	0
140 Natural vegetation fire, Other	0	0	0	1
142 Brush or brush-and-grass mixture fire	0	0	0	2
143 Grass fire	1	2	1	0
151 Outside rubbish, trash or waste fire	1	1	0	1
153 Construction or demolition landfill fire	0	1	0	0
154 Dumpster or other outside trash receptacle fire	0	0	3	0
162 Outside equipment fire	0	0	0	1
251 Excessive heat, scorch burns with no ignition	2	0	0	0
311 Medical assist, assist EMS crew	180	217	189	119
322 Motor vehicle accident with injuries	13	3	2	14
323 Motor vehicle/pedestrian accident (MV Ped)	2	1	2	0
324 Motor Vehicle Accident with no injuries	8	1	2	7
331 Lock-in (if lock out , use 511 )	1	0	0	0
352 Extrication of victim(s) from vehicle	0	0	1	0
353 Removal of victim(s) from stalled elevator	1	1	0	1
381 Rescue or EMS standby	0	0	1	0
411 Gasoline or other flammable liquid spill	1	0	0	0
412 Gas leak (natural gas or LPG)	1	3	2	2
413 Oil or other combustible liquid spill	0	1	0	0
424 Carbon monoxide incident	2	0	1	1
440 Electrical wiring/equipment problem, Other	1	4	0	0

DALTON

Incident Type Period Comparisons

Alarm Date Between {02/01/2019} and {02/28/2019}

Incident Type	02/01/2019	02/01/2018	02/01/2017	02/01/2016
	to 02/28/2019	to 02/28/2018	to 02/28/2017	to 02/28/2016
441 Heat from short circuit (wiring), defective/worn	1	0	1	2
442 Overheated motor	0	0	0	1
444 Power line down	1	0	2	5
445 Arcing, shorted electrical equipment	1	4	3	2
461 Building or structure weakened or collapsed	1	1	0	0
463 Vehicle accident, general cleanup	2	0	0	1
522 Water or steam leak	0	1	1	0
531 Smoke or odor removal	0	1	0	0
542 Animal rescue	1	1	0	0
551 Assist police or other governmental agency	0	0	0	1
553 Public service	1	7	1	1
561 Unauthorized burning	1	3	2	1
600 Good intent call, Other	0	0	0	2
611 Dispatched & cancelled en route	28	23	14	14
622 No Incident found on arrival at dispatch address	6	5	8	0
651 Smoke scare, odor of smoke	3	10	1	4
652 Steam, vapor, fog or dust thought to be smoke	0	0	1	0
653 Smoke from barbecue, tar kettle	1	0	0	0
671 HazMat release investigation w/no HazMat	1	2	1	0
711 Municipal alarm system, malicious false alarm	0	0	1	0
715 Local alarm system, malicious false alarm	1	0	0	1
721 Bomb scare - no bomb	0	0	0	1
731 Sprinkler activation due to malfunction	0	1	0	0
733 Smoke detector activation due to malfunction	2	2	7	4
734 Heat detector activation due to malfunction	0	0	0	1
735 Alarm system sounded due to malfunction	3	8	4	3
736 CO detector activation due to malfunction	1	0	0	0



DALTON

Incident Type Period Comparisons

Alarm Date Between {02/01/2019} and {02/28/2019}

Incident Type	02/01/2019	02/01/2018	02/01/2017	02/01/2016
	to	to	to	to
	02/28/2019	02/28/2018	02/28/2017	02/28/2016
740 Unintentional transmission of alarm, Other	0	1	0	0
741 Sprinkler activation, no fire - unintentional	0	2	1	1
743 Smoke detector activation, no fire -	10	7	11	10
744 Detector activation, no fire - unintentional	3	1	1	3
745 Alarm system activation, no fire - unintentional	6	8	3	4
911 Citizen complaint	0	0	1	1
<b>Totals</b>	<u>292</u>	<u>329</u>	<u>275</u>	<u>222</u>

DALTON

Monthly Unit Response Time Analysis

Alarm Date Between {02/01/2019} And {02/28/2019}  
and Response Code = "1 " (Emergency Response)

---

Response		Count	Percentage
Hrs	Mins		
<	01	14	4.1%
	01	40	11.8%
	02	87	25.7%
	03	97	28.6%
	04	55	16.2%
	05	27	7.9%
	06	8	2.3%
	07	2	0.5%
	08	2	0.5%
	09	2	0.5%
	10	1	0.2%
	11	1	0.2%
	14	2	0.5%

Overall Average Response Time: 00:03:28

DALTON

Monthly Unit Response Time Analysis

Alarm Date Between {02/01/2019} And {02/28/2019}  
and Response Code = "2 " (Non-Emergency Response)

---

Response		Count	Percentage
Hrs	Mins		
<	01	5	14.2%
	01	1	2.8%
	02	8	22.8%
	03	4	11.4%
	04	3	8.5%
	05	5	14.2%
	06	5	14.2%
	07	3	8.5%
	10	1	2.8%

---

Overall Average Response Time: 00:04:08

**Dalton Fire Department  
Medical Incident Study  
EMS On scene/Not on scene Prior to DFD Comparison  
2/1/19 –2/28/19**

**Total incidents in time period – 211**

**EMS on-scene prior to DFD – 51**

**EMS not on-scene prior – 160**

**During the month of February, Dalton Fire Department arrived on-scene prior to Hamilton EMS on 75% of medical responses.**

# Training Division Monthly Report

## February 2019

### Overview

The Fire Prevention Division delivered a course on Firehouse records management software that dealt specifically with pre-incident surveys and occupancies are modified within the system. The department's EMT instructors delivered a 6-hour EMT refresher on pediatrics to all licensed EMTs and paramedics. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of February totaled 2,616.

### Outside Schools

The department hosted Day 2 of the 16-hour course entitled Modular Emergency Response Radiological Transport Training (MERRTT) delivered by GEMA and the U.S. Department of Energy.

Lieutenant Dustin Martinez from Cobb County Fire & Emergency Services delivered a 4-hour course on advanced search and rescue techniques to all suppression personnel.

Two DFD personnel attended Emergency Resource Deployment Planning – Standards of Cover at the National Fire Academy in Emmitsburg, Maryland. This course teaches students how to analyze demographic, response, and GIS data to assist in writing a Standard of Cover for their department.

Additional off-campus training included:

Pressurized Container Fire Control	GPSTC	2
Incident Safety Officer	GPSTC	1
Handling Flammable Liquids Incidents	GPSTC	2

### Support Functions

- 103 hours were spent completing apparatus checks and equipment replenishment
- Cleaning and maintenance activities accounted for 650 hours in February
- 2 hours were dedicated to fire investigation and related activities

# Prevention Division Monthly Report

## February 2019

### Inspections

Annual Inspections	Total:	65
Apartment Inspections	Total:	1
Site Inspections	Total:	30
Fire Alarm Inspection	Total:	1
Sprinkler System Inspection	Total:	
New Kitchen Hood Inspections	Total:	
Knox Box Installation	Total:	12
Occupational Tax Certificate Inspections	Total:	8
Alcohol Inspections	Total:	1
50 Percent Inspections	Total:	1
80 Percent Inspections	Total:	1
100 Percent Inspections	Total:	4
Pre-Incident Surveys	Total:	17
Plan Reviews	Total:	2
Addressing	Total:	1
<b>Total Inspections</b>		<b>144</b>

### Public Relations

#### Fire Safety Education

Events	Total:	7
Staff Members Participated	Total:	25
Staff Hours	Total:	49
Number of Adults Reached	Total:	728
Number of Children Reached	Total:	3313
<b>Total Residents Reached</b>		<b>4041</b>

#### Smoke Detector Installation

Events	Total:	2
Staff Members Participated	Total:	6
Staff Hours	Total:	1
Total Smoke Detectors Installed	Total:	1
Total Number of Adults Reached	Total:	4
Total Number of Children Reached	Total:	2
<b>Total Residents Reached</b>		<b>6</b>

DALTON

Monthly Prevention Inspections by Type

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>200 INSPECTION - Annual</b>				
02/07/2019	13:45	20768 Highland Rivers 1011 Abutment RD	0.03	
02/26/2019	13:07	30026 NIZZIE'S BOTTLE SHOP 1902 Chattanooga RD	0.25	
02/26/2019	12:47	30027 MR BISCUIT 1904 Chattanooga RD /Mr. Biscuit #2	0.25	
02/26/2019	13:30	30028 Demolished 1908 Chattanooga RD /Rocky Face Shoppe/Suite 2	0.02	
02/26/2019	13:36	30031 MOTEL 6 2200 Chattanooga RD	0.22	
02/18/2019	11:04	30032 Los Pablos 2204 Chattanooga RD	0.27	
02/14/2019	10:06	30033 Guest Inn 2220 Chattanooga RD	0.32	
02/26/2019	13:38	30114 TIBBS RD. CONVENIECE STORE 813 Tibbs (North) RD	0.17	
02/28/2019	09:40	30138 Alliant Health Plans 1503 Tibbs (North) RD	0.40	
02/15/2019	13:17	30164 Green Vulture 2303 Chattanooga RD	0.13	
02/25/2019	13:33	30203 Holmes Liquor 2203 Chattanooga RD	0.31	
02/15/2019	14:11	30034 Southern Belle Resale 2305 Chattanooga RD	0.10	
02/26/2019	15:13	30220 Tijuana Mexican Restaurant 2311 Chattanooga RD	0.19	
02/28/2019	10:21	30242 Department of Transportation 1313 Tibbs (North) RD	0.07	
02/20/2019	10:28	30252 Waffle House 1912 Chattanooga RD	0.17	
02/20/2019	10:11	30290 Burger King 1906 Chattanooga RD	0.19	
02/20/2019	11:00	30291 Wendy's 2080 Chattanooga RD	0.17	
02/25/2019	10:19	30292 RaceTrac 1907 Chattanooga RD	0.20	
02/26/2019	11:14	40018 Encore 920 Market ST /D	0.12	

DALTON

Monthly Prevention Inspections by Type

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>200 INSPECTION - Annual</b>				
02/04/2019	15:07	40034 Tanger Outlet Center Offices 1001 Market ST /Suite 12 A	0.01	
02/04/2019	15:08	40035 Oyster Pub 933 Market ST /Suite 12 B	0.01	
02/15/2019	12:32	40049 Liberty Tax 1345 Walnut (West) AVE	0.10	
02/15/2019	12:39	40050 CI CI'S PIZZA 1345 Walnut (West) AVE /Suite 2	0.05	
02/15/2019	12:43	40051 Atlas Physical 1343 Walnut (West) AVE	0.03	
02/13/2019	13:32	40052 Petland 1343 Walnut (West) AVE	0.02	
02/15/2019	12:48	40048 AMERICA'S BEST CONTACT & EYEGLASSES 1341 Walnut (West) AVE	0.07	
02/12/2019	14:01	40066 Ed Kirby Chevrolet 1501 Walnut (West) AVE	0.09	
02/15/2019	12:18	40073 Planet Fitness 1515 Walnut (West) AVE	0.10	
02/15/2019	13:31	40105 Chilis 881 College DR	0.06	
02/28/2019	13:01	40110 Orchid Cleaners 1325 Dug Gap RD	0.20	
02/25/2019	09:58	40116 Dug Gap Family Dentistry 1405 Dug Gap RD	0.03	
02/26/2019	14:02	40117 Restoration Recovery 1500 Dug Gap RD	0.15	
02/08/2019	09:47	40119 Peds Care, P.C. 1933 Shields RD	0.05	
02/11/2019	10:03	40127 Total Image Hair Salon 1325 Dug Gap RD /F	0.00	
02/06/2019	09:51	40135 Quality Discount Carpet 1209 Walnut (West) AVE /Suite #9	0.10	
02/07/2019	11:06	40139 Seventh Day Adventist Church 300 Tibbs (South) RD	0.26	
02/04/2019	12:26	40150 Hilton Garden Inn 879 Holiday Inn DR	0.37	
02/04/2019	14:02	40151 Delta Spa Nails 1321 Walnut (West) AVE /Suite 4	0.01	



DALTON

Monthly Prevention Inspections by Type

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>200 INSPECTION - Annual</b>				
02/06/2019	13:26	40159 Regions Bank 1300 Walnut (West) AVE	0.15	
02/06/2019	10:14	40163 Verizon Wireless 1516 Walnut (West) AVE	0.09	
02/04/2019	14:49	40164 Krispy Kreme 1500 Walnut (West) AVE	0.11	
02/04/2019	13:32	40165 Sun Tan City 1329 Walnut (West) AVE /Suites 3 & 4	0.10	
02/04/2019	13:40	40166 RAK Outfitters 1329 Walnut (West) AVE /Suites 1 & 2	0.07	
02/04/2019	13:53	40167 TJ Maxx 1327 Walnut (West) AVE	0.25	
02/04/2019	14:03	40168 Sport Clips 1323 Walnut (West) AVE /Suite 4	0.09	
02/25/2019	13:52	40169 UPS Store 1323 Walnut (West) AVE /Suite 2	0.05	
02/04/2019	13:10	40169 UPS Store 1323 Walnut (West) AVE /Suite 2	0.07	
02/15/2019	09:37	40183 Panera Bread 1303 Walnut (West) AVE /Suite 1	0.09	
02/05/2019	09:22	40183 Panera Bread 1303 Walnut (West) AVE /Suite 1	0.20	
02/05/2019	09:59	40184 Five Guys 1303 Walnut (West) AVE	0.25	
02/06/2019	14:20	40184 Five Guys 1303 Walnut (West) AVE	0.01	
02/06/2019	12:09	40185 Kroger Fuel Center 1307 Walnut (West) AVE	0.07	
02/04/2019	14:32	40186 Schlotzsky's 1325 Walnut (West) AVE	0.14	
02/07/2019	10:23	50002 Warehouse One 1310 C & L DR	0.04	
02/15/2019	09:37	50002 Warehouse One 1310 C & L DR	0.43	
02/05/2019	08:51	50008 Accurate Mechanical & Piping 813 Legion DR	0.03	
02/13/2019	14:14	50012 One Main Financial 324 Northgate DR	0.01	

DALTON

Monthly Prevention Inspections by Type

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>200 INSPECTION - Annual</b>				
02/18/2019	11:15	50031 C V G / Finish T E K 1030 Vista DR	0.03	
02/18/2019	14:08	50033 C. V. G / Warehouse 1050 Vista DR	0.01	
02/05/2019	09:03	50079 Curt's Restarant 332 Northgate DR	0.06	
02/05/2019	10:12	50096 Iglesia De Dios Pentecostal Fuente Agua 1007 Underwood ST	0.07	
02/15/2019	10:15	50099 J&J Industries - Southcreek 1605 Underwood ST	0.07	
02/05/2019	10:18	50101 Trinity United Methodist Church 901 Veterans DR	0.02	
02/07/2019	10:45	50112 Cross Pointe Christian Center 2681 Underwood ST	0.00	
02/12/2019	12:39	50145 Sonic 1201 Glenwood (North) AVE	0.05	
<b>Total Activities for Type: 65</b>			<b>7.85</b>	
<b>205 INSPECTION - Annual Apartment</b>				
02/12/2019	15:05	40158 Emeralds Bridgewater PL	0.42	
<b>Total Activities for Type: 1</b>			<b>0.42</b>	
<b>210 INSPECTION - Site</b>				
02/27/2019		40173 Rak Outfitters 1310 Walnut (West) AVE /Suite 4	0.00	
02/12/2019		40189 KFC 1519 Walnut (West) AVE	0.00	
02/25/2019		40189 KFC 1519 Walnut (West) AVE	0.00	
02/13/2019	10:05	50137 Christian Heritage High School 1601 MLK Jr. BLVD	0.35	
02/13/2019	10:58	50094 Christian Heritage School 1600 MLK Jr. BLVD	0.03	

DALTON

Monthly Prevention Inspections by Type

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>210 INSPECTION - Site</b>				
02/08/2019	09:00	40063 Food City 1308 Walnut (West) AVE	0.50	
02/06/2019	12:00	40036 Stadium BBQ Pool 1001 Market ST /Suite 13	0.50	
02/06/2019		40002 NW Gerogia Trade and Convention Center 2211 Dug Gap Battle RD	0.00	
02/06/2019	13:00	30265 Legacy of Dalton 2111 Club DR	2.00	
02/27/2019		30077 Engineered Floors 1502 Coronet DR	0.00	
02/20/2019	11:00	30033 Guest Inn 2220 Chattanooga RD	1.00	
02/04/2019		30018 Vacant 1506 Thornton (North) AVE /D	0.00	
02/04/2019		30019 Chiro Choice 1508 Thornton (North) AVE /100/100	0.00	
02/19/2019	09:30	30033 Guest Inn 2220 Chattanooga RD	1.00	
02/04/2019		30016 Preferred Cherokee Dalton 1506 Thornton (North) AVE /A	0.00	
02/04/2019		30017 Southeastern Retina Associates 1506 Thornton (North) AVE /C/C	0.00	
02/15/2019		20770 United Karate Studios Dalton 1132 Walnut (East) AVE	0.00	
02/21/2019	12:30	20774 S. Glenwood Apartments 413 Glenwood (South) AVE	2.50	
02/22/2019	15:00	20774 S. Glenwood Apartments 413 Glenwood (South) AVE	1.00	
02/12/2019		20054 Plaze Georgia 310 Brookhollow Ind. BLVD	1.00	
02/05/2019		20504 Dalton Mall 816 Walnut Square BLVD	0.00	
02/11/2019	09:00	20733 Excalibur Village 2315 Sir Lancelot PL	1.00	
02/13/2019		10151 RIVER OF LIFE CHURCH 1002 Glenwood (North) AVE	0.00	
02/12/2019	11:30	10324 Planet of the Grapes 126 King (West) ST	0.50	

DALTON

Monthly Prevention Inspections by Type

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>210 INSPECTION - Site</b>				
02/26/2019	08:15	10359 HAMILTON MEDICAL CENTER 1200 Memorial DR	1.75	
02/27/2019		10359 HAMILTON MEDICAL CENTER 1200 Memorial DR	0.00	
02/14/2019	14:30	10777 Alliant Health Plans 201 Waugh (West) ST /Suite 300	0.50	
02/14/2019	14:00	10778 Health One Alliance, LLC 201 Waugh (West) ST /Suite 400	0.50	
02/12/2019	11:30	10782 Planet of the Grapes 208 Pentz (North) ST	0.50	
02/27/2019		10783 Peeple's Cancer Center 1215 Memorial DR	0.00	
<b>Total Activities for Type: 30</b>			<b>14.63</b>	
<b>211 INSPECTION - Plan Review</b>				
02/07/2019		10781 Skin Cancer & Cosmetic Dermatology 1107 Memorial DR /201	1.00	
02/06/2019		30289 Trans-Formers Transmissions 844 Shugart RD	1.00	
<b>Total Activities for Type: 2</b>			<b>2.00</b>	
<b>221 INSPECTION - Fire Alarm</b>				
02/07/2019	07:39	10240 All Chem 442 Hamilton (North) ST	0.03	
<b>Total Activities for Type: 1</b>			<b>0.03</b>	
<b>251 INSPECTION - Knox Box Installation</b>				
02/07/2019		10085 The Chop Shop 209 Cuyler (west) ST	0.00	
02/08/2019		10085 The Chop Shop 209 Cuyler (west) ST	0.00	
02/08/2019		20757 Select Staffing 801 Walnut (East) AVE /Suite N	0.00	

**DALTON**

**Monthly Prevention Inspections by Type**

**Date Completed Between {02/01/2019} And  
{02/28/2019}**

<b>Date</b>	<b>Time</b>	<b>Occupancy</b>	<b>Hrs</b>	<b>Fee</b>
<b>251 INSPECTION - Knox Box Installation</b>				
02/06/2019		20246 SHAW INDUSTRIES 2305 Abutment RD	0.00	
02/14/2019	13:30	30016 Preferred Cherokee Dalton 1506 Thornton (North) AVE /A	0.25	
02/14/2019	13:30	30017 Southeastern Retina Associates 1506 Thornton (North) AVE /C/C	0.25	
02/14/2019	13:30	30018 Vacant 1506 Thornton (North) AVE /D	0.25	
02/04/2019	12:15	40071 Total Health Chiropractic 1513 Walnut (West) AVE /Suite 3	0.25	
02/28/2019		40048 AMERICA'S BEST CONTACT & EYEGLASSES 1341 Walnut (West) AVE	0.00	
02/27/2019		50048 Intouch Computer Services 1716 Cleveland RD /600	0.00	
02/27/2019		5P002 Dan Combs Properties 1716 Cleveland HWY	0.00	
02/27/2019		40170 Ulta Beauty 1310 Walnut (West) AVE /Suite 1	0.00	
<b>Total Activities for Type: 12</b>			<b>1.00</b>	

**261 INSPECTION - OTC**

02/06/2019	13:21	40182 Chic-Fil-A 1517 Walnut (West) AVE	0.01	
02/15/2019	12:27	40182 Chic-Fil-A 1517 Walnut (West) AVE	0.00	
02/05/2019	13:08	30222 Village Podiatry 1505 Professional CT	0.01	
02/05/2019		30224 David Blevins Attorney 305 Point North PL /2	0.00	
02/27/2019		10411 Create and Play Studio 108 Pentz (North) ST /SUITE C	0.00	
02/13/2019		10552 Rail Side Tattoo 102 Waugh (West) ST	0.00	
02/27/2019	10:00	10784 Natasha's Tight Cutz N' Styles 624 Glenwood (North) AVE /Suite C	0.50	
02/27/2019	11:00	10785 Sharon Langford Realty, LLC 720 Glenwood (South) AVE /Suite 206	0.50	

DALTON

Monthly Prevention Inspections by Type

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>261 INSPECTION - OTC</b>				
<b>Total Activities for Type:</b>			<b>8</b>	<b>1.02</b>
<b>262 INSPECTION - Alcohol</b>				
02/15/2019		10762 Native 825 Chattanooga AVE /3/4	1.00	
<b>Total Activities for Type:</b>			<b>1</b>	<b>1.00</b>
<b>270 INSPECTION - 50</b>				
02/13/2019	15:33	40170 Ulta Beauty 1310 Walnut (West) AVE /Suite 1	0.01	
<b>Total Activities for Type:</b>			<b>1</b>	<b>0.01</b>
<b>280 INSPECTION - 80</b>				
02/12/2019		40173 Rak Outfitters 1310 Walnut (West) AVE /Suite 4	1.00	
<b>Total Activities for Type:</b>			<b>1</b>	<b>1.00</b>
<b>290 INSPECTION - 100</b>				
02/12/2019		40170 Ulta Beauty 1310 Walnut (West) AVE /Suite 1	0.00	
02/13/2019	14:34	50088 Cold Creek 101 North Oaks DR /Suite 1	0.06	
02/07/2019	16:22	10762 Native 825 Chattanooga AVE /3/4	0.57	
02/15/2019	11:27	10762 Native 825 Chattanooga AVE /3/4	0.03	
<b>Total Activities for Type:</b>			<b>4</b>	<b>0.66</b>

DALTON

**Monthly Prevention Inspections by Type**

Date Completed Between {02/01/2019} And  
{02/28/2019}

Date	Time	Occupancy	Hrs	Fee
<b>501 PRE-INCIDENT SURVEY</b>				
02/25/2019	13:30	30217 Whites Pediatrics 1575 Chattanooga AVE /suite 1	0.50	
02/25/2019	14:00	30218 Amedisys 1575 Chattanooga AVE /Suite 2	1.50	
02/25/2019	13:00	30219 Whites Pediatrics 1575 Chattanooga AVE /Suite 3	0.50	
02/25/2019		50049 Apex Spine Center 1716 Cleveland RD /700	0.00	
02/25/2019		50050 Vacant 1716 Cleveland RD /800	0.00	
02/25/2019		50085 la Fiesta 1525 Cleveland HWY /Suite 3	0.00	
02/25/2019		50086 La Fiesta 1525 Cleveland HWY /Suite 2 & 3	0.00	
02/25/2019		50087 Pizza Hut 1525 Cleveland HWY /Suite 1	0.00	
02/25/2019		50044 STATE FARM INSURANCE 1716 Cleveland HWY /100	0.00	
02/25/2019		50045 Vacant 1716 Cleveland RD /200	0.00	
02/25/2019		50046 Dental Arts of Dalton 1716 Cleveland HWY /400	0.00	
02/25/2019		50047 Vacant 1716 Cleveland RD /500	0.00	
02/25/2019		50048 Intouch Computer Services 1716 Cleveland RD /600	0.00	
02/25/2019		50138 Vacant 1716 Cleveland HWY /900	0.00	
02/25/2019		50139 Vacant 1716 Cleveland HWY /1000	0.00	
02/25/2019		50130 Vacant 1716 Cleveland HWY /300	0.00	
02/25/2019		50002 Warehouse One 1310 C & L DR	0.00	
<b>Total Activities for Type:</b>			<b>17</b>	<b>2.50</b>

**Grand Total Activities: 143**

**Grand Totals: 32.12 0.00**



DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

30138 Alliant Health Plans  
1503 Tibbs (North) RD  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/28/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building.				
02/28/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Multiple emergency lights are out.				
02/28/2019	2013 NFPA 13 6.2.7.2 Sprinkler system, eschusion	1			0
	<b>Notes:</b> Multiple plates missing.				

-----  
Total Individual Violation Codes for Occupancy: 3

10411 Create and Play Studio  
108 Pentz (North) ST  
SUITE C  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/27/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.				
02/27/2019	2012 IFC 605.1 Electrical panel, abatement of	1			0
	<b>Notes:</b> Open spaces in electrical panel needs to be covered.				
02/27/2019	2012 IFC 605.1 Electrical panel, abatement of	1			0
	<b>Notes:</b> Wiring going to light switch in electrical room has been spliced and is secured with electrical tape. This needs to be corrected, and brought up to code.				
02/27/2019	2012 NFPA 101 7.2.1.5.1 Exit, while building	1			0
	<b>Notes:</b> Due to the fact the main entrance door into the studio has a keyed lock on each side, a sign shall be placed on the door stating the following: This door is to remain unlocked while the building is occupied.				

\* Denotes Violations Corrected or Variance Issued

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

10411 Create and Play Studio  
108 Pentz (North) ST  
SUITE C  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

Total Individual Violation Codes for Occupancy: 4

30224 David Blevins Attorney  
305 Point North PL  
2  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

02/05/2019	2012 IFC 506.1 Knox Box, requirements	1			0
<p><b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.</p>					

02/05/2019	2012 IFC 906.3 Fire extinguisher, incorrect	1			0
<p><b>Notes:</b> No extinguishers present, install a 10lb fire extinguisher that has been tagged by a GA licensed contractor.</p>					

Total Individual Violation Codes for Occupancy: 2

40158 Emeralds  
Bridgewater PL  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

02/12/2019	2013 NFPA 72 10.3.2 System tested per	1			0
<p><b>Notes:</b> Need information in regards to fire alarm.</p>					

Total Individual Violation Codes for Occupancy: 1

\* Denotes Violations Corrected or Variance Issued

DALTON

Monthly Prevention Violations by Occupancy  
 Violation Date Reported Between {02/01/2019} And  
 {02/28/2019}

40018            **Encore**  
                   **920 Market ST**  
                   **D**  
                   **Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
02/26/2019	2012 IFC 906.2 Fire extinguisher, Properly <b>Notes:</b> Must have current inspection.	1			0
02/26/2019	2012 NFPA 101 7.9.3.1.1 Emergency light, <b>Notes:</b> Multiple emergency lights are out.	1			0
02/26/2019	DFDFMO AHJ, Requirement <b>Notes:</b> Have Nareen send email info.	1			0
-----					
<b>Total Individual Violation Codes for Occupancy: 3</b>					

40184            **Five Guys**  
                   **1303 Walnut (West) AVE**  
                   **Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
02/05/2019	*DFDFMO AHJ, Requirement <b>Notes:</b> Need to add proper key.	1			0
02/05/2019	*DFDFMO AHJ, Requirement <b>Notes:</b> Recheck violation record automatically created from a recheck request.	1			0
Original Violation Remarks: Need to add proper key.					
-----					
<b>Total Individual Violation Codes for Occupancy: 2</b>					

30164            **Green Vulture**  
                   **2303 Chattanooga RD**  
                   **Dalton, GA 30720**

Reported	Code/Description	Count	Article	Division	Page
02/15/2019	2012 IFC 506.1 Knox Box, requirements <b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet	1			0

\* Denotes Violations Corrected or Variance Issued

**DALTON**

**Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {02/01/2019} And  
{02/28/2019}**

**30164            Green Vulture  
                  2303 Chattanooga RD  
                  Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
	from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.Add Knox Box to building				
02/15/2019	2012 IFC 605.1 Electrical panel, abatement of <b>Notes:</b> Need to repair.	1			0
02/15/2019	2012 IFC 605.6 Electrical panel, cover not <b>Notes:</b> Replace all covers.	1			0
02/15/2019	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access <b>Notes:</b> Take chains off doors immediately.	1			0
02/15/2019	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire <b>Notes:</b> Email current fire alarm inspection.	1			0
02/15/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional <b>Notes:</b> Repair all exit signs.	1			0

-----  
**Total Individual Violation Codes for Occupancy: 6**

**30033            Guest Inn  
                  2220 Chattanooga RD  
                  Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/14/2019	2012 IFC 605.1 Electrical panel, abatement of <b>Notes:</b> Must be in conduit.	1			0
02/14/2019	2012 IFC 605.1 Electrical panel, abatement of <b>Notes:</b> Must repair.	1			0
02/14/2019	2012 IFC 605.5 Extension cord, Improper use <b>Notes:</b> See nots.	1			0
02/14/2019	2012 IFC 605.5.3 Extension cord, Maintenance <b>Notes:</b> Cannot use co dis for permanent wiring.	1			0
02/14/2019	2012 IFC 605.6 Electrical panel, cover not <b>Notes:</b> Replace cover.	1			0

**\* Denotes Violations Corrected or Variance Issued**

DALTON

Monthly Prevention Violations by Occupancy  
 Violation Date Reported Between {02/01/2019} And  
 {02/28/2019}

30033            Guest Inn  
                  2220 Chattanooga RD  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/14/2019	2012 NFPA 101 7.1.10.1 MOE, unimpeded exit access <b>Notes:</b> Cannot block.	1			0
02/14/2019	2012 NFPA 101 7.2.2.2.1 MOE, stairs ( existing ) <b>Notes:</b> Correct issues with stairs.	1			0
02/14/2019	2012 NFPA 101 7.2.2.4.5.2 MOE, guardrails <b>Notes:</b> Must be brought up to code.	1			0
02/14/2019	2012 NFPA 101 7.9.3.1.1 Emergency light, <b>Notes:</b> See note on cit sign.	1			0
02/14/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional <b>Notes:</b> Repair or replace exit sign. Plug in needs to be removed and hard wired.	1			0
02/14/2019	DFDFMO AHJ, Requirement <b>Notes:</b> Smoke alarm out in rm 105 Rm 107 no smoke alarm. Rm 111 not working. Rm 115 not working. Rm 211 has extension cord to another room. Rm 209 no alarm. No emergency lights on exterior are working. Rm 203 no smoke alarm. Add m 207 no smoke alarm. ( Bed Bug) issues. Bldg. 2 Rm 125 No smoke alarm Rm 129 Rm 132 needs battery Rm 130 not working Rm 126 not working Rm 124 not working Rm 120 not working Bldg. 3 Rm 135 not working Rm137 not working Rm 139 not working Rm 145 no alarm Rm 246 no alarm	1			0

\* Denotes Violations Corrected or Variance Issued

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

30033            Guest Inn  
                  2220 Chattanooga RD  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
	Rm 242 not working				
	Rm 233 not working				

-----  
Total Individual Violation Codes for Occupancy: 11

40150            Hilton Garden Inn  
                  879 Holiday Inn DR  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/04/2019	2012 NFPA 101 7.9.3.1.1 Emergency light, Notes: Repair or replace emergency lights.	1			0
02/04/2019	2013 NFPA 13 6.2.7.2 Sprinkler system, eschusion Notes: Replace rings.	1			0

-----  
Total Individual Violation Codes for Occupancy: 2

30203            Holmes Liquor  
                  2203 Chattanooga RD  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/25/2019	2012 IFC 506.1 Knox Box, requirements Notes: Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building.	1			0

-----  
Total Individual Violation Codes for Occupancy: 1

\* Denotes Violations Corrected or Variance Issued

**DALTON**

**Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {02/01/2019} And  
{02/28/2019}**

**30032            Los Pablos  
                  2204 Chattanooga RD  
                  Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/18/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building within 6 months.				
02/18/2019	2012 IFC 605.4 Multi outlet adaptor	1			0
	<b>Notes:</b> Cannot "piggyback" multi plug adapters				
02/18/2019	2012 IFC 605.5 Extension cord, Improper use	1			0
	<b>Notes:</b> Need to make plug ins available. This is overloading the outlet.				
02/18/2019	2012 IFC 605.6 Electrical panel, cover not	1			0
	<b>Notes:</b> Replace cover.				
02/18/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Repair or replace emergency lights.				
02/18/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional	1			0
	<b>Notes:</b> Repair or replace exit sign. Exit sign gun in bar and back hall in storage area are not working properly.				

-----  
**Total Individual Violation Codes for Occupancy: 6**

**30031            MOTEL 6  
                  2200 Chattanooga RD  
                  Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/26/2019	2012 IFC 605.3 Electrical panel, obstructed	1			0
	<b>Notes:</b> Remove combustibles near electrical panels.				
02/26/2019	2012 IFC 906.2 Fire extinguisher, Properly	1			0
	<b>Notes:</b> Have Fire extinguishers serviced annually.				
02/26/2019	2012 NFPA 101 9.6.1.3 Fire alarm, Annual fire	1			0
	<b>Notes:</b> Have fire alarm inspection completed.				

**\* Denotes Violations Corrected or Variance Issued**

**DALTON**

**Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {02/01/2019} And  
{02/28/2019}**

**30031           MOTEL 6  
                  2200 Chattanooga RD  
                  Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/26/2019	DFDFMO AHJ, Requirement	1			0
	<b>Notes:</b> Replace fire extinguisher cabinets with approved cabinets.				

-----  
**Total Individual Violation Codes for Occupancy: 4**

**30027           MR BISCUIT  
                  1904 Chattanooga RD  
                  Mr. Biscuit #2  
                  Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/26/2019	2011 NFPA 96 10.9.1 Kitchen hood suppression	1			0
	<b>Notes:</b> Hood suppression system needs to be inspected. Should be inspected every 6 months.				
02/26/2019	2011 NFPA 96 11.4 Kitchen hood,	1			0
	<b>Notes:</b> Have hood system inspected and cleaned every 6 months.				
02/26/2019	2011 NFPA 96 11.7.2 Cooking equipment,	1			0
	<b>Notes:</b> Clean behind equipment on an as needed basis.				
02/26/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box on the building.				
02/26/2019	2012 IFC 605.5 Extension cord, Improper use	1			0
	<b>Notes:</b> Extension cords should only be used for temporary power.				
02/26/2019	2012 IMC 507.12 Cooking equipment, Proper	1			0
	<b>Notes:</b> Cooking equipment should be at least 6 inches inside hood.				

-----  
**Total Individual Violation Codes for Occupancy: 6**

**\* Denotes Violations Corrected or Variance Issued**



**DALTON**

**Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {02/01/2019} And  
{02/28/2019}**

**10784            Natasha's Tight Cutz N' Styles  
624 Glenwood (North) AVE  
Suite C  
Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/27/2019	2012 IFC 506.1 Knox Box, requirements	1			0
<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.					
02/27/2019	2012 IFC 906.3 Fire extinguisher, incorrect	1			0
<b>Notes:</b> There were no fire extinguishers present, contact a licensed fire extinguisher contractor to install the appropriate fire extinguisher and tag it.					

-----  
**Total Individual Violation Codes for Occupancy: 2**

**10762            Native  
825 Chattanooga AVE  
3/4  
Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/07/2019	* 2011 NFPA 96 4.1.3 Kitchen hood suppression	1			0
<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Needs to be attached to alarm system.					
02/07/2019	* 2011 NFPA 96 4.1.3 Kitchen hood suppression	1			0
<b>Notes:</b> Needs to be attached to alarm system.					
02/07/2019	* DFDFMO AHJ, Requirement	1			0
<b>Notes:</b> Add gas cut off below ceiling. Seal are between hood and wall.					
02/07/2019	* DFDFMO AHJ, Requirement	1			0
<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Add gas cut off below ceiling. Seal are between hood and wall.					

**\* Denotes Violations Corrected or Variance Issued**

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

10762            Native  
                 825 Chattanooga AVE  
                 3/4  
                 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
<b>Total Individual Violation Codes for Occupancy: 4</b>					

30026            NIZZIE'S BOTTLE SHOP  
                 1902 Chattanooga RD  
                 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/26/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Install Knox Box on building.				
02/26/2019	2012 IFC 605.1 Electrical panel, abatement of	1			0
	<b>Notes:</b> Cover exposed electrical wiring.				
02/26/2019	2012 IFC 605.3 Electrical panel, obstructed	1			0
	<b>Notes:</b> Remove combustibles near electrical panels.				
02/26/2019	2012 IFC 605.5 Extension cord, Improper use	1			0
	<b>Notes:</b> Extension cords should only be used for temporary power.				
<b>Total Individual Violation Codes for Occupancy: 4</b>					

40183            Panera Bread  
                 1303 Walnut (West) AVE  
                 Suite 1  
                 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/05/2019	* 2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in				

\* Denotes Violations Corrected or Variance Issued

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

40183 Panera Bread  
1303 Walnut (West) AVE  
Suite 1  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
	place to access building.Add Knox Box to building.				
02/05/2019	* 2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.Add Knox Box to building.				
02/05/2019	* 2013 NFPA 13 6.2.7.2 Sprinkler system, eschusion	1			0
	<b>Notes:</b> Ensure eschusion rings are in place.				
02/05/2019	* 2013 NFPA 13 6.2.7.2 Sprinkler system, eschusion	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Ensure eschusion rings are in place.				
02/05/2019	* 2013 NFPA 8.6.5.3.1 Storage with 18" of sprinkler	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Move storage.				
02/05/2019	* 2013 NFPA 8.6.5.3.1 Storage with 18" of sprinkler	1			0
	<b>Notes:</b> Move storage.				

-----  
Total Individual Violation Codes for Occupancy: 6

40135 Quality Discount Carpet  
1209 Walnut (West) AVE  
Suite #9  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/06/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at www.knoxbox.com select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.Add Knox Box to building.				

\* Denotes Violations Corrected or Variance Issued

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

40135           Quality Discount Carpet  
                  1209 Walnut (West) AVE  
                  Suite #9  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/06/2019	2012 IFC 906.2 Fire extinguisher, Properly	1			0
	<b>Notes:</b> Current inspection needed.				

-----  
Total Individual Violation Codes for Occupancy: 2

30292           RaceTrac  
                  1907 Chattanooga RD  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/25/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.Add Knox Box to building.				
02/25/2019	2012 IFC 605.6 Electrical panel, cover not	1			0
	<b>Notes:</b> Replace cover.				

-----  
Total Individual Violation Codes for Occupancy: 2

40159           Regions Bank  
                  1300 Walnut (West) AVE  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/06/2019	2012 IFC 506.1 Knox Box, requirements	1			0
	<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.Add Knox Box to building.				

\* Denotes Violations Corrected or Variance Issued

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

40159           Regions Bank  
                  1300 Walnut (West) AVE  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

-----  
Total Individual Violation Codes for Occupancy: 1

40186           Schlotzsky's  
                  1325 Walnut (West) AVE  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

02/04/2019	2011 NFPA 96 10.9.1 Kitchen hood suppression	1			0
------------	--	---	--	--	---

Notes: Inspection past due.

02/04/2019	2012 IFC 506.1 Knox Box, requirements	1			0
------------	---------------------------------------	---	--	--	---

Notes: Install Knox Box on building. Order at [www.knoxbox.com](http://www.knoxbox.com) select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building.

02/04/2019	2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
------------	--	---	--	--	---

Notes: Repair or replace emergency lights.

02/04/2019	2013 NFPA 10 6.6.1 Class K fire extinguisher	1			0
------------	--	---	--	--	---

Notes: Add Class K extinguisher to kitchen.

02/04/2019	2013 NFPA 96 10.2.2 Class K placard required	1			0
------------	--	---	--	--	---

Notes: See Annex A NFPA 10 Add correct placard at time of addition of Class K extinguisher.

-----  
Total Individual Violation Codes for Occupancy: 5

10785           Sharon Langford Realty, LLC  
                  720 Glenwood (South) AVE  
                  Suite 206  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

\* Denotes Violations Corrected or Variance Issued

**DALTON**

**Monthly Prevention Violations by Occupancy**

**Violation Date Reported Between {02/01/2019} And  
{02/28/2019}**

**10785**            **Sharon Langford Realty, LLC**  
**720 Glenwood (South) AVE**  
**Suite 206**  
**Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/27/2019	2012 IFC 506.1 Knox Box, requirements <b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.	1			0
02/27/2019	2012 IFC 906.2 Fire extinguisher, Properly <b>Notes:</b> Have fire extinguishers serviced by a GA licensed contractor.	1			0
02/27/2019	2012 NFPA 101 7.9.3.1.1 Emergency light, <b>Notes:</b> All emergency lights shall be inspected to ensure they work properly in case power is lossed.	1			0
02/27/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional <b>Notes:</b> All exit signs shall be inspected to ensure they work properly in the event of a power loss.	1			0

-----  
**Total Individual Violation Codes for Occupancy: 4**

**30034**            **Southern Belle Resale**  
**2305 Chattanooga RD**  
**Dalton, GA 30720**

<b>Reported</b>	<b>Code/Description</b>	<b>Count</b>	<b>Article</b>	<b>Division</b>	<b>Page</b>
02/15/2019	2012 IFC 506.1 Knox Box, requirements <b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building. Add Knox Box to building.	1			0
02/15/2019	2012 IFC 605.4 Multi outlet adaptor <b>Notes:</b> Cannot piggyback cords.	1			0
02/15/2019	2012 NFPA 101 7.10.1.8 Exit sign, not visible <b>Notes:</b> Add exit signs.	1			0

**\* Denotes Violations Corrected or Variance Issued**

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

30034 Southern Belle Resale  
2305 Chattanooga RD  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/15/2019	2012 NFPA 101 7.9.2.1 Emergency light, none	1			0
<b>Notes:</b> Add emergency lights.					

-----  
Total Individual Violation Codes for Occupancy: 4

40168 Sport Clips  
1323 Walnut (West) AVE  
Suite 4  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/04/2019	2012 IFC 506.1 Knox Box, requirements	1			0
<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.No key in Knox Box.					

-----  
Total Individual Violation Codes for Occupancy: 1

30114 TIBBS RD. CONVENIECE STORE  
813 Tibbs (North) RD  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/26/2019	2012 IFC 505.1 Address, no suite	1			0
<b>Notes:</b> Address numbers should be a minimum of 4 inches tall and 1/2 inch wide. Numbers should be visible from road fronting the property, and be contrasting to the background.Add address to front of building. 4 inches tall 1 inch stroke.					
02/26/2019	2012 IFC 506.1 Knox Box, requirements	1			0
<b>Notes:</b> Install Knox Box on building. Order at <a href="http://www.knoxbox.com">www.knoxbox.com</a> select Dalton Fire Department. Should be installed near front door at a maximum height of 6 feet from ground. Make sure to put the sticker on the door. Ensure proper key is in place to access building.Add Knox Box to building					

\* Denotes Violations Corrected or Variance Issued

DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

30114            TIBBS RD. CONVENIECE STORE  
813 Tibbs (North) RD  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
<b>Total Individual Violation Codes for Occupancy: 2</b>					

40167            TJ Maxx  
1327 Walnut (West) AVE  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/04/2019	2011 NFPA 25 4.3.6.1 Sprinkler system, Annual	1			0
	<b>Notes:</b> Have sprinkler system inspection performed by a GA licensed contractor.				
02/04/2019	2013 NFPA 72 17.14.8.2 Fire alarm, pull station	1			0
	<b>Notes:</b> Do not block pull stations.				
<b>Total Individual Violation Codes for Occupancy: 2</b>					

40169            UPS Store  
1323 Walnut (West) AVE  
Suite 2  
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/04/2019	* 2012 IFC 605.6 Electrical panel, cover not	1			0
	<b>Notes:</b> Replace cover.				
02/04/2019	* 2012 IFC 605.6 Electrical panel, cover not	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Replace cover.				
02/04/2019	* 2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Recheck violation record automatically created from a recheck request. Original Violation Remarks: Repair or replace emergency lights.				
02/04/2019	* 2012 NFPA 101 7.9.3.1.1 Emergency light,	1			0
	<b>Notes:</b> Repair or replace emergency lights.				

\* Denotes Violations Corrected or Variance Issued





DALTON

Monthly Prevention Violations by Occupancy

Violation Date Reported Between {02/01/2019} And  
{02/28/2019}

30252           Waffle House  
                  1912 Chattanooga RD  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/20/2019	2011 NFPA 96 10.9.1 Kitchen hood suppression <b>Notes:</b> Out of date.	1			0
02/20/2019	2011 NFPA 96 11.4 Kitchen hood, <b>Notes:</b> No paperwork available.	1			0
02/20/2019	2012 IFC 906.2 Fire extinguisher, Properly <b>Notes:</b> Out of date.	1			0
02/20/2019	DFDFMO AHJ, Requirement <b>Notes:</b> Class K needs to be inspected	1			0

-----  
**Total Individual Violation Codes for Occupancy: 4**

30291           Wendy's  
                  2080 Chattanooga RD  
                  Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
02/20/2019	2012 NFPA 101 7.9.3.1.1 Emergency light, <b>Notes:</b> Repair or replace emergency light.	1			0
02/20/2019	2012 NFPA101 7.10.5.1 Exit sign, non functional <b>Notes:</b> Repair or replace exit sign.	1			0

-----  
**Total Individual Violation Codes for Occupancy: 2**

**Grand Total Violations: 102**

\* Denotes Violations Corrected or Variance Issued