

DALTON FIRE DEPARTMENT

TODD PANGLE
Fire Chief
Telephone 706-278-7363
Fax 706-272-7107
tpangle@daltonga.gov

404 School Street
Dalton, GA 30720



PUBLIC SAFETY COMMISSION

Bill Weaver
Terry Mathis
Anthony Walker
Luis Viamonte
Truman Whitfield

July 2020

Incident Response

Monthly Synopsis

<u>Category</u>	<u>Responses</u>	<u>Percentage</u>
Fire	6	2.13%
Overpressure Rupture, Overheat	2	0.71%
Rescue/Medical	170	60.49%
Hazardous Condition	11	3.91%
Service Call	7	2.49%
Good Intent	55	19.57%
False Alarm	30	10.67%

Total Responses **281**

Average Response Time **3:35**

Estimated Loss **\$82,200**

Incident Type Report (Monthly Summary)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident Type	Count	Pct of Incidents	Total Est Loss	Pct of Losses
1 Fire				
111 Building fire	1	0.35%	\$1,200	1.45%
131 Passenger vehicle fire	1	0.35%	\$1,000	1.21%
132 Road freight or transport vehicle fire	1	0.35%	\$75,000	91.24%
142 Brush or brush-and-grass mixture fire	2	0.71%	\$500	0.60%
143 Grass fire	1	0.35%	\$0	0.00%
	6	2.13%	\$77,700	94.52%
2 Overpressure Rupture, Explosion, Overheat (no fire)				
251 Excessive heat, scorch burns with no	2	0.71%	\$0	0.00%
	2	0.71%	\$0	0.00%
3 Rescue & Emergency Medical Service Incident				
311 Medical assist, assist EMS crew	150	53.38%	\$0	0.00%
322 Motor vehicle accident with injuries	15	5.33%	\$0	0.00%
324 Motor Vehicle Accident with no injuries	5	1.77%	\$0	0.00%
	170	60.49%	\$0	0.00%
4 Hazardous Condition (No Fire)				
411 Gasoline or other flammable liquid spill	1	0.35%	\$0	0.00%
412 Gas leak (natural gas or LPG)	1	0.35%	\$0	0.00%
413 Oil or other combustible liquid spill	1	0.35%	\$0	0.00%
441 Heat from short circuit (wiring),	2	0.71%	\$0	0.00%
442 Overheated motor	1	0.35%	\$0	0.00%
443 Breakdown of light ballast	1	0.35%	\$0	0.00%
444 Power line down	3	1.06%	\$4,500	5.47%
445 Arcing, shorted electrical equipment	1	0.35%	\$0	0.00%
	11	3.91%	\$4,500	5.47%
5 Service Call				
500 Service Call, other	1	0.35%	\$0	0.00%
522 Water or steam leak	2	0.71%	\$0	0.00%
553 Public service	3	1.06%	\$0	0.00%
561 Unauthorized burning	1	0.35%	\$0	0.00%
	7	2.49%	\$0	0.00%
6 Good Intent Call				
611 Dispatched & cancelled en route	45	16.01%	\$0	0.00%
622 No Incident found on arrival at dispatch	8	2.84%	\$0	0.00%
651 Smoke scare, odor of smoke	2	0.71%	\$0	0.00%

Incident Type Report (Monthly Summary)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident Type	Pct of Count	Total Incidents	Total Est Loss	Pct of Losses
6 Good Intent Call	55	19.57%	\$0	0.00%
7 False Alarm & False Call				
731 Sprinkler activation due to malfunction	1	0.35%	\$0	0.00%
733 Smoke detector activation due to	2	0.71%	\$0	0.00%
734 Heat detector activation due to malfunction	1	0.35%	\$0	0.00%
735 Alarm system sounded due to malfunction	4	1.42%	\$0	0.00%
736 CO detector activation due to malfunction	1	0.35%	\$0	0.00%
741 Sprinkler activation, no fire -	1	0.35%	\$0	0.00%
743 Smoke detector activation, no fire -	11	3.91%	\$0	0.00%
744 Detector activation, no fire -	3	1.06%	\$0	0.00%
745 Alarm system activation, no fire -	5	1.77%	\$0	0.00%
746 Carbon monoxide detector activation, no CO	1	0.35%	\$0	0.00%
	30	10.67%	\$0	0.00%

Total Incident Count: 281

Total Est Loss:

\$82,200

DALTON**Dollar Value Saved & Loss Analysis (Monthly)****Alarm Date Between {07/01/2020} And {07/31/2020}**

Incident Type	Count	Total Values	Total Losses	Total Saved	Percent Lost	Percent Saved
111 Building fire	1	\$66,000	\$1,200	\$64,800	1.82%	98.18%
131 Passenger vehicle fire	1	\$0	\$1,000	\$-1,000	0.00%	0.00%
132 Road freight or	1	\$75,000	\$75,000	\$0	100.00%	0.00%
142 Brush or	1	\$500	\$500	\$0	100.00%	0.00%
444 Power line down	1	\$152,500	\$4,500	\$148,000	2.95%	97.05%
Grand Totals	5	\$294,000	\$82,200	\$211,800		

Total Percent Lost: 27.96 %

Total Percent Saved: 72.04 %

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001556	0	07/01/2020	05:40:37	900	Shugart	311 Medical assist, assist EMS crew
20-0001557	0	07/01/2020	10:54:45	1898	Grand Summit	553 Public service
20-0001558	0	07/01/2020	13:17:40	2209	Raintree	311 Medical assist, assist EMS crew
20-0001559	0	07/01/2020	13:34:04	1447	Westover	311 Medical assist, assist EMS crew
20-0001560	0	07/01/2020	16:36:22		Cleveland	611 Dispatched & cancelled en route
20-0001561	0	07/01/2020	18:01:40	216	Fort Hill	311 Medical assist, assist EMS crew
20-0001562	0	07/01/2020	20:01:02	800	College	411 Gasoline or other flammable liquid
20-0001563	0	07/01/2020	20:43:26	510	Shugart	311 Medical assist, assist EMS crew
20-0001564	0	07/01/2020	21:43:23	2210	Rocky Face	311 Medical assist, assist EMS crew
20-0001565	0	07/02/2020	01:34:23	2305	Abutment	311 Medical assist, assist EMS crew
20-0001566	0	07/02/2020	09:28:27		Glenwood (North)	322 Motor vehicle accident with
20-0001573	0	07/02/2020	16:02:37	1804	Martha's Bridge	142 Brush or brush-and-grass mixture
20-0001574	0	07/02/2020	18:48:16	628	Fifth	611 Dispatched & cancelled en route
20-0001575	0	07/03/2020	06:06:51	312	Matilda (East)	311 Medical assist, assist EMS crew
20-0001576	0	07/03/2020	06:59:55	1304	Granada	611 Dispatched & cancelled en route
20-0001577	0	07/03/2020	10:35:56	122	Huntington	311 Medical assist, assist EMS crew
20-0001578	0	07/03/2020	13:47:16	816	Walnut Square	311 Medical assist, assist EMS crew
20-0001579	0	07/03/2020	14:04:51	1008	May	311 Medical assist, assist EMS crew
20-0001580	0	07/03/2020	15:37:05		Chattanooga	322 Motor vehicle accident with
20-0001581	0	07/03/2020	16:04:10	1007	Underwood	743 Smoke detector activation, no fire
20-0001582	0	07/03/2020	21:57:47	1507	Tibbs (North)	311 Medical assist, assist EMS crew
20-0001583	0	07/04/2020	10:52:52	2519	Turf	311 Medical assist, assist EMS crew
20-0001584	0	07/04/2020	12:37:47	1602	Anthony	611 Dispatched & cancelled en route
20-0001585	0	07/04/2020	17:29:52	912	Glenwood (North)	311 Medical assist, assist EMS crew
20-0001586	0	07/04/2020	21:40:30		North Bypass	611 Dispatched & cancelled en route
20-0001587	0	07/04/2020	22:07:20	601	Cockburn	311 Medical assist, assist EMS crew
20-0001588	0	07/05/2020	00:39:38	125	Andasol	311 Medical assist, assist EMS crew
20-0001589	0	07/05/2020	01:33:28	1003	MLK Jr.	311 Medical assist, assist EMS crew
20-0001590	0	07/05/2020	11:59:08	1002	Underwood	611 Dispatched & cancelled en route
20-0001591	0	07/05/2020	12:31:00	711	Hamilton (South)	311 Medical assist, assist EMS crew
20-0001592	0	07/05/2020	13:36:52	1000	Rockdale	311 Medical assist, assist EMS crew
20-0001593	0	07/05/2020	13:43:22	1218	Broadrick	311 Medical assist, assist EMS crew

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001594	0	07/05/2020	14:04:47	1300	Waugh (West)	311 Medical assist, assist EMS crew
20-0001595	0	07/05/2020	19:13:12		I-75 N. Bound	622 No Incident found on arrival at
20-0001596	0	07/05/2020	20:17:44		I-75 N. Bound	611 Dispatched & cancelled en route
20-0001597	0	07/05/2020	21:40:43	865	Holiday Inn	311 Medical assist, assist EMS crew
20-0001598	0	07/05/2020	21:44:22	1209	Georgian	311 Medical assist, assist EMS crew
20-0001599	0	07/05/2020	22:32:39	1320	Winton	311 Medical assist, assist EMS crew
20-0001600	0	07/06/2020	08:24:26	1447	Westover	311 Medical assist, assist EMS crew
20-0001601	0	07/06/2020	10:10:48		Glenwood (North)	322 Motor vehicle accident with
20-0001602	0	07/06/2020	15:41:26	405	Underwood	311 Medical assist, assist EMS crew
20-0001603	0	07/06/2020	16:55:52	824	Beirut	611 Dispatched & cancelled en route
20-0001604	0	07/06/2020	22:58:35	1919	David	311 Medical assist, assist EMS crew
20-0001605	0	07/06/2020	23:40:47	475	Reed	745 Alarm system activation, no fire -
20-0001606	0	07/07/2020	12:07:38	1308	Memorial	311 Medical assist, assist EMS crew
20-0001607	0	07/07/2020	15:19:41		Walnut (West)	622 No Incident found on arrival at
20-0001608	0	07/08/2020	00:09:04	824	Beirut	311 Medical assist, assist EMS crew
20-0001609	0	07/08/2020	05:35:10	618	Fifth	311 Medical assist, assist EMS crew
20-0001610	0	07/08/2020	07:24:24	606	Kenilworth	311 Medical assist, assist EMS crew
20-0001611	0	07/08/2020	10:40:16	1104	Orman	311 Medical assist, assist EMS crew
20-0001612	0	07/08/2020	11:35:44	2709	Airport	611 Dispatched & cancelled en route
20-0001613	0	07/08/2020	12:55:29	605	Woodland (West)	311 Medical assist, assist EMS crew
20-0001614	0	07/08/2020	15:55:32	2650	Abutment	611 Dispatched & cancelled en route
20-0001615	0	07/08/2020	16:25:25	803	Tibbs (North)	311 Medical assist, assist EMS crew
20-0001616	0	07/08/2020	16:38:40	1110	Burleyson	611 Dispatched & cancelled en route
20-0001617	0	07/08/2020	17:20:37	711	Hamilton (South)	611 Dispatched & cancelled en route
20-0001618	0	07/08/2020	18:24:16	225	Westerly	622 No Incident found on arrival at
20-0001619	0	07/08/2020	18:19:58	606	Silver	311 Medical assist, assist EMS crew
20-0001620	0	07/08/2020	20:50:09	1302	Woodsdale	311 Medical assist, assist EMS crew
20-0001621	0	07/08/2020	22:12:18	314	Sycamore	744 Detector activation, no fire -
20-0001622	0	07/09/2020	03:47:33	907	Hardwick	311 Medical assist, assist EMS crew
20-0001623	0	07/09/2020	04:37:29	713	Morris (East)	311 Medical assist, assist EMS crew
20-0001624	0	07/09/2020	10:36:32	1805	Shadow	311 Medical assist, assist EMS crew
20-0001625	0	07/09/2020	10:48:23	519	Hawthorne (West)	311 Medical assist, assist EMS crew

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001626	0	07/09/2020	11:56:06	1916 Fairfield	553 Public service	
20-0001627	0	07/09/2020	12:59:44	836 McAfee	311 Medical assist, assist EMS crew	
20-0001628	0	07/09/2020	18:53:04	1331 Walnut (West)	743 Smoke detector activation, no fire	
20-0001629	0	07/09/2020	19:07:21	1203 Acme	311 Medical assist, assist EMS crew	
20-0001630	0	07/09/2020	19:15:17	100 Brothers	311 Medical assist, assist EMS crew	
20-0001631	0	07/09/2020	20:20:33	500 Thornton (South)	735 Alarm system sounded due to	
20-0001632	0	07/09/2020	21:54:49	1008 May	311 Medical assist, assist EMS crew	
20-0001633	0	07/10/2020	00:11:33	1007 Underwood	611 Dispatched & cancelled en route	
20-0001634	0	07/10/2020	04:18:30	908 Elk	731 Sprinkler activation due to	
20-0001635	0	07/10/2020	06:08:16	Walnut (East)	611 Dispatched & cancelled en route	
20-0001636	0	07/10/2020	08:53:20	2125 Walnut (East)	745 Alarm system activation, no fire -	
20-0001637	0	07/10/2020	12:13:50	1104 Walston	311 Medical assist, assist EMS crew	
20-0001638	0	07/10/2020	15:28:41	1030 Willowdale	311 Medical assist, assist EMS crew	
20-0001639	0	07/10/2020	17:58:42	1012 May	311 Medical assist, assist EMS crew	
20-0001640	0	07/10/2020	19:20:44	512 Abigail	311 Medical assist, assist EMS crew	
20-0001641	0	07/10/2020	22:46:35	881 Holiday Inn	311 Medical assist, assist EMS crew	
20-0001642	0	07/10/2020	23:41:44	I-75 S. Bound	324 Motor Vehicle Accident with no	
20-0001643	0	07/11/2020	02:23:36	Glenwood (North)	413 Oil or other combustible liquid	
20-0001644	0	07/11/2020	02:33:43	I-75 N. Bound	611 Dispatched & cancelled en route	
20-0001645	0	07/11/2020	07:22:01	609 Thornton (South)	311 Medical assist, assist EMS crew	
20-0001646	0	07/11/2020	10:55:59	Tibbs (North)	322 Motor vehicle accident with	
20-0001647	0	07/11/2020	12:41:48	136 Nickie	311 Medical assist, assist EMS crew	
20-0001648	0	07/11/2020	12:59:44	418 Spencer (North)	311 Medical assist, assist EMS crew	
20-0001649	0	07/11/2020	14:53:25	1011 Morris (East)	311 Medical assist, assist EMS crew	
20-0001650	0	07/11/2020	15:39:39	606 Silver	311 Medical assist, assist EMS crew	
20-0001651	0	07/11/2020	16:33:59	1737 Brighton	311 Medical assist, assist EMS crew	
20-0001652	0	07/11/2020	16:46:52	816 Walnut Square	611 Dispatched & cancelled en route	
20-0001653	0	07/12/2020	00:07:51	2224 Chattanooga	311 Medical assist, assist EMS crew	
20-0001654	0	07/12/2020	11:03:06	609 Thornton (South)	311 Medical assist, assist EMS crew	
20-0001655	0	07/13/2020	00:03:34	521 Selvidge St. (North)	311 Medical assist, assist EMS crew	
20-0001656	0	07/13/2020	00:40:35	1507 Tibbs (North)	311 Medical assist, assist EMS crew	
20-0001657	0	07/13/2020	00:55:00	818 Shugart	311 Medical assist, assist EMS crew	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001658	0	07/13/2020	14:46:18	906 Thornton (South)	611 Dispatched & cancelled en route	
20-0001659	0	07/13/2020	15:01:29	North Bypass	322 Motor vehicle accident with	
20-0001660	0	07/13/2020	19:35:06	1475 Westover	611 Dispatched & cancelled en route	
20-0001661	0	07/13/2020	20:59:10	1795 Carter	311 Medical assist, assist EMS crew	
20-0001662	0	07/13/2020	22:03:54	1110 Burleyson	311 Medical assist, assist EMS crew	
20-0001663	0	07/14/2020	07:58:37	815 Shugart	311 Medical assist, assist EMS crew	
20-0001664	0	07/14/2020	08:02:21	1411 Burgess	311 Medical assist, assist EMS crew	
20-0001665	0	07/14/2020	08:03:42	902 Sandy Dunes	311 Medical assist, assist EMS crew	
20-0001666	0	07/14/2020	14:52:05	1212 Broadrick	743 Smoke detector activation, no fire	
20-0001667	0	07/14/2020	16:59:56	304 Easterling (South)	311 Medical assist, assist EMS crew	
20-0001668	0	07/14/2020	18:52:27	1613 Beechland	311 Medical assist, assist EMS crew	
20-0001669	0	07/14/2020	21:53:22	626 Fourth	522 Water or steam leak	
20-0001670	0	07/14/2020	22:59:22	Chattanooga	322 Motor vehicle accident with	
20-0001671	0	07/15/2020	08:04:58	1903 Hamilton (South)	735 Alarm system sounded due to	
20-0001672	0	07/15/2020	09:59:09	501 Alice	441 Heat from short circuit (wiring),	
20-0001673	0	07/15/2020	11:44:41	441 Fourth	611 Dispatched & cancelled en route	
20-0001674	0	07/16/2020	03:52:05	711 Hamilton (South)	311 Medical assist, assist EMS crew	
20-0001675	0	07/16/2020	08:07:14	1923 Sourwood	311 Medical assist, assist EMS crew	
20-0001676	0	07/16/2020	11:16:36	905 Hamilton (South)	111 Building fire	\$1,200
20-0001677	0	07/16/2020	12:54:38	950 Riverbend	311 Medical assist, assist EMS crew	
20-0001678	0	07/16/2020	13:18:04	800 Thornton	311 Medical assist, assist EMS crew	
20-0001679	0	07/16/2020	13:30:56	501 Central	611 Dispatched & cancelled en route	
20-0001680	0	07/16/2020	14:01:08	1416 Walston	311 Medical assist, assist EMS crew	
20-0001681	0	07/16/2020	14:12:51	501 Central	611 Dispatched & cancelled en route	
20-0001682	0	07/16/2020	14:46:30	501 Central	611 Dispatched & cancelled en route	
20-0001683	0	07/16/2020	17:25:08	South Bypass	143 Grass fire	
20-0001684	0	07/16/2020	19:12:59	916 Lakeshore (West)	311 Medical assist, assist EMS crew	
20-0001685	0	07/16/2020	19:15:15	1812 Ridgefield	442 Overheated motor	
20-0001686	0	07/17/2020	05:50:47	637 Fireside	311 Medical assist, assist EMS crew	
20-0001687	0	07/17/2020	08:33:09	315 Bowen	500 Service Call, other	
20-0001688	0	07/17/2020	10:49:44	1001 Market	311 Medical assist, assist EMS crew	
20-0001689	0	07/17/2020	11:11:51	1109 Burleyson	744 Detector activation, no fire -	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001690	0	07/17/2020	12:35:04	205 Selvidge St. (North)	744 Detector activation, no fire -	
20-0001691	0	07/17/2020	14:11:04	1100 Boylston	311 Medical assist, assist EMS crew	
20-0001692	0	07/17/2020	15:49:14	I-75 S. Bound	132 Road freight or transport vehicle	\$75,000
20-0001693	0	07/17/2020	17:19:47	1617 Beechland	311 Medical assist, assist EMS crew	
20-0001694	0	07/17/2020	21:23:04	1104 Walston	611 Dispatched & cancelled en route	
20-0001695	0	07/17/2020	22:22:20	243 Hamilton (North)	311 Medical assist, assist EMS crew	
20-0001696	0	07/17/2020	23:43:34	415 Cedar	522 Water or steam leak	
20-0001697	0	07/18/2020	05:34:48	431 Cedar	311 Medical assist, assist EMS crew	
20-0001698	0	07/18/2020	08:47:20	2209 Raintree	311 Medical assist, assist EMS crew	
20-0001699	0	07/18/2020	08:52:19	1218 Broadrick	311 Medical assist, assist EMS crew	
20-0001700	0	07/18/2020	09:19:03	I-75 S. Bound	611 Dispatched & cancelled en route	
20-0001701	0	07/18/2020	09:20:31	338 I-75 S. Bound	322 Motor vehicle accident with	
20-0001702	0	07/18/2020	12:14:46	Hamilton (South)	444 Power line down	
20-0001703	0	07/18/2020	12:39:48	885 Shugart	322 Motor vehicle accident with	
20-0001704	0	07/18/2020	12:50:06	Chattanooga	322 Motor vehicle accident with	
20-0001705	0	07/18/2020	13:11:07	2128 Chatham	142 Brush or brush-and-grass mixture	\$500
20-0001706	0	07/18/2020	14:11:34	1916 Fairington	743 Smoke detector activation, no fire	
20-0001707	0	07/18/2020	19:43:35	609 Thornton (South)	311 Medical assist, assist EMS crew	
20-0001708	0	07/18/2020	22:10:56	Dixie (South)	622 No Incident found on arrival at	
20-0001709	0	07/19/2020	00:12:30	1015 Lakeshore (East)	311 Medical assist, assist EMS crew	
20-0001710	0	07/19/2020	01:06:03	132 Levi	311 Medical assist, assist EMS crew	
20-0001711	0	07/19/2020	01:45:12	1104 Willowdale	553 Public service	
20-0001712	0	07/19/2020	04:02:55	1015 Lakeshore (East)	311 Medical assist, assist EMS crew	
20-0001713	0	07/19/2020	09:36:47	101 Cappes	622 No Incident found on arrival at	
20-0001714	0	07/19/2020	14:59:08	1208 Frazier	743 Smoke detector activation, no fire	
20-0001715	0	07/19/2020	16:17:26	MM I-75 N. Bound	611 Dispatched & cancelled en route	
20-0001716	0	07/19/2020	16:43:34	702 Emmons	611 Dispatched & cancelled en route	
20-0001717	0	07/19/2020	17:57:45	1435 Heather	311 Medical assist, assist EMS crew	
20-0001718	0	07/19/2020	21:13:12	1306 Underwood	311 Medical assist, assist EMS crew	
20-0001719	0	07/19/2020	23:40:16	1015 Lakeshore (East)	611 Dispatched & cancelled en route	
20-0001720	0	07/20/2020	04:11:40	1707 Willow Oak	311 Medical assist, assist EMS crew	
20-0001721	0	07/20/2020	07:49:39	Memorial	743 Smoke detector activation, no fire	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001722	0	07/20/2020	12:48:50	1318 Underwood	131 Passenger vehicle fire	\$1,000
20-0001723	0	07/20/2020	14:16:21	1306 Rio Vista	311 Medical assist, assist EMS crew	
20-0001724	0	07/20/2020	21:23:42	1386 Lida	311 Medical assist, assist EMS crew	
20-0001725	0	07/21/2020	02:41:57	1000 Manly	311 Medical assist, assist EMS crew	
20-0001726	0	07/21/2020	02:56:50	1304 Georgian	251 Excessive heat, scorch burns with	
20-0001727	0	07/21/2020	05:07:56	2120 Holly	311 Medical assist, assist EMS crew	
20-0001728	0	07/21/2020	05:15:43	1800 Underwood	311 Medical assist, assist EMS crew	
20-0001729	0	07/21/2020	06:20:23	300 Autumn	311 Medical assist, assist EMS crew	
20-0001730	0	07/21/2020	12:11:24	1916 Fairington	743 Smoke detector activation, no fire	
20-0001731	0	07/21/2020	12:50:52	I-75 N. Bound	611 Dispatched & cancelled en route	
20-0001732	0	07/21/2020	15:37:29	1320 Winton	311 Medical assist, assist EMS crew	
20-0001733	0	07/21/2020	15:49:19	1706 Brandywine	311 Medical assist, assist EMS crew	
20-0001734	0	07/21/2020	16:33:20	1306 Georgian	311 Medical assist, assist EMS crew	
20-0001735	0	07/21/2020	17:45:51	1008 May	311 Medical assist, assist EMS crew	
20-0001736	0	07/21/2020	18:48:14	806 Dogwood	746 Carbon monoxide detector	
20-0001737	0	07/21/2020	23:25:52	1220 Broadrick	734 Heat detector activation due to	
20-0001738	0	07/22/2020	03:36:06	550 Callahan	745 Alarm system activation, no fire -	
20-0001739	0	07/22/2020	04:19:30	824 Beirut	311 Medical assist, assist EMS crew	
20-0001740	0	07/22/2020	11:49:59	1502 Thornton (North)	311 Medical assist, assist EMS crew	
20-0001741	0	07/22/2020	14:06:16	600 Spring	444 Power line down	
20-0001742	0	07/22/2020	14:31:48	1010 Vista	741 Sprinkler activation, no fire -	
20-0001743	0	07/22/2020	14:50:32	608 Silver	611 Dispatched & cancelled en route	
20-0001744	0	07/22/2020	16:03:42	418 Chattanooga	444 Power line down	\$4,500
20-0001745	0	07/22/2020	16:49:03	1015 Lakeshore (East)	311 Medical assist, assist EMS crew	
20-0001746	0	07/22/2020	17:02:17	475 Reed	735 Alarm system sounded due to	
20-0001747	0	07/22/2020	20:40:20	2681 Underwood	311 Medical assist, assist EMS crew	
20-0001748	0	07/22/2020	22:15:26	2305 Abutment	311 Medical assist, assist EMS crew	
20-0001749	0	07/23/2020	05:47:38	1116 Willowdale	311 Medical assist, assist EMS crew	
20-0001750	0	07/23/2020	11:48:23	1010 Vista	745 Alarm system activation, no fire -	
20-0001751	0	07/23/2020	13:16:48	I-75 N. Bound	611 Dispatched & cancelled en route	
20-0001752	0	07/23/2020	21:02:39	Cross Plains	311 Medical assist, assist EMS crew	
20-0001753	0	07/23/2020	21:25:02	2311 Dug Gap	622 No Incident found on arrival at	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location		Incident Type		Est Loss
20-0001754	0	07/24/2020	02:42:58	509	Crawford (West)	311	Medical assist, assist EMS crew	
20-0001755	0	07/24/2020	03:13:30	612	Dantzler	311	Medical assist, assist EMS crew	
20-0001756	0	07/24/2020	10:39:10	818	J & J	443	Breakdown of light ballast	
20-0001757	0	07/24/2020	11:12:58	205	Selvidge St. (North)	251	Excessive heat, scorch burns with	
20-0001758	0	07/24/2020	11:18:57		Chattanooga	622	No Incident found on arrival at	
20-0001759	0	07/24/2020	11:22:24	869	College	611	Dispatched & cancelled en route	
20-0001760	0	07/24/2020	12:33:31		MLK Jr.	324	Motor Vehicle Accident with no	
20-0001761	0	07/24/2020	18:16:16	341	I-75 S. Bound	611	Dispatched & cancelled en route	
20-0001762	0	07/24/2020	21:10:05	1012	May	311	Medical assist, assist EMS crew	
20-0001763	0	07/25/2020	04:18:09	600	Walnut (West)	311	Medical assist, assist EMS crew	
20-0001764	0	07/25/2020	04:19:49	1907	Chattanooga	311	Medical assist, assist EMS crew	
20-0001765	0	07/25/2020	06:50:14	807	Underwood	311	Medical assist, assist EMS crew	
20-0001766	0	07/25/2020	07:41:31	2311	Chattanooga	651	Smoke scare, odor of smoke	
20-0001767	0	07/25/2020	09:04:25	519	Hawthorne (West)	311	Medical assist, assist EMS crew	
20-0001768	0	07/25/2020	09:13:23	MM337	I-75 N. Bound	322	Motor vehicle accident with	
20-0001769	0	07/25/2020	11:57:22	1406	Stacy	311	Medical assist, assist EMS crew	
20-0001770	0	07/25/2020	15:09:44		I-75 S. Bound	322	Motor vehicle accident with	
20-0001771	0	07/25/2020	16:42:41	612	Dantzler	311	Medical assist, assist EMS crew	
20-0001772	0	07/25/2020	17:36:17		Glenwood (North)	445	Arcing, shorted electrical	
20-0001773	0	07/25/2020	20:08:40	1320	Morris (East)	311	Medical assist, assist EMS crew	
20-0001774	0	07/25/2020	22:22:31	1335	Crescent	311	Medical assist, assist EMS crew	
20-0001775	0	07/25/2020	23:24:20	1502	Anthony	311	Medical assist, assist EMS crew	
20-0001776	0	07/25/2020	23:31:49	591	Stillwood	311	Medical assist, assist EMS crew	
20-0001777	0	07/25/2020	23:34:36	319	Hamilton (North)	743	Smoke detector activation, no fire	
20-0001778	0	07/26/2020	02:40:06	1068	Dozier	311	Medical assist, assist EMS crew	
20-0001779	0	07/26/2020	06:24:13	2005	Chatham	733	Smoke detector activation due to	
20-0001780	0	07/26/2020	06:33:07	410	Jennifer	736	CO detector activation due to	
20-0001781	0	07/26/2020	11:36:16	869	Holiday Inn	311	Medical assist, assist EMS crew	
20-0001782	0	07/26/2020	14:24:38	1212	Broadrick	311	Medical assist, assist EMS crew	
20-0001783	0	07/26/2020	16:25:21		Rowena	311	Medical assist, assist EMS crew	
20-0001784	0	07/26/2020	16:54:57	806	Jamestown	311	Medical assist, assist EMS crew	
20-0001785	0	07/26/2020	18:05:39		Cleveland	611	Dispatched & cancelled en route	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001786	0	07/26/2020	18:26:25	835 Shugart	311 Medical assist, assist EMS crew	
20-0001787	0	07/26/2020	18:40:43	1275 Cross Plains	311 Medical assist, assist EMS crew	
20-0001788	0	07/26/2020	20:37:02	811 Riverbend	324 Motor Vehicle Accident with no	
20-0001789	0	07/26/2020	21:42:57	1619 Crow Valley	611 Dispatched & cancelled en route	
20-0001790	0	07/26/2020	21:53:24	Thornton (North)	311 Medical assist, assist EMS crew	
20-0001791	0	07/27/2020	00:48:11	308 Tarver	311 Medical assist, assist EMS crew	
20-0001792	0	07/27/2020	05:58:23	1210 Royal	311 Medical assist, assist EMS crew	
20-0001793	0	07/27/2020	07:36:29	820 Riverbend	311 Medical assist, assist EMS crew	
20-0001794	0	07/27/2020	12:00:34	205 Boring	611 Dispatched & cancelled en route	
20-0001795	0	07/27/2020	12:15:25	1001 Willow Park Lane	561 Unauthorized burning	
20-0001796	0	07/27/2020	12:28:37	1116 Willowdale	611 Dispatched & cancelled en route	
20-0001797	0	07/27/2020	13:31:48	911 Clark	311 Medical assist, assist EMS crew	
20-0001798	0	07/27/2020	13:44:54	1907 Chattanooga	611 Dispatched & cancelled en route	
20-0001799	0	07/27/2020	14:16:51	543 Callahan	745 Alarm system activation, no fire	-
20-0001800	0	07/27/2020	16:28:28	Morris (East)	322 Motor vehicle accident with	
20-0001801	0	07/27/2020	17:40:39	312 Matilda (East)	311 Medical assist, assist EMS crew	
20-0001802	0	07/27/2020	19:51:55	711 Hamilton (South)	311 Medical assist, assist EMS crew	
20-0001803	0	07/27/2020	21:01:57	Veterans	311 Medical assist, assist EMS crew	
20-0001804	0	07/27/2020	22:28:35	1616 Beechland	311 Medical assist, assist EMS crew	
20-0001805	0	07/28/2020	00:21:19	1507 Tibbs (North)	311 Medical assist, assist EMS crew	
20-0001806	0	07/28/2020	06:20:00	416 Glenwood (North)	311 Medical assist, assist EMS crew	
20-0001807	0	07/28/2020	10:36:37	2450 Abutment	622 No Incident found on arrival at	
20-0001808	0	07/28/2020	10:53:32	824 Beirut	311 Medical assist, assist EMS crew	
20-0001809	0	07/28/2020	12:59:15	Chattanooga	322 Motor vehicle accident with	
20-0001810	0	07/28/2020	15:16:56	315 Sycamore	311 Medical assist, assist EMS crew	
20-0001811	0	07/28/2020	17:04:29	I-75 N. Bound	611 Dispatched & cancelled en route	
20-0001812	0	07/28/2020	17:24:00	Threadmill	324 Motor Vehicle Accident with no	
20-0001813	0	07/28/2020	22:55:48	1901 Middle Summit	311 Medical assist, assist EMS crew	
20-0001814	0	07/28/2020	23:06:35	1116 Willowdale	311 Medical assist, assist EMS crew	
20-0001815	0	07/29/2020	07:00:51	Walnut (East)	611 Dispatched & cancelled en route	
20-0001816	0	07/29/2020	07:12:23	1015 Delaware	611 Dispatched & cancelled en route	
20-0001817	0	07/29/2020	09:16:34	1218 Broadrick	743 Smoke detector activation, no fire	

DALTON

Incident List by Incident Number w/Est Loss (Month)

Alarm Date Between {07/01/2020} And {07/31/2020}

Incident	Exp	Alm Date	Time	Location	Incident Type	Est Loss
20-0001818	0	07/29/2020	13:16:45	902 Park Canyon	311 Medical assist, assist EMS crew	
20-0001819	0	07/29/2020	13:58:06	1500 Manly	311 Medical assist, assist EMS crew	
20-0001820	0	07/29/2020	14:34:29	712 Jackson	611 Dispatched & cancelled en route	
20-0001821	0	07/29/2020	15:22:32	1000 Vista	611 Dispatched & cancelled en route	
20-0001822	0	07/29/2020	17:33:31	2100 Threadmill	322 Motor vehicle accident with	
20-0001823	0	07/29/2020	18:55:49	1365 Walnut (West)	322 Motor vehicle accident with	
20-0001824	0	07/29/2020	19:59:59	608 Silver	311 Medical assist, assist EMS crew	
20-0001825	0	07/29/2020	21:42:04	875 Shugart	412 Gas leak (natural gas or LPG)	
20-0001826	0	07/30/2020	07:32:11	1225 Valencia	743 Smoke detector activation, no fire	
20-0001829	0	07/30/2020	14:59:00	1208 Frazier	735 Alarm system sounded due to	
20-0001830	0	07/30/2020	18:54:58	815 Shugart	311 Medical assist, assist EMS crew	
20-0001831	0	07/30/2020	19:27:09	North Bypass	611 Dispatched & cancelled en route	
20-0001832	0	07/30/2020	19:41:08	705 Arbella	311 Medical assist, assist EMS crew	
20-0001833	0	07/30/2020	22:11:20	442 Hamilton (North)	743 Smoke detector activation, no fire	
20-0001834	0	07/30/2020	23:09:42	1909 Walnut (East)	611 Dispatched & cancelled en route	
20-0001835	0	07/30/2020	23:11:02	612 Fifth	311 Medical assist, assist EMS crew	
20-0001836	0	07/31/2020	00:21:50	338 I-75 N. Bound	611 Dispatched & cancelled en route	
20-0001837	0	07/31/2020	08:27:25	1709 Briarcliff	311 Medical assist, assist EMS crew	
20-0001838	0	07/31/2020	14:16:13	2475 Abutment	311 Medical assist, assist EMS crew	
20-0001839	0	07/31/2020	19:21:23	2225 Walnut (East)	651 Smoke scare, odor of smoke	
20-0001840	0	07/31/2020	19:31:04	700 Phoenix	311 Medical assist, assist EMS crew	
20-0001841	0	07/31/2020	20:06:19	1100 Riverbend	311 Medical assist, assist EMS crew	
20-0001842	0	07/31/2020	20:38:48	100 Walnut (West)	441 Heat from short circuit (wiring),	
20-0001843	0	07/31/2020	22:35:12	1200 Memorial	733 Smoke detector activation due to	
20-0001844	0	07/31/2020	22:36:05	612 Callahan	324 Motor Vehicle Accident with no	

Total Incident Count 281

Total Est Loss

\$82,200

DALTON**Incident Type Period Comparisons****Alarm Date Between {07/01/2020} and {07/31/2020}**

Incident Type	07/01/2020	07/01/2019	07/01/2018	07/01/2017
	to	to	to	to
	07/31/2020	07/31/2019	07/31/2018	07/31/2017
100 Fire, Other	0	1	0	0
111 Building fire	1	4	2	6
113 Cooking fire, confined to container	0	1	0	3
123 Fire in portable building, fixed location	0	1	0	1
131 Passenger vehicle fire	1	0	2	2
132 Road freight or transport vehicle fire	1	0	0	0
140 Natural vegetation fire, Other	0	1	0	0
142 Brush or brush-and-grass mixture fire	2	0	1	0
143 Grass fire	1	1	0	0
151 Outside rubbish, trash or waste fire	0	0	2	1
154 Dumpster or other outside trash receptacle fire	0	0	2	1
251 Excessive heat, scorch burns with no ignition	2	1	0	0
311 Medical assist, assist EMS crew	150	217	208	207
322 Motor vehicle accident with injuries	15	15	12	2
323 Motor vehicle/pedestrian accident (MV Ped)	0	0	2	0
324 Motor Vehicle Accident with no injuries	5	6	5	2
341 Search for person on land	0	0	1	0
350 Extrication, rescue, Other	0	1	1	0
352 Extrication of victim(s) from vehicle	0	1	1	0
353 Removal of victim(s) from stalled elevator	0	2	0	0
360 Water & ice-related rescue, other	0	0	2	0
363 Swift water rescue	0	0	0	1
411 Gasoline or other flammable liquid spill	1	0	3	0
412 Gas leak (natural gas or LPG)	1	3	2	3
413 Oil or other combustible liquid spill	1	0	0	2
421 Chemical hazard (no spill or leak)	0	0	1	0
422 Chemical spill or leak	0	0	1	0
424 Carbon monoxide incident	0	0	1	1
441 Heat from short circuit (wiring), defective/worn	2	0	0	0
442 Overheated motor	1	0	0	0

DALTON**Incident Type Period Comparisons****Alarm Date Between {07/01/2020} and {07/31/2020}**

Incident Type	07/01/2020	07/01/2019	07/01/2018	07/01/2017
	to	to	to	to
	07/31/2020	07/31/2019	07/31/2018	07/31/2017
443 Breakdown of light ballast	1	0	0	0
444 Power line down	3	1	2	5
445 Arcing, shorted electrical equipment	1	2	1	2
461 Building or structure weakened or collapsed	0	1	0	1
500 Service Call, other	1	1	0	0
510 Person in distress, Other	0	1	0	1
511 Lock-out	0	0	0	1
522 Water or steam leak	2	3	0	1
531 Smoke or odor removal	0	0	3	0
551 Assist police or other governmental agency	0	2	0	1
552 Police matter	0	1	0	0
553 Public service	3	2	0	1
561 Unauthorized burning	1	1	2	0
600 Good intent call, Other	0	1	1	1
611 Dispatched & cancelled en route	45	30	30	32
622 No Incident found on arrival at dispatch address	8	7	7	2
631 Authorized controlled burning	0	0	0	1
651 Smoke scare, odor of smoke	2	2	1	2
652 Steam, vapor, fog or dust thought to be smoke	0	0	1	0
661 EMS call, party transported by non-fire agency	0	0	0	1
671 HazMat release investigation w/no HazMat	0	1	0	0
711 Municipal alarm system, malicious false alarm	0	0	1	1
715 Local alarm system, malicious false alarm	0	0	0	1
731 Sprinkler activation due to malfunction	1	0	0	1
732 Extinguishing system activation due to	0	0	2	0
733 Smoke detector activation due to malfunction	2	6	7	8
734 Heat detector activation due to malfunction	1	2	0	0
735 Alarm system sounded due to malfunction	4	3	6	8
736 CO detector activation due to malfunction	1	0	0	0
740 Unintentional transmission of alarm, Other	0	1	0	0

DALTON

Incident Type Period Comparisons

Alarm Date Between {07/01/2020} and {07/31/2020}

Incident Type	07/01/2020	07/01/2019	07/01/2018	07/01/2017
	to	to	to	to
	07/31/2020	07/31/2019	07/31/2018	07/31/2017
741 Sprinkler activation, no fire - unintentional	1	3	0	1
743 Smoke detector activation, no fire -	11	10	12	13
744 Detector activation, no fire - unintentional	3	1	1	0
745 Alarm system activation, no fire - unintentional	5	5	10	10
746 Carbon monoxide detector activation, no CO	1	0	0	0
Totals	281	342	336	327

Dalton Fire Department

Monthly Emergency Response Time Analysis

Emergency Responses

Response		Count	Percentage
Hrs	Mins		
< 01		8	2.6%
01		41	13.5%
02		70	23.1%
03		81	26.7%
04		54	17.8%
05		25	8.2%
06		12	3.9%
07		6	1.9%
08		3	0.9%
09		2	0.6%
11		1	0.3%

Overall Average Response Time: 00:03:35

Dalton Fire Department

Monthly Non-Emergency Response Time Analysis

Non-Emergency Responses

Response		Count	Percentage
Hrs	Mins		
< 01		1	2.0%
01		3	6.0%
02		8	16.0%
03		12	24.0%
04		6	12.0%
05		5	10.0%
06		1	2.0%
07		4	8.0%
08		7	14.0%
09		1	2.0%
10		1	2.0%
12		1	2.0%

Overall Average Response Time: 00:05:00

**Dalton Fire Department
Medical Incident Study
EMS On scene/Not on scene Prior to DFD Comparison
7/1/20 –7/31/20**

Total incidents in time period – 170

EMS on-scene prior to DFD – 60

EMS not on-scene prior – 120

During the month of July, Dalton Fire Department arrived on-scene prior to Hamilton EMS on 70% of medical responses.

Training Division Monthly Report

July 2020

Overview

A course addressing updates to radio communications equipment was delivered to all suppression personnel. Dalton Police Department delivered a course on active threat response and tactical movement that included scenario-based evolutions conducted at Brookwood Elementary School. Members of the department's technical rescue team delivered a unit on confined space awareness to Dalton Public Works personnel. Sessions 3 and 4 of a 40-hour EMT/Paramedic refresher course were delivered to all licensed medical providers. The department hosted week 2 of Georgia Fire Academy's 80-hour Fire Department Management course with 12 students completing the course and gaining NPQ Fire Officer 2 certification. The department conducted its first ever NPQ test for pumping apparatus driver operator with 12 candidates challenging the exam. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of July totaled 2,686.

Outside Schools

5 DFD personnel attended Preparation for Initial Company Operations at Gordon County Fire Department.

2 DFD personnel attended Strategy & Tactics for Initial Company Operations at Gordon County Fire Department.

2 DFD personnel attended Decision Making for Initial Company Operations at Gordon County Fire Department.

1 company officer attended the National Fire Academy's Executive Skills Series course on leadership to facilitate adaptive change at GPSTC.

Support Functions

- 172 hours were spent completing apparatus checks and equipment replenishment
- Cleaning and maintenance activities accounted for 912 hours in July
- 33 hours were attributed to hydrant detail
- 3 hours were dedicated to fire investigation and related activities
- SCBA maintenance consumed 17 hours during the month

Prevention Division Monthly Report

July 2020

Inspections

Annual Inspections	Total:	45
Apartment Inspections	Total:	
Site Inspections	Total:	48
Fire Alarm Inspection	Total:	2
Sprinkler System Inspection	Total:	1
New Kitchen Hood Inspections	Total:	
Knox Box Installation	Total:	2
Occupational Tax Certificate Inspections	Total:	16
Alcohol Inspections	Total:	
50 Percent Inspections	Total:	
80 Percent Inspections	Total:	3
100 Percent Inspections	Total:	
Pre-Incident Surveys	Total:	63
Plan Reviews	Total:	8
Addressing	Total:	1
Total Inspections		189

Public Relations

Fire Safety Education		
Events	Total:	4
Staff Members Participated	Total:	12
Staff Hours	Total:	17
Number of Adults Reached	Total:	312
Number of Children Reached	Total:	216
Total Residents Reached		528

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
200 INSPECTION - Annual				
07/13/2020	13:50	20788 John Kiker Construction 855 Abutment RD /Suite 5	0.02	
07/13/2020	15:10	20784 World Floor Covering Association 855 Abutment RD /Suite 1	0.02	
07/02/2020	10:12	20814 Waffle House 2505 Walnut (East) AVE	0.19	
07/06/2020	10:23	20007 Gill's Grill 1511 Abutment RD	0.09	
07/06/2020	11:06	20075 American Industrial Product 2450 Abutment RD /Suite 3	0.06	
07/06/2020	10:59	20216 Doteco 2450 Abutment RD /Suite 7	0.09	
07/06/2020	11:14	20041 Emcor Services 2450 Abutment RD /Suite 1 & 2	1.36	
07/06/2020	10:20	20256 Generation Green Recycling 2488 Abutment RD	0.21	
07/06/2020	10:54	20218 Essex Inc. 2450 Abutment RD /Suite 6	0.08	
07/07/2020	10:13	20010 Shaw Plant DM/LS 1627/31 Abutment RD	0.11	
07/07/2020	10:20	20301 N.W. Ga Family Crisis Center 136 Nickie DR	0.39	
07/07/2020	10:05	20724 The Battle Grounds 2708 Airport RD /1	0.32	
07/10/2020	13:57	20686 Innervention 515 Benjamin WAY /suites 300 &302	0.03	
07/10/2020	14:07	20690 Hamilton Home Health and Hospice 517 Benjamin WAY /517/400-406	0.10	
07/10/2020	14:00	20687 Whitfield County Republican Party 515 Benjamin WAY /suites 304 &306	0.02	
07/09/2020	10:50	20558 Affordable Vision 1805 Walnut (East) AVE	0.01	
07/10/2020	07:56	10535 Carniceria Nacho Underwood ST	0.75	
07/14/2020	08:00	20249 Milliken Industries 2410 Abutment RD	0.80	
07/14/2020	08:22	20785 Floor Covering Industry Foundation 855 Abutment RD /Suite 2	0.01	
07/14/2020	08:18	2P005 The 855 Building 855 Abutment RD /Suite 6	0.01	

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
200 INSPECTION - Annual				
07/14/2020	08:21	20786 EF Floors & Design 855 Abutment RD /Suite 3	0.01	
07/14/2020	08:15	20789 Neo Graphics 855 Abutment RD /Suite 6	0.05	
07/14/2020	12:47	20483 Bargain Hunt 2121 Walnut (East) AVE	0.14	
07/14/2020	10:27	20751 Harbor Freight Tools 2125 Walnut (East) AVE	0.20	
07/16/2020	13:55	20258 Advanced Machine Tech /Quality Spring 2600 Abutment RD	0.11	
07/16/2020	09:29	10184 Morris Innovative High School 104 Fort Hill TER	0.46	
07/16/2020	10:41	10687 Blue Ridge Elementary Schools 100 Bogle (South) ST	0.21	
07/16/2020	11:09	50089 Park Creek Elementary School 1500 Hale-Bowen DR	0.63	
07/17/2020	09:35	50004 Dalton Middle School 1250 Cross Plains TRL	1.55	
07/20/2020	13:57	20254 Leading the Way Transport 2473 Abutment RD	0.06	
07/20/2020	10:07	50137 Christian Heritage High School 1601 MLK Jr. BLVD	0.52	
07/20/2020	13:36	50094 Christian Heritage Elementary School 1600 MLK Jr. BLVD	0.66	
07/21/2020	13:19	10799 Northstar School 307 Fredrick (South) ST	1.22	
07/24/2020	13:09	10524 Westwood Elementary School 708 Trammell ST	0.24	
07/24/2020	15:23	20091 Brookwood Elementary School 501 Central AVE	0.09	
07/24/2020	08:02	10440 Roan Street Elementary School 1116 Roan ST	0.68	
07/27/2020	09:03	40139 Seventh Day Adventist/Learning Tree 300 Tibbs (South) RD	0.09	
07/28/2020	10:08	20717 Walgreens 2225 Walnut (East) AVE	0.13	
07/28/2020	10:30	10280 Tasker's Barber and Salon 310 Hamilton (South) ST	0.12	
07/28/2020	12:42	10070 City Park School 405 School ST	1.89	

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
200 INSPECTION - Annual				
07/28/2020	11:34	10355 Dalton High School 1500 Manly ST	1.08	
07/29/2020	13:10	2P020 Foster Plaza 2705 Airport RD	0.12	
07/30/2020	13:46	10479 Dalton Public Schools IT 101 Thornton (North) AVE	0.15	
07/30/2020	14:06	50094 Christian Heritage Elementary School 1600 MLK Jr. BLVD	0.01	
07/30/2020	14:05	50137 Christian Heritage High School 1601 MLK Jr. BLVD	0.01	
Total Activities for Type:				15.10

210 INSPECTION - Site Inspection

07/29/2020	10565 Saint Joseph Clinic 1102 Waugh (West) ST	0.00
07/29/2020	40096 Fairfield Inn & Suites 786 College DR	0.00
07/14/2020	40088 Moe's 1507 Walnut (West) AVE /Suite 1	0.00
07/28/2020	50151 Hammond Creek Middle School 330 Pleasant Grove DR NE	0.00
07/27/2020	50053 Kroger 1205 Glenwood (North) AVE /Suite 5	0.00
07/27/2020	20513 Gimmie A 5 880 Walnut Square BLVD	0.00
07/27/2020	20664 Hot Topic 816 Walnut Square BLVD /Suite 39	0.00
07/27/2020	10233 Vacant 323 Hamilton (North) ST	0.00
07/27/2020	40059 Kroger 1365 Walnut (West) AVE	0.00
07/27/2020	30205 Wal-Mart 815 Shugart RD	0.00
07/27/2020	20054 Plaza Georgia 310 Brookhollow Ind. BLVD	0.00
07/27/2020	40020 Holiday Inn Express 934 Market ST	0.00
07/27/2020	40096 Fairfield Inn & Suites 786 College DR	0.00

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
210 INSPECTION - Site Inspection				
07/27/2020		40059 Kroger 1365 Walnut (West) AVE		0.00
07/27/2020		40088 Moe's 1507 Walnut (West) AVE /Suite 1		0.00
07/26/2020	18:00	40059 Kroger 1365 Walnut (West) AVE		0.50
07/23/2020		10768 Eclectic 79 315 Morris (East) ST		0.00
07/24/2020	09:17	20585 CSL Plasma 902 Abutment RD		0.05
07/21/2020		40096 Fairfield Inn & Suites 786 College DR		0.00
07/21/2020		30269 Park Canyon Apartment Homes 284 Park Canyon DR		0.00
07/22/2020		40020 Holiday Inn Express 934 Market ST		0.00
07/22/2020		50027 Tiarco-RST 1010 Vista DR		0.00
07/22/2020		50004 Dalton Middle School 1250 Cross Plains TRL		0.00
07/17/2020	09:54	50135 Underwood Lodge 1306 Underwood ST		0.01
07/17/2020		20504 Cox's Apartments 905 Hamilton (South) ST		0.00
07/20/2020		10742 Stone Ridge Apartments 1104 Walston AVE		0.00
07/10/2020	10:48	20101 Servicios Latinos 908 Elk ST		0.44
07/10/2020		20685 Edge Hair Salon 513 Benjamin WAY /suites 212&214		0.00
07/16/2020		30269 Park Canyon Apartment Homes 284 Park Canyon DR		0.00
07/14/2020		10288 Sweet Spot 336 Hamilton (South) ST		0.00
07/10/2020	09:55	50004 Dalton Middle School 1250 Cross Plains TRL		0.01
07/10/2020	08:45	40020 Holiday Inn Express 934 Market ST		0.09
07/10/2020	08:21	3P003 Shugart Center 841 Shugart RD		0.09

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
210 INSPECTION - Site Inspection				
07/02/2020	10:10	10701 Park Place Apartments 510 Underwood ST	0.01	
07/02/2020	10:10	50006 Western Sizzlin 501 Legion DR	0.00	
07/08/2020		20703 Tortilleria El Comal 616 Fourth AVE /Suite 1	0.00	
07/07/2020		20370 Subway 906 Thornton (South) AVE /D	0.00	
07/07/2020		50036 Lowe's Home Center 1212 Glenwood (North) AVE	0.00	
07/07/2020		2P007 Dalton Mall 816 Walnut Square BLVD /Suite 2	0.00	
07/06/2020	09:49	10771 American Import Auto Parts LLC. 412 Hamilton (North) ST	0.20	
07/06/2020		20249 Milliken Industries 2410 Abutment RD	0.00	
07/06/2020		20248 Dalyn Rug Co. 2386 Abutment RD	0.00	
07/06/2020		20254 Leading the Way Transport 2473 Abutment RD	0.00	
07/04/2020	22:42	10785 Crescent City Tavern 324 S Depot ST	0.02	
07/04/2020	22:29	10807 Tenoch LLC 319 Hamilton (North) ST	0.20	
07/04/2020	22:55	40035 Oyster Pub 933 Market ST /Suite 12 B	0.03	
07/04/2020	22:57	10505 The Weaving Room 851 Chattanooga AVE	0.01	
Total Activities for Type: 47				1.66

211 INSPECTION - Plan Review

07/06/2020	20511 Awad Apartment 700 Morris (East) ST	0.00
07/07/2020	10537 Beautiful Smiles Dentistry 509 Thornton (South) AVE	0.00
07/10/2020	20585 CSL Plasma 902 Abutment RD	0.00
07/16/2020	30205 Wal-Mart 815 Shugart RD	0.00

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
211 INSPECTION - Plan Review				
07/12/2020		50151 Hammond Creek Middle School 330 Pleasant Grove DR NE		0.00
07/20/2020		50027 Tiarco-RST 1010 Vista DR		0.00
07/20/2020		10538 TMobile 2204 Walnut (East) AVE		0.00
07/21/2020		40012 Home 2 Suites 865 Holiday Inn DR		0.00
Total Activities for Type:			8	0.00
212 INSPECTION - Fireworks Display				
07/04/2020	17:28	50152 Heritage Point Park 1275 Cross Plains TRL		0.02
Total Activities for Type:			1	0.02
221 INSPECTION - Fire Alarm				
07/10/2020	09:37	20585 CSL Plasma 902 Abutment RD		0.70
07/22/2020		20585 CSL Plasma 902 Abutment RD		0.00
Total Activities for Type:			2	0.70
222 INSPECTION - Sprinkler System				
07/10/2020	09:55	50004 Dalton Middle School 1250 Cross Plains TRL		0.08
Total Activities for Type:			1	0.08
251 INSPECTION - Knox Box Installation				
07/21/2020		40058 H&R Block 1323 Walnut (West) AVE		0.00
07/27/2020		30104 Hamilton office 1432 Broadrick DR		0.00

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
251 INSPECTION - Knox Box Installation				
<hr/>				
Total Activities for Type: 2				0.00
<hr/>				
261 INSPECTION - OTC				
<hr/>				
07/28/2020	10:22	20335 G&A Auto Repair 1224 Morris (East) ST	0.06	
07/28/2020		40076 Broken Arrow Tattoo 1514 Walnut (West) AVE /Suite 1	0.00	
07/28/2020		10237 All Chem 437 Hamilton (North) ST	0.00	
07/21/2020		20585 CSL Plasma 902 Abutment RD	0.00	
07/22/2020	09:11	10042 Big Rig Lending 101 Crawford (East) ST /Suite 400	0.68	
07/30/2020	10:46	10321 Sumthin Southern LLC 116 King (West) ST	0.01	
07/30/2020		20146 Andor 419 Glenwood (South) AVE /Dalton, GA 30719	0.00	
07/09/2020	13:31	20451 AJV Enterprises Inc. 710 Hartwood ST	0.24	
07/20/2020	12:58	10380 Tienda Tony 911 Morris (East) ST /A	0.38	
07/02/2020	10:04	10792 Trinity Barbeque 825 Chattanooga AVE /34	2.11	
07/08/2020		50125 JAS Tobacco 601 Flemming ST /Suite A	0.00	
07/08/2020		50034 All Seasons Self Storage 1060 Vista DR	0.00	
07/02/2020	10:11	10188 Vacant 267 Hamilton (North) ST	0.00	
07/01/2020		10178 Bohemy Co Salon and Spa 205 Gordon (West) ST	0.00	
07/01/2020	10:00	10551 Bobby Pins Salon 106 Waugh (West) ST	0.20	
07/13/2020		50027 Tiarco-RST 1010 Vista DR	0.00	
Total Activities for Type: 16				3.68
<hr/>				

DALTON**Monthly Prevention Inspections by Type**

Date Completed Between {07/01/2020} And {07/31/2020}

Date	Time	Occupancy	Hrs	Fee
280 INSPECTION - 80				
07/17/2020	09:05	50004 Dalton Middle School 1250 Cross Plains TRL	0.28	
07/14/2020		10359 Hamilton Medical Center 1200 Memorial DR	0.00	
07/30/2020		10359 Hamilton Medical Center 1200 Memorial DR	0.00	
Total Activities for Type: 3				0.28

501 PRE-INCIDENT SURVEY

07/13/2020	50085 La Fiesta 1525 Cleveland HWY /Suite 3	0.00
07/13/2020	50086 La Fiesta 1525 Cleveland HWY /Suite 2 & 3	0.50
07/13/2020	50087 Pizza Hut 1525 Cleveland HWY /Suite 1	0.50
07/13/2020	50130 Vacant 1716 Cleveland HWY /300	0.50
07/13/2020	50138 Vacant 1716 Cleveland HWY /900	0.50
07/13/2020	50044 State Farm Insurance 1716 Cleveland HWY /100	0.50
07/13/2020	50139 Vacant 1716 Cleveland HWY /1000	0.50
07/13/2020	50045 DC Spa Retreat 1716 Cleveland RD /200	0.50
07/13/2020	50046 Dental Arts of Dalton 1716 Cleveland HWY /400	0.50
07/13/2020	50048 Intouch Computer Services 1716 Cleveland RD /600	0.50
07/13/2020	50049 Apex Spine Center 1716 Cleveland RD /700	0.50
07/13/2020	50050 Vacant 1716 Cleveland RD /800	0.50
07/13/2020	50047 Vacant 1716 Cleveland RD /500	0.50
07/13/2020	10191 Kellie Smith by Design 200 Hamilton (North) ST	0.00
07/13/2020	10192 The Cherry Tree 210 Hamilton (North) ST	0.00

DALTON**Monthly Prevention Inspections by Type**

**Date Completed Between {07/01/2020} And
{07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
501 PRE-INCIDENT SURVEY				
07/13/2020		10194 Dave and Pauli's Art Emporium 218 Hamilton (North) ST		0.00
07/13/2020		10195 Clark Davies and Easley 220 Hamilton (North) ST		0.00
07/13/2020		10197 North Georgia Regional Collection Agency 224 Hamilton (North) ST		0.00
07/13/2020		10198 Tease Salon 226 Hamilton (North) ST /2		0.00
07/13/2020		10199 Caleb Carnes PC 230 Hamilton (North) ST		0.00
07/13/2020		10200 Cyra's 234 Hamilton (North) ST		0.00
07/13/2020		10791 State Farm Insurance 236 Hamilton (North) ST		0.00
07/13/2020		10806 Casa Frida 238 Hamilton (North) ST		0.00
07/13/2020	13:00	10188 Vacant 267 Hamilton (North) ST		0.17
07/13/2020		10201 Corner Boutique 238 Hamilton (North) ST /Suite 2		0.00
07/13/2020		10753 Cafe` Ostro 240 Hamilton (North) ST		0.00
07/13/2020		10202 Escape Dalton 244 Hamilton (North) ST		0.00
07/13/2020	13:10	10226 Bugs and Kisses 265 Hamilton (North) ST		0.17
07/13/2020		10651 J.L.M. Properties 248 Hamilton (North) ST		0.00
07/13/2020		10767 Element Heating and Air 250 Hamilton (North) ST		0.00
07/13/2020		10203 Followers of Jesus Ministry Center 254 Hamilton (North) ST		0.00
07/13/2020		10204 Friends and Company 256 Hamilton (North) ST		0.00
07/13/2020	13:00	10233 Vacant 323 Hamilton (North) ST		0.00
07/13/2020		10205 Simply Outrageous Interior Design Studio 258 Hamilton (North) ST		0.00
07/13/2020		10193 Buckin' Burrito 212 Hamilton (North) ST		0.00

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
501 PRE-INCIDENT SURVEY				
07/13/2020	13:00	10807 Tenoch LLC 319 Hamilton (North) ST	0.00	
07/13/2020	13:00	10232 Southeastern Light & Electric 313 Hamilton (North) ST	0.25	
07/13/2020	13:20	10225 Fast Foto 261 Hamilton (North) ST	0.17	
07/13/2020	13:30	10224 Paper Princess 259 Hamilton (North) ST	0.17	
07/13/2020	13:00	10788 Carlson & Carlson 311 Hamilton (North) ST	0.25	
07/13/2020	13:00	10230 Affordable Sales and Rentals 309 Hamilton (North) ST	0.25	
07/13/2020	13:40	10222 Fantasy Factory 257 Hamilton (North) ST	0.17	
07/13/2020	13:00	10229 Bone Dry Guttering 307 Hamilton (North) ST	0.25	
07/13/2020	13:50	10223 Centers for Creative Learning 251 Hamilton (North) ST	0.17	
07/13/2020	13:00	10228 Southern Charm Clothing 305 Hamilton (North) ST	0.25	
07/13/2020	14:00	10221 BDH Insurance Solutions 247 Hamilton (North) ST	0.17	
07/13/2020	13:00	10227 A Touch Of Beauty 301 Hamilton (North) ST	0.25	
07/13/2020	13:00	10235 Bucket List Antiques 300 Hamilton (North) ST	0.25	
07/13/2020	13:00	10553 B&J Janitorial 100 Waugh (West) ST	0.25	
07/13/2020	13:00	10552 Rail Side Tattoo 102 Waugh (West) ST	0.25	
07/13/2020	14:10	10220 Oscar's 245 Hamilton (North) ST	0.17	
07/13/2020	13:00	10551 Bobby Pins Salon 106 Waugh (West) ST	0.25	
07/13/2020	14:20	10218 Kirkman and Associates 243 Hamilton (North) ST	0.17	
07/13/2020	13:00	10550 Dalton Stamp and Coin & Among Friends 110 Waugh (West) ST	0.25	
07/13/2020	14:30	10216 The Yellow Bird 235 Hamilton (North) ST	0.17	

DALTON**Monthly Prevention Inspections by Type****Date Completed Between {07/01/2020} And {07/31/2020}**

Date	Time	Occupancy	Hrs	Fee
501 PRE-INCIDENT SURVEY				
07/13/2020	14:40	10215 Vacant 229 Hamilton (North) ST	0.17	
07/13/2020	14:50	10214 Inglesia Misionera 225 Hamilton (North) ST	0.17	
07/13/2020	15:00	10217 Polishes Nail Salon 223 Hamilton (North) ST	0.17	
07/13/2020	15:10	10213 American National 223 Hamilton (North) ST	0.17	
07/13/2020	15:20	10211 The Anderson Company 217 Hamilton (North) ST	0.17	
07/13/2020	15:20	10209 The Anderson Company 211 Hamilton (North) ST	0.17	
07/13/2020	15:30	10208 Crutchfield's 209 Hamilton (North) ST	0.17	
07/13/2020		10196 Baja Coop 222 Hamilton (North) ST	0.00	
Total Activities for Type:			63	11.64

Grand Total Activities: 188**Grand Totals:** 33.16 0.00

DALTON**Monthly Prevention Violations by Occupancy****Violation Date Reported Between {07/01/2020} And {07/31/2020}**

20451 AJV Enterprises Inc.
 710 Hartwood ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/09/2020	2017 NFPA 25 5.2.1.1 Sprinkler system, Annual	1			0
	Notes: Need current inspection.				
07/09/2020	2018 IFC 315.3.3 Storage, combustibles not stored	1			0
	Notes: Clear area around riser.				
07/09/2020	2018 IFC 505.1 Address, in approved	1			0
	Notes: Add address to building.				
07/09/2020	2018 IFC 506.1 Knox Box, requirements met	1			0
	Notes: Add Knox Box to building.				
07/09/2020	2018 IFC 5704.3.4.4 Storage, flammable liquids	1			0
	Notes: Store correctly.				
07/09/2020	2018 IFC 906.2 MOD Fire extinguisher, properly	1			0
	Notes: Extinguishers must be inspected by a licensed contractor and mounted correctly.				
07/09/2020	2018 NFPA 101 7.1.10.1 MOE, maintained free and	1			0
	Notes: Door welded closed.				
07/09/2020	2018 NFPA 101 7.10.5.1 Exit sign, functional	1			0
	Notes: Repair or replace exit signs.				
07/09/2020	2018 NFPA 101 7.9.2.3 Emergency light, operates	1			0
	Notes: Repair or replace emergency lighting.				
07/09/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0
	Notes: Maintain separation between combustible materials and cutting welding area.				

Total Individual Violation Codes for Occupancy: 10

10042 Big Rig Lending
 101 Crawford (East) ST
 Suite 400
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/22/2020	2018 IFC 506.1 Knox Box, requirements met	1			0
	Notes: Key required to access RISER ROOM.				

* Denotes Violations Corrected or Variance Issued

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

10042 Big Rig Lending
 101 Crawford (East) ST
 Suite 400
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/22/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0
Notes: Install signage on RISER ROOM. Install FACP/ELECTRICAL ROOM signage.					

Total Individual Violation Codes for Occupancy: 2

10687 Blue Ridge Elementary Schools
 100 Bogle (South) ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/16/2020	2018 NFPA 101 7.10.5.1 Exit sign, functional	1			0
Notes: Repair or replace non-operational exit signage.					
07/16/2020	2018 NFPA 101 7.9.2.3 Emergency light, operates	1			0
Notes: Repair or replace non-operational emergency lighting.					

Total Individual Violation Codes for Occupancy: 2

10551 Bobby Pins Salon
 106 Waugh (West) ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/01/2020	2018 IFC 506.1 Knox Box, requirements met	1			0
Notes: Install required Knox Box.					

Total Individual Violation Codes for Occupancy: 1

20091 Brookwood Elementary School
 501 Central AVE
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

* Denotes Violations Corrected or Variance Issued

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

20091 **Brookwood Elementary School**
501 Central AVE
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/24/2020	2017 NFPA 25 13.8.1 FDC, caps in place	1			0
	Notes: Install caps on FDC.				
07/24/2020	2018 IFC 912.2.2 FDC, location marked correctly	1			0
	Notes: Install FDC signage.				
07/24/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0
	Notes: Install FACP sign on room containing fire alarm control panel.				

Total Individual Violation Codes for Occupancy: 3

10535 **Carniceria Nacho**
Underwood ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/10/2020	2017 NFPA 96 10.2.2 Class K placard required	1			0
	Notes: Install class K extinguisher placard.				
07/10/2020	2017 NFPA 96 11.2.1 Kitchen hood suppression	1			0
	Notes: Suppression system must be inspected by a GA licensed contractor.				
07/10/2020	2017 NFPA 96 6.2.3.3 Kitchen hood, grease	1			0
	Notes: Replace missing hood filters.				
07/10/2020	2018 IFC 305.1 Ignition sources, proper	1			0
	Notes: Cooking equipment must be located under a protected hood system.				
07/10/2020	2018 IFC 505.1 Address, in approved	1			0
	Notes: Install address signage.				
07/10/2020	2018 IFC 604.1 Electrical equipment, no hazards	1			0
	Notes: All electrical inspections and repairs require a permit must be made by a licensed electrician.				
	Extension cords shall not substitute permanent electrical wiring.				
07/10/2020	2018 IFC 604.3 Electrical panel, correct working	1			0
	Notes: Maintain 36" clearance around electrical panels.				
07/10/2020	2018 IFC 604.5 Extension cord, properly used	1			0
	Notes: Extension cords shall not substitute permanent electrical wiring.				

* Denotes Violations Corrected or Variance Issued

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

10535 Carniceria Nacho
Underwood ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/10/2020	2018 IFC 906.1 MOD Fire extinguisher, required	1			0
	Notes: Install fire extinguishers.				
07/10/2020	2018 IFC 906.2 MOD Fire extinguisher, properly	1			0
	Notes: Fire extinguishers require current annual inspection, performed by a GA licensed contractor.				
07/10/2020	2018 IMC 507.4.1 Cooking equipment, Proper	1			0
	Notes: All cooking devices must properly located.				
07/10/2020	2018 NFPA 101 7.10.1.2.1 Approved signage where	1			0
	Notes: Install exit signs				
07/10/2020	2018 NFPA 101 7.9.1.1 Emergency light, installed	1			0
	Notes: Install exit signs.				
07/10/2020	2018 NFPA 101 7.9.2.3 Emergency light, operates	1			0
	Notes: Install emergency lighting.				

Total Individual Violation Codes for Occupancy: 14

50094 Christian Heritage Elementary School
1600 MLK Jr. BLVD
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/20/2020	* 2018 IFC 315.3.3 Storage, combustibles not stored	1			0
	Notes: Maintain clearance around riser.				
07/20/2020	* 2018 IFC 315.3.3 Storage, combustibles not stored	1			0
	Notes: Recheck violation record automatically created from a recheck request.				
	Original Violation Remarks: Maintain clearance around riser.				

Total Individual Violation Codes for Occupancy: 2

50137 Christian Heritage High School
1601 MLK Jr. BLVD
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
* Denotes Violations Corrected or Variance Issued					
08/03/2020	07:33				

DALTON**Monthly Prevention Violations by Occupancy****Violation Date Reported Between {07/01/2020} And {07/31/2020}**

07/20/2020 * 2018 IFC 604.5 Extension cord, properly used	1	0
---	---	---

Notes: Cannot use extension cords for permanent wiring.

07/20/2020 * 2018 IFC 604.5 Extension cord, properly used	1	0
---	---	---

Notes: Recheck violation record automatically created from a recheck request.

Original Violation Remarks: Cannot use extension cords for permanent wiring.

Total Individual Violation Codes for Occupancy: 2

10070 **City Park School**
405 School ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/28/2020	2018 IFC 901.7 Fire protection system, in service	1			0
	Notes: Address alarm supervisory alert.				
07/28/2020	2018 NFPA 101 7.1.10.1 MOE, maintained free and	1			0
	Notes: Remove all storage from stairwells.				
07/28/2020	2019 NFPA 80 6.3.1.7.4 Firedoor, gap does not	1			0
	Notes: Ensure proper closure of all fire doors.				

Total Individual Violation Codes for Occupancy: 3

10355 **Dalton High School**
1500 Manly ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/28/2020	2017 NFPA 25 13.8.1 FDC, caps in place	1			0
	Notes: Install caps on all fire department connections.				
07/28/2020	2018 IFC 604.1 Electrical equipment, no hazards	1			0
	Notes: Maintain 36" clearance around all electrical panels.				
	Field house breaker panel housing cover must be properly mounted.				
07/28/2020	2018 IFC 912.2.2 FDC, location marked correctly	1			0
	Notes: Install FDC signage on all fire department connections.				
07/28/2020	2018 IFC 912.4.2 FDC, not blocked/obstructed	1			0
	Notes: FDC must remain unobstructed.				

* Denotes Violations Corrected or Variance Issued

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

10355 Dalton High School
1500 Manly ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/28/2020	2018 IMC 507.4.1 Cooking equipment, Proper	1			0
Notes: An exhaust hood, vented to the exterior of the structure, must be installed above the stove located in room 115.					
07/28/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0
Notes: Clothes dryers must be vented to the exterior of the structure.					

Total Individual Violation Codes for Occupancy: 6

50004 Dalton Middle School
1250 Cross Plains TRL
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/17/2020	2018 IFC 509.1 Riser room, marked with	1			0
Notes: Install signage on riser rooms.					
07/17/2020	2018 NFPA 101 7.9.2.3 Emergency light, operates	1			0
Notes: Repair or replace all non-operational emergency lighting.					

Total Individual Violation Codes for Occupancy: 2

10479 Dalton Public Schools IT
101 Thornton (North) AVE
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/30/2020	2018 IFC 604.1 Electrical equipment, no hazards	1			0
Notes: Maintain 36" clearance around electrical panels.					
07/30/2020	2018 IFC 604.3.1 Electrical equipment, properly	1			0
Notes: Install signage on second floor electrical room.					

Total Individual Violation Codes for Occupancy: 2

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

10768 Eclectic 79
315 Morris (East) ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/23/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0

Notes: Storage and display of upholstered furniture exceeds square footage amounts in an unsprinklered building.

Electrical issues including exposed wiring and spliced electrical cords being used for the extension of wiring connected to lighting being used.

Total Individual Violation Codes for Occupancy: 1

10359 Hamilton Medical Center
1200 Memorial DR
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/14/2020	2018 NFPA 101 8.3.1.2 Fire Barrier, meets	1			0

Notes: Expansion joint not complete.

07/14/2020	2018 NFPA 101 9.6.1.1 Fire alarm , installed	1			0
------------	--	---	--	--	---

Notes: Fire dampers failed test.

Total Individual Violation Codes for Occupancy: 2

10184 Morris Inovative High School
104 Fort Hill TER
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/16/2020	2018 IFC 604.1 Electrical equipment, no hazards	1			0

Notes: Install light switch cover. install cover over electrical junction box.Room 118.1.

Install blanks in the electrical panel in electrical room 300.

07/16/2020	2018 NFPA 101 7.10.5.1 Exit sign, functional	1			0
------------	--	---	--	--	---

Notes: Ensure sure exit signs are functional in the kitchen.

07/16/2020	2019 NFPA 80 6.3.1.7.4 Firedoor, gap does not	1			0
------------	---	---	--	--	---

Notes: Check fire doors for proper adjustment.

* Denotes Violations Corrected or Variance Issued

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

10184 Morris Inovative High School
104 Fort Hill TER
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
Total Individual Violation Codes for Occupancy: 3					

10799 Northstar School
307 Fredrick (South) ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/21/2020	2018 IFC 305.1 Ignition sources, proper	1			0
Notes: Flammable must not be stored in front of heat producing devices.					
07/21/2020	2018 IFC 604.1 Electrical equipment, no hazards	1			0
Notes: Install blanks in open spaces in electrical panels. Install covers on electrical junction boxes. Exposed electrical wiring must be installed in junction boxes.					
07/21/2020	2018 NFPA 101 7.10.5.1 Exit sign, functional	1			0
Notes: Repair or replace all non-operational exit signage.					
07/21/2020	2018 NFPA 101 7.2.1.8.2 Firedoor, automatic	1			0
Notes: Ensure all fire door auto closures are operable					
07/21/2020	2018 NFPA 101 8.3.5.1 Firewall, joints properly	1			0
Notes: Seal penetrations in custodian room 106 with fire caulk.					
07/21/2020	2019 NFPA 80 6.3.1.7.4 Firedoor, gap does not	1			0
Notes: Ensure all fire doors are properly spaced.					
07/21/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0
Notes: Install ceiling tiles in open ceiling spaces throughout.					
Total Individual Violation Codes for Occupancy: 7					

30269 Park Canyon Apartment Homes
284 Park Canyon DR
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
Total Individual Violation Codes for Occupancy: 7					

* Denotes Violations Corrected or Variance Issued

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

30269 Park Canyon Apartment Homes
284 Park Canyon DR
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/21/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0

Notes: The contractor requested a fire wall inspection. Myself along with Inspector Stratton and Building Inspector Burgess met with the contractor and advised him that fire caulk was not required on an exterior wall, however it was acceptable. Further site visits will continue to monitor the progress of the building.

Total Individual Violation Codes for Occupancy: 1

10440 Roan Street Elementary School
1116 Roan ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/24/2020	2018 IFC 604.1 Electrical equipment, no hazards	1			0
	Notes: Install blanks in open spaces in electrical panels.				
07/24/2020	2018 IFC 604.4.1 MOD Multi outlet adaptor meets	1			0
	Notes: Multi plug adapters shall not be plugged into multi plug adapters.				
07/24/2020	2018 IFC 604.5 Extension cord, properly used	1			0
	Notes: Extension cords shall not be plugged into multi plug adapters.				
	Extension cords shall not be plugged into extension cords.				
07/24/2020	2018 IFC 912.2.2 FDC, location marked correctly	1			0
	Notes: Install FDC signage.				
07/24/2020	2018 NFPA 101 7.2.1.8.2 Firedoor, automatic	1			0
	Notes: Ensure proper operation of all fire door closures.				
07/24/2020	2019 NFPA 80 6.3.1.7.4 Firedoor, gap does not	1			0
	Notes: Ensure proper spacing of all fire doors.				

Total Individual Violation Codes for Occupancy: 6

20101 Servicios Latinos
908 Elk ST
Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
----------	------------------	-------	---------	----------	------

* Denotes Violations Corrected or Variance Issued

DALTON**Monthly Prevention Violations by Occupancy**

Violation Date Reported Between {07/01/2020} And {07/31/2020}

20101 **Servicios Latinos**
 908 Elk ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/10/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0

Notes: Fire Marshall Daniel and Inspector Stratton conducted a site visit. The fire alarm had activated the night before. Fire department personnel stated that the dry system had activated and had become wet. Inspection confirmed what was stated. Preventions personnel Met with the owner, he stated that he would contact his sprinkler contractor to make the appropriate repairs and reset the system.

Total Individual Violation Codes for Occupancy: 1

10380 **Tienda Tony**
 911 Morris (East) ST
 A
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/20/2020	2018 IFC 506.1 Knox Box, requirements met	1			0
	Notes: Install required Knox Box.				
07/20/2020	2018 IFC 604.1 Electrical equipment, no hazards	1			0
	Notes: Install electrical outlet covers.				
	Install blank covers in open spaces in electrical panels.				
07/20/2020	2018 IFC 604.4.1 MOD Multi outlet adaptor meets	1			0
	Notes: Multi plug adapters must be properly mounted. Multi plug adapters must not be plugged into multi plug adapters.				
07/20/2020	2018 IFC 604.5 Extension cord, properly used	1			0
	Notes: Extension cords shall not substitute permanent electrical wiring.				
07/20/2020	2018 NFPA 101 7.10.5.1 Exit sign, functional	1			0
	Notes: Repair or replace non operational exit signage.				

Total Individual Violation Codes for Occupancy: 5

DALTON

Monthly Prevention Violations by Occupancy

**Violation Date Reported Between {07/01/2020} And
{07/31/2020}**

10524 Westwood Elementary School
 708 Trammell ST
 Dalton, GA 30720

Reported	Code/Description	Count	Article	Division	Page
07/24/2020	DFDFMO NFPA, ICC Code not specified on checklist	1			0

Notes: Install tiles in open spaces of the ceiling assembly.
Install FACP signage on room containing fire alarm control panel.

Total Individual Violation Codes for Occupancy: 1

Grand Total Violations: 76