

Dalton Fire Department

Dalton, GA

This report was generated on 7/20/2021 3:38:11 PM



Incident Statistics

Zone(s): All Zones | Start Date: 06/01/2021 | End Date: 06/30/2021

INCIDENT COUNT			
INCIDENT TYPE		# INCIDENTS	
EMS		241	
FIRE		108	
TOTAL		349	
TOTAL TRANSPORTS (N2 and N3)			
APPARATUS	# of APPARATUS TRANSPORTS	# of PATIENT TRANSPORTS	TOTAL # of PATIENT CONTACTS
TOTAL			
PRE-INCIDENT VALUE		LOSSES	
\$256,800.00		\$43,000.00	
CO CHECKS			
424 - Carbon monoxide incident		3	
736 - CO detector activation due to malfunction		1	
746 - Carbon monoxide detector activation, no CO		1	
TOTAL		5	
MUTUAL AID			
Aid Type		Total	
Aid Given		11	
Aid Received		2	
OVERLAPPING CALLS			
# OVERLAPPING		% OVERLAPPING	
114		32.66	
LIGHTS AND SIREN - AVERAGE RESPONSE TIME (Dispatch to Arrival)			
Station	EMS	FIRE	
Station 1	0:04:09	0:04:13	
Station 2	0:05:11	0:05:12	
Station 3	0:04:43	0:05:37	
Station 4	0:04:22	0:06:04	
Station 5	0:04:42	0:05:39	
AVERAGE FOR ALL CALLS		0:04:41	
LIGHTS AND SIREN - AVERAGE TURNOUT TIME (Dispatch to Enroute)			
Station	EMS	FIRE	
Station 1	0:01:01	0:01:19	
Station 2	0:01:12	0:01:23	

Only Reviewed Incidents included. EMS for Incident counts includes only 300 to 399 Incident Types. All other incident types are counted as FIRE. CO Checks only includes Incident Types: 424, 736 and 734. # Apparatus Transports = # of incidents where apparatus transported. # Patient Transports = All patients transported by EMS. # Patient Contacts = # of PCR contacted by apparatus. This report now returns both NEMSIS 2 & 3 data as appropriate. For overlapping calls that span over multiple days, total per month will not equal Total count for year.

Station 3	0:01:09	0:01:12
Station 4	0:00:57	0:01:33
Station 5	0:00:59	0:01:07
AVERAGE FOR ALL CALLS		0:01:07
AGENCY	AVERAGE TIME ON SCENE (MM:SS)	
Dalton Fire Department	16:01	

Only Reviewed Incidents included. EMS for Incident counts includes only 300 to 399 Incident Types. All other incident types are counted as FIRE. CO Checks only includes Incident Types: 424, 736 and 734. # Apparatus Transports = # of incidents where apparatus transported. # Patient Transports = All patients transported by EMS. # Patient Contacts = # of PCR contacted by apparatus. This report now returns both NEMSIS 2 & 3 data as appropriate. For overlapping calls that span over multiple days, total per month will not equal Total count for year.

Dalton Fire Department


Dalton, GA

This report was generated on 7/20/2021 3:39:34 PM



Incidents by Day of the Week for Date Range

Start Incident Type: 100 | End Incident Type: 911 | Start Date: 06/01/2021 | End Date: 06/30/2021



DAY OF THE WEEK	# INCIDENTS
Sunday	31
Monday	52
Tuesday	58
Wednesday	65
Thursday	43
Friday	52
Saturday	48
TOTAL	349

Only Reviewed incidents included.



emergencyreporting.com

Doc Id: 1284

Page # 1 of 1

Dalton Fire Department


Dalton, GA

This report was generated on 7/20/2021 3:40:15 PM



Incidents per Hour for Incident Type Range for Date Range

Start Incident Type: 100 | End Incident Type: 911 | Start Date: 06/01/2021 | End Date: 06/30/2021



HOURLY	# of CALLS
00:00 - 00:59	4
01:00 - 01:59	10
02:00 - 02:59	9
03:00 - 03:59	5
04:00 - 04:59	9
05:00 - 05:59	9
06:00 - 06:59	10
07:00 - 07:59	12
08:00 - 08:59	15
09:00 - 09:59	19
10:00 - 10:59	14
11:00 - 11:59	22
12:00 - 12:59	23
13:00 - 13:59	18
14:00 - 14:59	18
15:00 - 15:59	18
16:00 - 16:59	20
17:00 - 17:59	20
18:00 - 18:59	15
19:00 - 19:59	24
20:00 - 20:59	19
21:00 - 21:59	17
22:00 - 22:59	9
23:00 - 23:59	10
TOTAL:	349

Only REVIEWED incidents included.



Dalton Fire Department

Dalton, GA

This report was generated on 7/20/2021 3:40:54 PM



Incident Type Count per Station for Date Range

Start Date: 06/01/2021 | End Date: 06/30/2021

INCIDENT TYPE	# INCIDENTS
Station: 1 - STATION 1	
131 - Passenger vehicle fire	1
151 - Outside rubbish, trash or waste fire	1
162 - Outside equipment fire	1
231 - Chemical reaction rupture of process vessel	1
311 - Medical assist, assist EMS crew	94
322 - Motor vehicle accident with injuries	4
323 - Motor vehicle/pedestrian accident (MV Ped)	2
324 - Motor vehicle accident with no injuries.	4
440 - Electrical wiring/equipment problem, other	1
441 - Heat from short circuit (wiring), defective/worn	1
445 - Arcing, shorted electrical equipment	2
500 - Service Call, other	1
551 - Assist police or other governmental agency	1
611 - Dispatched & cancelled en route	13
622 - No incident found on arrival at dispatch address	3
651 - Smoke scare, odor of smoke	1
652 - Steam, vapor, fog or dust thought to be smoke	1
733 - Smoke detector activation due to malfunction	1
735 - Alarm system sounded due to malfunction	5
743 - Smoke detector activation, no fire - unintentional	5
744 - Detector activation, no fire - unintentional	1
745 - Alarm system activation, no fire - unintentional	1
746 - Carbon monoxide detector activation, no CO	1
# Incidents for 1 - Station 1:	146

Station: 2 - STATION 2	
131 - Passenger vehicle fire	2
311 - Medical assist, assist EMS crew	38
322 - Motor vehicle accident with injuries	1
324 - Motor vehicle accident with no injuries.	3
424 - Carbon monoxide incident	1
445 - Arcing, shorted electrical equipment	2
551 - Assist police or other governmental agency	1
611 - Dispatched & cancelled en route	4
731 - Sprinkler activation due to malfunction	2
735 - Alarm system sounded due to malfunction	4

Only REVIEWED incidents included.



INCIDENT TYPE	# INCIDENTS
741 - Sprinkler activation, no fire - unintentional	3
743 - Smoke detector activation, no fire - unintentional	1
745 - Alarm system activation, no fire - unintentional	1

Incidents for 2 - Station 2: 63

Station: 3 - STATION 3

131 - Passenger vehicle fire	1
142 - Brush or brush-and-grass mixture fire	1
311 - Medical assist, assist EMS crew	43
322 - Motor vehicle accident with injuries	5
412 - Gas leak (natural gas or LPG)	1
611 - Dispatched & cancelled en route	6
735 - Alarm system sounded due to malfunction	2
743 - Smoke detector activation, no fire - unintentional	3

Incidents for 3 - Station 3: 62

Station: 4 - STATION 4

111 - Building fire	1
113 - Cooking fire, confined to container	1
311 - Medical assist, assist EMS crew	15
322 - Motor vehicle accident with injuries	3
444 - Power line down	1
445 - Arcing, shorted electrical equipment	2
611 - Dispatched & cancelled en route	3
622 - No incident found on arrival at dispatch address	3
735 - Alarm system sounded due to malfunction	3
743 - Smoke detector activation, no fire - unintentional	3
744 - Detector activation, no fire - unintentional	1

Incidents for 4 - Station 4: 36

Station: 5 - STATION 5

142 - Brush or brush-and-grass mixture fire	1
311 - Medical assist, assist EMS crew	25
322 - Motor vehicle accident with injuries	3
352 - Extrication of victim(s) from vehicle	1
424 - Carbon monoxide incident	2
611 - Dispatched & cancelled en route	2
731 - Sprinkler activation due to malfunction	1
733 - Smoke detector activation due to malfunction	2
735 - Alarm system sounded due to malfunction	1
736 - CO detector activation due to malfunction	1
740 - Unintentional transmission of alarm, other	1
745 - Alarm system activation, no fire - unintentional	2

Incidents for 5 - Station 5: 42

Only REVIEWED incidents included.



Dalton Fire Department



Dalton, GA

This report was generated on 7/20/2021 3:41:30 PM



Major Incident Types by Month for Date Range

Start Date: 06/01/2021 | End Date: 06/30/2021



INCIDENT TYPE	JUN	TOTAL
False Alarm & False Call	45	45
Fire	10	10
Good Intent Call	36	36
Hazardous Condition (No Fire)	13	13
Overpressure Rupture, Explosion, Overheat(no fire)	1	1
Rescue & Emergency Medical Service Incident	241	241
Service Call	3	3
Total	349	349

Only REVIEWED incidents included



emergencyreporting.com

Doc Id: 495

Page # 1 of 1

Dalton Fire Department


Dalton, GA

This report was generated on 7/20/2021 3:41:56 PM



Count of Aid Given and Received for Incidents for Date Range

Start Date: 06/01/2021 | End Date: 06/30/2021



AID TYPE	TOTAL	% of TOTAL
Automatic aid received	2	0.6%
Automatic aid given	11	3.2%
None	336	96.3%

Only REVIEWED incidents included



Dalton Fire Department

Dalton, GA

This report was generated on 7/20/2021 3:42:46 PM



Detailed Fire Losses per Incident Type for Date Range

Start Date: 06/01/2021 | End Date: 06/30/2021

INCIDENT TYPE	COUNT	% OF INCIDENTS	TOTAL LOSSES (Sum of Property and Content Loss)	% OF TOTAL
111 - Building fire	1	16.67 %	\$1,200.00	2.79 %
131 - Passenger vehicle fire	3	50.00 %	\$40,500.00	94.19 %
142 - Brush or brush-and-grass mixture fire	1	16.67 %	\$500.00	1.16 %
440 - Electrical wiring/equipment problem, other	1	16.67 %	\$800.00	1.86 %

Only REVIEWED incidents included.



emergencyreporting.com

Doc Id: 1238

Page # 1 of 1

Dalton Fire Department

Dalton, GA

This report was generated on 7/20/2021 3:45:23 PM



Detailed Property And Contents Saved for Date Range

Start Date: 06/01/2021 | End Date: 06/30/2021

INCIDENT #	DATE	TYPE	LOCATION	PRE-INCIDENT PROPERTY	PRE-INCIDENT CONTENTS	PRE-INCIDENT TOTAL	PROP. SAVED	CONT. SAVED	TOTAL SAVED
2021-01668	06/15/2021	440 - Electrical wiring/equipment problem, other	1207 PEABODY DR Dalton	\$0.00	\$800.00	\$800.00	\$0.00	\$0.00	\$0.00
2021-01724	06/19/2021	142 - Brush or brush-and-grass mixture fire	1235 N Glenwood AVE Dalton	\$0.00	\$500.00	\$500.00	\$0.00	\$0.00	\$0.00
2021-01738	06/21/2021	131 - Passenger vehicle fire	808 W WALNUT AVE Dalton	\$25,000.00	\$0.00	\$25,000.00	\$22,000.00	\$0.00	\$22,000.00
2021-01754	06/22/2021	111 - Building fire	1917 W Brookhaven CIR Dalton	\$180,000.00	\$12,000.00	\$192,000.00	\$180,000.00	\$10,800.00	\$190,800.00
2021-01780	06/25/2021	131 - Passenger vehicle fire	1013 N Glenwood AVE Dalton	\$3,500.00	\$0.00	\$3,500.00	\$1,000.00	\$0.00	\$1,000.00
2021-01805	06/27/2021	131 - Passenger vehicle fire	334 I75 S Dalton	\$35,000.00	\$0.00	\$35,000.00	\$0.00	\$0.00	\$0.00

TOTAL PRE-INCIDENT PROPERTY	TOTAL PRE-INCIDENT CONTENT	TOTAL PRE-INCIDENT	TOTAL PROP. SAVED	TOTAL CONT. SAVED	TOTAL SAVED
\$243,500.00	\$13,300.00	\$256,800.00	\$203,000.00	\$10,800.00	\$213,800.00

# INCIDENTS	AVG. VAL.	AVERAGE SAVED
6	\$42,800.00	\$35,633.00

Only REVIEWED incidents included



emergencyreporting.com

Doc Id: 1834

Page # 1 of 1

Training Division Monthly Report

June 2021

Overview

The department hosted a Safe Return course delivered by the Alzheimer's Association that teaches first responders how to interact with patients suffering from dementia or Alzheimer's disease. An NFPA 1670 compliant surface water rescue refresher was delivered to all suppression personnel. This training culminated with a scenario-based rescue evolution conducted at Haig Mill Lake Park. Monthly training included territory familiarization, pre-fire training, core competency check-offs, special operations training, and company level drills chosen by company officers. Training hours during the month of June totaled 1,839.

Outside Schools

An instructor from the Training Division assisted in the delivery of a Trench Rescue Technician course hosted by Catoosa County Fire Department.

One company officer attended a course titled Understanding and Fighting Basement Fires hosted by Cobb County Fire & Emergency Services in Marietta, Georgia.

One of the department's EMT/Paramedic instructors attended an EMS educator update at the Region 1 EMS office in Rome, Georgia.

Dalton Fire Department

Dalton, GA

This report was generated on 7/13/2021 2:29:28 PM



Completed Inspections per Inspection Type for Date Range

Occupancy Status: All | Start Date: 06/01/2021 | End Date: 06/30/2021

ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
11301	United Karate Studios Dalton	1132 E Walnut AVE Dalton, GA 30721	06/02/2021	Stratton, Dale Lee	Passed	
11232	Baymont Inn & Suites	2106 Chattanooga RD Dalton, GA 30720	06/03/2021	Blankenship, Donnie	Corrective Action Plan Given	
10355	DPS-Dalton High School	1500 Manly ST Dalton, GA 30720	06/03/2021	Daniel, Matthew T.	Passed	Inspection for Early Head Start. Rooms 304, 326, 331 and 337. Occupancy Load: Room 304: 32 Room 326: 36 Room 331: 30 Room 337: 38
10219	Mitchell & Mitchell	108 S Thornton AVE Dalton, GA 30720	06/03/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Add extinguisher.
10965	Reddy Ice	426 S Hamilton ST Dalton, GA 30721	06/03/2021	Stratton, Dale Lee	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov
10489	Bank of America	300 S Thornton AVE Dalton, GA 30720	06/03/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10519	Daily Citizen News	308 S Thornton AVE Dalton, GA 30720	06/03/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
11209	Coppedge, Michmerhuizen, Rayburn	508 S Thornton AVE Dalton, GA 30720	06/03/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
11021	Providence Ministries (Homeless Shelter)	613 Oxford ST Dalton, GA 30720	06/03/2021	Blankenship, Donnie	Corrective Action Plan Given	
10100 - 1	Investment & Retirement Management	200 W Emery ST #Suite 1&2 Dalton, GA 30720	06/03/2021	Stratton, Dale Lee	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov
10488	U.S.Post Office	100 S Thornton AVE Dalton, GA 30720	06/04/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10234	UGA Extension Office	104 S Thornton AVE Dalton, GA 30720	06/04/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguishers need to be inspected.
10100 - 2	Everstep Flooring	200 W Emery ST #Suite 3 Dalton, GA 30720	06/04/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10100	200 Emery St. Property	200 W Emery ST Dalton, GA 30720	06/04/2021	Stratton, Dale Lee	Corrective Action Plan Given	

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
10100 - 3	Vacant	200 W Emery ST #Suite 4 Dalton, GA 30720	06/04/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10100 - 4	Vacant	200 W Emery ST #Suite 5 Dalton, GA 30720	06/04/2021	Stratton, Dale Lee	Corrective Action Plan Given	
11209	Coppedge, Michmerhuizen, Rayburn	508 S Thornton AVE Dalton, GA 30720	06/07/2021	Hearn, Scott Raymond	Passed	
10174	First National Community Bank	415 S Thornton AVE Dalton, GA 30720	06/07/2021	Stratton, Dale Lee	Passed	
10520	Mitchael A. Corbin Attorney at Law	505 S Thornton AVE Dalton, GA 30720	06/07/2021	Stratton, Dale Lee	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov
10756	Aesops Inc.	301 Dayton ST Dalton, GA 30720	06/08/2021	Stratton, Dale Lee	Corrective Action Plan Given	
11018 - 3	LGM & Associates	519 Oxford ST Dalton, GA 30720	06/08/2021	Stratton, Dale Lee	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov
11018 - 2	LGM & Associates	517 Oxford ST Dalton, GA 30720	06/08/2021	Stratton, Dale Lee	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov
11018 - 1	Colorworks	510 S Pentz ST Dalton, GA 30720	06/08/2021	Stratton, Dale Lee	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov
10883	Georgia Meat Distribution	645 S Hamilton ST Dalton, GA 30721	06/09/2021	Blankenship, Donnie	Failed	
10155	Leo's Car Detailing	633 S Hamilton ST Dalton, GA 30720	06/09/2021	Blankenship, Donnie	Failed	
10757	R&J Properties	309 Dayton ST Dalton, GA 30720	06/10/2021	Stratton, Dale Lee	Corrective Action Plan Given	Email photos of corrected actions to dstratton.daltonga.gov
10182	Acree Jinright & Co. Pc.	212 W Gordon ST Dalton, GA 30720	06/10/2021	Stratton, Dale Lee	Failed	Fire extinguishers were installed. No other corrective actions were addressed by the tenant.
10104	El Sol Audio	800 E Morris ST Dalton, GA 30720	06/11/2021	Stratton, Dale Lee	Passed	
10681	Temps Plus	601 S Thornton AVE Dalton, GA 30720	06/15/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10793	Trevor A. Brown, Attorney	603 S Thornton AVE Dalton, GA 30720	06/15/2021	Stratton, Dale Lee	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov
10829 - 2	Heartlite Hospice	307 W Emery ST #Suite B Dalton, GA 30720	06/15/2021	Stratton, Dale Lee	Passed with Comments	Contact Dale Stratton at 706-278-7363 Ext.248 when the keys are ready to be placed in the Knox Box.
11024	Willie's Bar-B-Que	301 W Emery ST Dalton, GA 30721	06/17/2021	Stratton, Dale Lee	Passed	
11276	Angela Moss Gordy; Certified Public Accountant	605 S Thornton AVE Dalton, GA 30720	06/17/2021	Stratton, Dale Lee	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Annual						
10071	Child Support Enforcement/Department of Human Services	417 W Crawford ST Dalton, GA 30720	06/21/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Have extinguishers inspected by a licensed Georgia contractor.
10654	Flash Graphics	212 N Pentz ST Dalton, GA 30720	06/22/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
11316	McMahan Law Firm	700 S Thornton AVE Dalton, GA 30720	06/22/2021	Hearn, Scott Raymond	Corrective Action Plan Given	See report.
10281	Dalton Family Dentistry	400 S Thornton AVE Dalton, GA 30720	06/22/2021	Hearn, Scott Raymond	Passed	
10876	Lisa's Café	410 S Hamilton ST Dalton, GA 30720	06/22/2021	Stratton, Dale Lee	Passed with Comments	Notify Inspector Dale Stratton when the Knox Box has been installed and keys are ready for placement. 706-278-7363 Ext. 248
10604	McCamy, Phillips, Tuggle, and Fordham	411 W Crawford ST Dalton, GA 30720	06/22/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Add Knox Box to building.
10829 - 3	Fairway Independent Mortgage	307 W Emery ST #C Dalton, GA 30720	06/22/2021	Stratton, Dale Lee	Corrective Action Plan Given	
11322	Salon 315	315 W Franklin ST Dalton, GA 30721	06/23/2021	Stratton, Dale Lee	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov
11279	Greg Kinnamon	512 S Thornton AVE Dalton, GA 30720	06/23/2021	Hearn, Scott Raymond	Complaint cleared by Contact	
11081	Christ The King Lutheran Church	625 S Thornton AVE Dalton, GA 30720	06/23/2021	Stratton, Dale Lee	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov
10545	Jack's	1202 N Glenwood AVE Dalton, GA 30721	06/24/2021	Stratton, Dale Lee	Corrective Action Plan Given	All corrective actions regarding fire related equipment must be addressed by 6-28-2021.
10589	Kinard Realty	704 S Thornton AVE Dalton, GA 30720	06/25/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguisher
10504	Oakhaven	216 Fort Hill TER Dalton, GA 30720	06/25/2021	Hearn, Scott Raymond	Passed	
10345 - 1	Congressional Office	702 S Thornton AVE #A Dalton, GA 30720	06/29/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguisher needs an inspection.
11324 - 3	Robinson Door	209 W Emery ST #Suite C Dalton, GA 30720	06/29/2021	Stratton, Dale Lee	Corrective Action Plan Given	
10345 - 2	Kinard Realty	702 S Thornton AVE #B AND C Dalton, GA 30720	06/29/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Inspect extinguishers.
11324 - 1	A-1 Lock & Security	209 W Emery ST #Suite A Dalton, GA 30720	06/29/2021	Stratton, Dale Lee	Corrective Action Plan Given	
11324 - 2	Alpha & Omega Insurance LLC	209 W Emery ST #Suite B Dalton, GA 30720	06/29/2021	Stratton, Dale Lee	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
----	-----------	---------	------	-----------	--------	-------

Total # Inspections for Annual:

51

Inspection Type: Fireworks

00002 - 1	Phanton Fireworks	883 Shugart RD Dalton, GA 30720	06/17/2021	Stratton, Dale Lee	Passed	
00002 - 2	TNT Fireworks	815 Shugart RD Dalton, GA 30720	06/25/2021	Stratton, Dale Lee	Passed	
00002 - 3	TNT Fireworks	1287 N Glenwood AVE Dalton, GA 30720	06/25/2021	Stratton, Dale Lee	Passed	

Total # Inspections for Fireworks:

3

Inspection Type: New Construction

10738	Fairfield Inn & Suites	786 College DR Dalton, GA 30720	06/01/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
-------	------------------------	------------------------------------	------------	-------------------------	---------------------------------	--

Total # Inspections for New Construction:

1

Inspection Type: OTC

10576 - 3	The Aesthetic At Trevitt	111 N Hamilton ST Dalton, GA 30720	06/02/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10011 - 3	Top It Off	1506 N Thornton AVE #Suite B Dalton, GA 30720	06/07/2021	Hearn, Scott Raymond	Passed	
10291	Dalton Optometry	415 W Crawford ST Dalton, GA 30720	06/09/2021	Daniel, Matthew T.	Passed	
10421 - 1	Dollar Tree	1261 N Glenwood AVE Dalton, GA 30721	06/10/2021	Blankenship, Donnie	Corrective Action Plan Given	
10627 - 3	Dalton Infra Inc.	911 E Morris ST #Suite A Dalton, GA 30720	06/15/2021	Blankenship, Donnie	Corrective Action Plan Given	
10537	Beautiful Smiles Dentistry	509 S Thornton AVE Dalton, GA 30720	06/15/2021	Blankenship, Donnie	Corrective Action Plan Given	
10103 - 3	Rail Side Tattoo/Hempheads	102 Waugh (West) ST Dalton, GA 30720	06/16/2021	Blankenship, Donnie	Corrective Action Plan Given	
11097 - 10	Benchmark Physical Therapy	785 Shugart RD #Suite 10 Dalton, GA 30720	06/22/2021	Blankenship, Donnie	Corrective Action Plan Given	
10736 - 14	Edible Arrangements	1001 Market ST #Suite 24 Dalton, GA 30720	06/25/2021	Blankenship, Donnie	Corrective Action Plan Given	
10378	Citgo Food Mart	1246 N Thornton AVE Dalton, GA 30720	06/28/2021	Hearn, Scott Raymond	Passed	
11218 - 4	GNC	816 Walnut Square BLVD #Suite 6 Dalton, GA 30720	06/28/2021	Hearn, Scott Raymond	Corrective Action Plan Given	Extinguisher needs updated.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: OTC						
10129 - 1	Chihuahua"s	314 N Glenwood AVE Dalton, GA 30720	06/28/2021	Hearn, Scott Raymond	Passed	
10147	Take 5 Oil Change	2703 Airport RD Dalton, GA 30721	06/29/2021	Daniel, Matthew T.	Passed	

Total # Inspections for OTC: 13

Inspection Type: Plan Review						
10262	Burr Park	101 S Hamilton ST Dalton, GA 30720	06/14/2021	Daniel, Matthew T.	Passed	Concessions and restroom plan review no issues.
10448	Circle K	1200 N Glenwood AVE Dalton, GA 30721	06/14/2021	Daniel, Matthew T.	Passed	Interior remodel no issues.
10731	Brown Sample	1915 Abutment RD Dalton, GA 30720	06/15/2021	Daniel, Matthew T.	Passed	Fire Alarm.
10332	Christian Heritage Elementary School	1600 MLK Jr. BLVD Dalton, GA 30720	06/15/2021	Daniel, Matthew T.	Passed	Fire Alarm no issues.
10772	STR	310 Brookhollow Ind. BLVD Dalton, GA 30720	06/15/2021	Daniel, Matthew T.	Passed	
11268	Wal-Mart	815 Shugart RD Dalton, GA 30720	06/18/2021	Daniel, Matthew T.	Passed	Sprinkler addition.
10351	El Milagro #2	101 E Long ST Dalton, GA 30720	06/18/2021	Daniel, Matthew T.	Passed	Building remodel.
10479	Cornerstone Medical Offices	1430 Chattanooga AVE Dalton, GA 30720	06/23/2021	Daniel, Matthew T.	Passed	Site and building plan review.
11298	Advanced Fibers	1805 S Hamilton ST Dalton, GA 30720	06/23/2021	Daniel, Matthew T.	Passed	Sprinkler plan review.
10120	Vacant	210 N Glenwood AVE Dalton, GA 30720	06/28/2021	Daniel, Matthew T.	Passed	Building plan review no issues.
11326	Blanca's Venue	Pleasant Grove DR NE Dalton, GA 30721	06/28/2021	Daniel, Matthew T.	Passed	Site review.
10428	Dalton Aircraft	4465 Airport RD Dalton, GA 30720	06/29/2021	Daniel, Matthew T.	Passed	
11298	Advanced Fibers	1805 S Hamilton ST Dalton, GA 30720	06/29/2021	Daniel, Matthew T.	Passed	New addition.

Total # Inspections for Plan Review: 13

Inspection Type: Reinspection						
10282	Psychological Forensic Associates	314 S Hamilton ST Dalton, GA 30720	06/07/2021	Hearn, Scott Raymond	Corrective Action Plan Given	

Total # Inspections for Reinspection: 1

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10890	Log Cabin	1001 Poly Pac DR Dalton, GA 30720	06/01/2021	Blankenship, Donnie	Corrective Action Plan Given	
11297	Integrated Fiber Solutions	2313 Dalton Industrial CT Dalton, GA 30720	06/01/2021	Stratton, Dale Lee	Passed with Comments	placed business key in Knox Box
11250	Holiday Inn Express	934 Market ST Dalton, GA 30720	06/02/2021	Hearn, Scott Raymond	Passed with Comments	
10739	Walnut Creek	1115 W Walnut AVE Dalton, GA 30720	06/02/2021	Blankenship, Donnie	Corrective Action Plan Given	
10677- 1	Park Canyon Apartment Homes	2270 Park Canyon DR Dalton, GA 30720	06/02/2021	Blankenship, Donnie	Passed	
10973	Emerald Carpets	2650 Abutment RD Dalton, GA 30720	06/03/2021	Stratton, Dale Lee	Passed with Comments	Put keys in the Knox Box keys.
10974	Emerald Carpets	2668 Abutment RD Dalton, GA 30720	06/03/2021	Stratton, Dale Lee	Passed with Comments	Replaced Knox Box key.
10325	Cuyler Triplex	402 W Cuyler ST Dalton, GA 30720	06/03/2021	Blankenship, Donnie	Passed	
10475	American Legion	1118 N Glenwood AVE Dalton, GA 30720	06/04/2021	Stratton, Dale Lee	Passed	John Wilson 706-226-5120 requested a burn permit to burn a brush pile. Was unable to make contact with Mr. Wilson via phone. Site visit was conducted in an effort to expedite issuance of a burn permit.
10475	American Legion	1118 N Glenwood AVE Dalton, GA 30720	06/04/2021	Stratton, Dale Lee	Passed with Comments	Met with John Wilson to discuss acquiring a burn permit to dispose of hand piled yard debris. Mr. Wilson also needed help accessing the city website to coordinate a Flag Retirement Ceremony. Inspector Stratton assisted Mr. Wilson with signing up through the City Web site.
10343	Vacant	507 S Thornton AVE Dalton, GA 30720	06/07/2021	Stratton, Dale Lee	Passed with Comments	Site visit revealed that the building has been reduced to a single occupancy. Because of the aforementioned finding, tenant occupancies have been archived.
10992	City of Refuge	416 S Glenwood AVE Dalton, GA 30720	06/14/2021	Blankenship, Donnie	Corrective Action Plan Given	
11097 - 10	Benchmark Physical Therapy	785 Shugart RD #Suite 10 Dalton, GA 30720	06/18/2021	Blankenship, Donnie	Corrective Action Plan Given	
10992	City of Refuge	416 S Glenwood AVE Dalton, GA 30720	06/18/2021	Blankenship, Donnie	Passed	
11142	Krystal	1909 E Walnut AVE Dalton, GA 30721	06/21/2021	Stratton, Dale Lee	Passed with Comments	Acquisition of Hood system ventilation information.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10395 - 1	Vacant	305 Fernwood AVE Dalton, GA 30721	06/21/2021	Daniel, Matthew T.	Passed	Met with John Davis and M Fowler to discuss zoning and occupancy of the building.
10777	Longhorn Steak House	1315 W Walnut AVE Dalton, GA 30720	06/21/2021	Hearn, Scott Raymond	Corrective Action Plan Given	
10125	Big Brothers Big Sisters of Northwest Georgia Mountains	209 W Morris ST Dalton, GA 30720	06/22/2021	Stratton, Dale Lee	Passed with Comments	A 30 day extension has been granted.
11063	Vacant	203 W Emery ST Dalton, GA 30720	06/22/2021	Blankenship, Donnie	Passed	Raisin Textiles has moved out of the building, and A1 Lock/Robinson Door is in the process of moving in.
10883	Georgia Meat Distribution	645 S Hamilton ST Dalton, GA 30721	06/22/2021	Blankenship, Donnie	Passed	Met with the occupant who advised he would like to me to come back tomorrow at 2:30 to discuss the sprinkler system and inspect the locked area as previously discussed.
11218 - 37	Chic-Fil-A	816 Walnut Square BLVD #Suite 54 Dalton, GA 30720	06/22/2021	Daniel, Matthew T.	Passed	Met with business owner to discuss temporary food service from a mobile food truck. This is an existing business undergoing renovation. Transient Merchant requirements are being met and the mobile food truck will not be used once the new renovations are complete. Building Inspector was present.
10829	Green Spot Building	307 W Emery ST Dalton, GA 30720	06/23/2021	Stratton, Dale Lee	Passed with Comments	Inspector Stratton accessed the Knox Box to allow Carpet Capitol to disconnect the alarm switch inside. Inspector Stratton function checked the keys to ensure they operated the locks.
11300	Salon Garibaldi	1309 Morris (East) ST Dalton, GA 30720	06/23/2021	Daniel, Matthew T.	Corrective Action Plan Given	
10883	Georgia Meat Distribution	645 S Hamilton ST Dalton, GA 30721	06/23/2021	Blankenship, Donnie	Passed with Comments	
10074	Xtreme Audio and Accessories	400 S Hamilton ST Dalton, GA 30720	06/25/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to assess progress of corrective actions. A 30 day extension has been granted.
10227 - 3	DWCDC	407 S Thornton AVE #Suite 3 Dalton, GA 30720	06/25/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to assess progress of corrective actions. A 30 day extension has been granted.

Includes LOCKED inspections for both archived and unarchived occupancy records.



ID	OCCUPANCY	ADDRESS	DATE	INSPECTOR	RESULT	NOTES
Inspection Type: Site Visit						
10227 - 5	Northwest Family Crisis Center	407 S Thornton AVE #Suite 5 Dalton, GA 30720	06/25/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to assess progress of corrective actions. A 30 day extension has been granted.
10227 - 1	Landmark Realty	407 S Thornton AVE #Suite 1 Dalton, GA 30720	06/25/2021	Stratton, Dale Lee	Passed with Comments	Site visit conducted to assess progress of corrective actions. A 30 day extension has been granted.
10545	Jack's	1202 N Glenwood AVE Dalton, GA 30721	06/28/2021	Stratton, Dale Lee	Passed with Comments	Met with Dan White to assess progress of corrective actions. To date: storage in front of the electrical panels has been moved, exit sign has been repaired, hood system has been cleaned. Mr. White, stated that the hood suppression system and fire extinguishers will be addressed on Wednesday. Replaced the Knox Box key.
10348	Juicy Seafood	819 Walnut Square BLVD Dalton, GA 30721	06/29/2021	Hearn, Scott Raymond	Passed	

Total # Inspections for Site Visit:

30

TOTAL # INSPECTIONS: 112

Includes LOCKED inspections for both archived and unarchived occupancy records.



Dalton Fire Department

Dalton, GA

This report was generated on 7/13/2021 2:27:42 PM



Occupancy Inspection History per Occupancy with Violations

Inspection Observations: CORRECTIVE ACTION PLAN, FAIL | Occupancy Categories: All Categories | Start Date: 06/01/2021 | End Date: 06/30/2021

INSPECTION DATE	INSPECTION TYPE	RESULT	NOTES	QUESTION	REMARKS	OBSERVATION
Engine 1 A Shift						
Child Support Enforcement/Department of Human Services - 417 W Crawford ST - 844.694.2347						
06/21/2021	Annual	Corrective Action Plan Given	Have extinguishers inspected by a licensed Georgia contractor.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	All extinguishers must be inspected by a licensed Georgia contractor annually.	CORRECTIVE ACTION PLAN
Coppedge, Michmerhuizen, Rayburn - 508 S Thornton AVE						
06/03/2021	Annual	Corrective Action Plan Given		Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Update extinguisher.	CORRECTIVE ACTION PLAN
Dalton Infra Inc. - 911 E Morris ST #Suite A						
06/15/2021	OTC	Corrective Action Plan Given		Does the emergency lighting system work correctly?	Repair or replace emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs properly illuminated?	Repair or replace exit signage.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install cover on electrical outlet. Install blanks in electrical panel.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	CORRECTIVE ACTION PLAN
Mitchell & Mitchell - 108 S Thornton AVE - 706-278-2040						
06/03/2021	Annual	Corrective Action Plan Given	Add extinguisher.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add correct extinguisher by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Temps Plus - 601 S Thornton AVE

06/15/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Is a fire alarm installed where required by the Code?	Install batteries in Carbon Monoxide detectors.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	1) All multi plug adapters must be mounted according to manufacturers recommended specifications. 2) Multi plug adapters shall not be plugged into multi plug adapters. 3) Install switch plate covers and outlet covers on all light switches and electrical outlets. 4) Enclose open electrical wiring. 5) Properly mount electrical switch. 6) Install ELECTRICAL PANEL sign on the door covering the electrical panel.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install address signage.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Remove all obstructions from stairwells and means of egress.	CORRECTIVE ACTION PLAN

Engine 1 B Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Acree Jinright & Co. Pc. - 212 W Gordon ST - 706-278-5853

06/10/2021	Annual	Failed	Fire extinguishers were installed. No other corrective actions were addressed by the tenant.	Are extension cords being used correctly?	Extension cords shall not be plugged into multi plug adapters. Extension cords shall not be plugged into extension cords. Extension cords shall not substitute permanent wiring. Extension cords shall not pass through walls or ceilings.	FAIL
				Are electrical rooms marked?		FAIL
				Is a proper working space provided in front of electrical service equipment?	Remove storage from in front of electrical panels.	FAIL
				Are multiplug adapters code compliant and in proper use?	Multi plug adapters shall not be plugged into multi plug adapters.	FAIL
				Are wiring splices concealed in a junction box and are open junction boxes covered with an approved junction box cover?	Open splices must be installed in approved junction boxes.	FAIL
				Is address signage correct and in place?	Install address signage.	FAIL
				Has a Knox Box containing the property access keys been installed?	Install Knox Box.	FAIL
				Are exits, or enclosures for stairways and ramps free of combustibles?		FAIL
				Are boiler rooms, mechanical rooms, electrical rooms, and fire command centers free of combustible material storage?		FAIL
				Is the headroom in the means of egress code compliant?	Repair stairwell ceiling.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguishers as discussed.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Bank of America - 300 S Thornton AVE

06/03/2021	Annual	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	--	--	---------------------------	------------------------

Trevor A. Brown, Attorney - 603 S Thornton AVE

06/15/2021	Annual	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov	Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	1) Install blanks in open spaces in the electrical panel. 2) Install ELECTRICAL ROOM sign on the door concealing the electrical panel. 3) Install appropriate covers on electrical junction boxes.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	All fire extinguishers require current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Engine 1 C Shift

Psychological Forensic Associates - 314 S Hamilton ST - 844.541.9988

06/07/2021	Reinspection	Corrective Action Plan Given		Does the emergency lighting system work correctly?	Repair or replace. Not complete. 12/14/2020	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace. Not complete 12/14/2020.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box. Not complete must be installed 05/2021.	CORRECTIVE ACTION PLAN
				Are the size and distribution of fire extinguishers code compliant?	Need minimum 5lb. extinguisher, inspected by licensed contractor. Not complete 12/14/2020.	CORRECTIVE ACTION PLAN

Engine 2 A Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Fairway Independent Mortgage - 307 W Emery ST #C- (706) 541-8978

06/22/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	All multi plug adapters shall be mounted according to manufacturers recommended specifications.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	A key to the business must be supplied for placement in the Knox Box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	All installed fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

GNC - 816 Walnut Square BLVD #Suite 6- 706-278-7134

06/28/2021	OTC	Corrective Action Plan Given	Extinguisher needs updated.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Extinguisher needs inspection by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN
------------	-----	------------------------------	-----------------------------	---	---	------------------------

Heartlite Hospice - 307 W Emery ST #Suite B- 706.272.1035

06/15/2021	Annual	Passed with Comments	Contact Dale Stratton at 706-278-7363 Ext.248 when the keys are ready to be placed in the Knox Box.	Has a Knox Box containing the property access keys been installed?	Install keys in Knox Box.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	--	---------------------------	------------------------

McMahan Law Firm - 700 S Thornton AVE

06/22/2021	Annual	Corrective Action Plan Given	See report.	Are there any identifiable electrical hazards?	Have electrician add permanent wiring to pump.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have extinguishers inspected by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN

Engine 2 B Shift

Aesops Inc. - 301 Dayton ST

06/08/2021	Annual	Corrective Action Plan Given		Does the emergency lighting system work correctly?	Repair or replace all non operational emergency lighting.	FAIL
				Are exits, other than main exits properly marked?	Install additional emergency exit signage in the office area.	CORRECTIVE ACTION PLAN
				Are exit signs properly illuminated?	Repair or replace all non operational emergency exit signage.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Are there any identifiable electrical hazards?	1) Install blanks in open spaces in electrical panels. 2) Open slices must be installed and covered in a junction box.	FAIL
Are multiplug adapters code compliant and in proper use?	Multi plug adapters shall not be plugged into multi plug adapters.	CORRECTIVE ACTION PLAN
Are wiring splices concealed in a junction box and are open junction boxes covered with an approved junction box cover?	Open splices in junction boxes must be covered with an appropriate junction box cover.	FAIL
Are rooms containing fire protection equipment properly marked ?	Install a RISER ROOM sign above the door containing the sprinkler riser.	CORRECTIVE ACTION PLAN
Has a Knox Box containing the property access keys been installed?	Because the building is sprinkled, installment of a Knox Box will be required.	CORRECTIVE ACTION PLAN
Do doors open readily from the egress side?	Repair non operational emergency exit.	FAIL
Are normally open valves properly secured?	Sprinkler control valve must be chained in the open position.	FAIL
Has the sprinkler system been inspected annually by a Georgia licensed contractor?	Sprinkler systems require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	FAIL
Are existing buildings marked with code compliant FDC signage?	Install FDC signage.	FAIL
Are fire extinguishers mounted at the proper height?	All fire extinguishers must be properly mounted.	FAIL
Are the required number and type of fire extinguisher installed for the present hazard or condition?	Install fire extinguishers as discussed.	CORRECTIVE ACTION PLAN
Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	All fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	FAIL

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Leo's Car Detailing - 633 S Hamilton ST - 7063137158

06/09/2021	Annual	Failed		Is required emergency lighting in place?	Install emergency lighting in building.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Extension cords cannot be used for permanent power. Extension cord should be plugged directly into an outlet when used for temporary power. Electrical wiring should be in conduit with appropriate junction boxes.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	I'm sure address is visible from the road from your property and is the appropriate size and of contrasting color.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox box on building.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Keep means of egress free of obstructions.	CORRECTIVE ACTION PLAN
				Have sprinklers been maintained and in operational condition?	Sprinkler system is currently not operational. Sprinkler system shall be brought back up with current code and in working order.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install code compliant fire extinguishers. Fire extinguishers must be tagged by Georgia licensed fire extinguisher contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



R&J Properties - 309 Dayton ST

06/10/2021	Annual	Corrective Action Plan Given	Email photos of corrected actions to dstratton.daltonga.gov	Is required emergency lighting in place?	Install emergency lighting	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Install exit signs with emergency lighting.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install blanks in open spaces in all electrical panels. Install cover on electrical panel. Install covers on all electrical junction boxes.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install address signage.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Because the building has a sprinkler system, the structure will require installation of a Knox Box.	CORRECTIVE ACTION PLAN
				Are the installed sprinkler systems code compliant?	Install FDC and RISER ROOM signage.	CORRECTIVE ACTION PLAN

Engine 2 C Shift

200 Emery St. Property - 200 W Emery ST - 7062601287

06/04/2021	Annual	Corrective Action Plan Given		Is address signage correct and in place?	Install suite numbering above all doors as discussed.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Repair rear exit door on suite 1.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Everstep Flooring - 200 W Emery ST #Suite 3- 844-296-4669

06/04/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signage.	CORRECTIVE ACTION PLAN
				Are proper clearances of combustible materials from ignition sources being maintained?	Remove combustibles from mechanical/electrical room. Maintain 36" clearance in front of electrical panel. Install ELECTRICAL ROOM signage.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers require current annual inspection; must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Investment & Retirement Management - 200 W Emery ST #Suite 1&2- 706-278-2429

06/03/2021	Annual	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov	Does the emergency lighting system work correctly?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs properly illuminated?	Repair or replace all non operational exit signage.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	1) Install blanks in open spaces in electrical panels.	CORRECTIVE ACTION PLAN
				Are electrical rooms marked?	Install ELECTRICAL ROOM signage.	CORRECTIVE ACTION PLAN
				Is a proper working space provided in front of electrical service equipment?	Remove storage from in front of electrical panels.	CORRECTIVE ACTION PLAN
				Are multiplug adapters code compliant and in proper use?	Properly mount multi plug adapters according to manufacturers recommended specifications.	CORRECTIVE ACTION PLAN
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Fire extinguishers require current annual inspection; must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN
				Do the fire extinguishers have the appropriate inspection tag required by law?		CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Vacant - 200 W Emery ST #Suite 4- +17062266028

06/04/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signage.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install ELECTRICAL ROOM sign on electrical room door.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguisher. All fire extinguishers require a current annual inspection; must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Vacant - 200 W Emery ST #Suite 5- 706-278-9304

06/04/2021	Annual	Corrective Action Plan Given		Have all applicable code requirements been met?	Install ELECTRICAL ROOM sign on the electrical room door.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguisher. All fire extinguishers require a current annual inspection and it must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Engine 4 A Shift

Fairfield Inn & Suites - 786 College DR - 7062757215

06/01/2021	New Construction	Corrective Action Plan Given		Have all applicable code requirements been met?	Discussed Porte cochere cover up. Noted the wood would need to be fire retardant or would require sprinkler coverage. Will re-inspect after.	CORRECTIVE ACTION PLAN
------------	------------------	------------------------------	--	---	--	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Georgia Meat Distribution - 645 S Hamilton ST - 706-508-8861

06/09/2021	Annual	Failed		Is required emergency lighting in place?	Install emergency lighting and building.	CORRECTIVE ACTION PLAN
				Are exits, other than main exits properly marked?	Install exercise image above exit doors. Ensure they are code compliant with battery back up.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	The building does not meet the requirements to have a living quarters. If someone is living in the structure they need to vacate the structure immediately.	FAIL
				Are there any identifiable electrical hazards?	Electrical wiring should be in conduit. Install blanks in electrical panel.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Address number should be visible from the road and meet the requirements of the code.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox box on the building.	CORRECTIVE ACTION PLAN
				Have sprinklers been maintained and in operational condition?	Sprinkler system has been removed. Sprinkler system has to be repaired and brought up to current code.	FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install code compliant fire extinguishers. Fire extinguishers must be tagged by Georgia license for extinguisher contractor.	CORRECTIVE ACTION PLAN

Lisa's Café - 410 S Hamilton ST - 706-278-1159

06/22/2021	Annual	Passed with Comments	Notify Inspector Dale Stratton when the Knox Box has been installed and keys are ready for placement. 706-278-7363 Ext. 248	Has a Knox Box containing the property access keys been installed?	Install Knox Box.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	--	-------------------	------------------------

Walnut Creek - 1115 W Walnut AVE

06/02/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Spray foam was used for penetrations and smoke wall it should not be used in a commercial building. Egress doors swing inward and should swing outward.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	---	------------------------

Engine 4 B Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



City of Refuge - 416 S Glenwood AVE - 706-226-1301

06/14/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	A sprinkler head was activated due to a ball hitting it. This set off the alarm in the building, but the Fire Department didn't get dispatched by the alarm monitoring service. The fire alarm needs to be inspected to ensure that it is being monitored as required. Protective cages that meet code requirements needs to be added to sprinkler heads in the gym area.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	--	------------------------

Colorworks - 510 S Pentz ST - 7062771811

06/08/2021	Annual	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov	Have all applicable code requirements been met?	Fire extinguishers require current annual inspection. Inspection must be conducted by a Georgia licensed contractor. Install FDC sign at the Fire Department Connection.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Repair address signage.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Edible Arrangements - 1001 Market ST #Suite 24- 7065297255

06/25/2021	OTC	Corrective Action Plan Given		Does the emergency lighting system work correctly?	Repair or replace emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs properly illuminated?	Repair or replace exit signage.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Keep storage a minimum of 18 inches below sprinkler heads.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Install cover on electrical outlet. Remove combustibles near electrical panels. Install blanks in electrical panel.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install a Knox Box on the building. When ordering make sure to select Dalton City as the Fire Department.	CORRECTIVE ACTION PLAN
				Do doors open readily from the egress side?	Ensure both doors are unlocked when open to the public.	CORRECTIVE ACTION PLAN
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Contact a Georgia licensed fire extinguisher contractor for inspection.	CORRECTIVE ACTION PLAN

LGM & Associates - 517 Oxford ST

06/08/2021	Annual	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install a fire extinguisher. All fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN
------------	--------	----------------------	---	---	---	------------------------

LGM & Associates - 519 Oxford ST - 706-370-5888

06/08/2021	Annual	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov	Has a Knox Box containing the property access keys been installed?	The structure has a sprinkler system and will require installment of a Knox Box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install a fire extinguisher. All fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Providence Ministries (Homeless Shelter) - 613 Oxford ST - 706-275-0268

06/03/2021	Annual	Corrective Action Plan Given		Is required emergency lighting in place?	Repair emergency lighting.	CORRECTIVE ACTION PLAN
				Have all applicable code requirements been met?	Install smoke under drop in ceiling in electrical room. Remove combustibles under kitchen hood.	CORRECTIVE ACTION PLAN
				Is a fire alarm installed where required by the Code?	Add required devices in front of building.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Remove combustibles in electrical room. Email a copy of the current fire alarm inspection report.	CORRECTIVE ACTION PLAN
				Are the means of egress free of obstructions or impediments?	Don't chain egress paths. Corrected on site.	CORRECTIVE ACTION PLAN
				Are all required areas of the building sprinkled?	Add sprinkler head in electrical room and front area not sprinkled.	CORRECTIVE ACTION PLAN

Reddy Ice - 426 S Hamilton ST - 706-278-1071

06/03/2021	Annual	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov	Does the emergency lighting system work correctly?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exits, other than main exits properly marked?	Install additional exit signage as discussed.	CORRECTIVE ACTION PLAN
				Are exit signs properly illuminated?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Are doors, passages, or stairways that could be mistaken as an exit marked NO EXIT?	Install NO EXIT signage as discussed.	CORRECTIVE ACTION PLAN
				Are extension cords being used correctly?	Extension cords shall not pass through walls. Extension cords shall not substitute permanent electrical wiring.	CORRECTIVE ACTION PLAN
				Are electrical rooms marked?	Install ELECTRICAL ROOM signage.	CORRECTIVE ACTION PLAN
				Are exits, or enclosures for stairways and ramps free of combustibles?	Remove compressed gas storage from the stairwell.	CORRECTIVE ACTION PLAN

Engine 4 C Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.

Christ The King Lutheran Church - 625 S Thornton AVE - 706-278-3979

06/23/2021	Annual	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov	Is required emergency lighting in place?	Repair or replace all non operational emergency lighting.	CORRECTIVE ACTION PLAN
				Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Multi plug adapters shall be mounted according to manufacturers recommended specifications. Install blanks in open spaces in electrical the electrical panel. A cover must be installed on electrical junction boxes.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install address signage.	CORRECTIVE ACTION PLAN

Longhorn Steak House - 1315 W Walnut AVE - 706-281-1568

06/21/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Working on fan replacement.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	-----------------------------	------------------------

Engine 5 A Shift

Dollar Tree - 1261 N Glenwood AVE

06/10/2021	OTC	Corrective Action Plan Given		Is address signage correct and in place?	Address signage should be visible from road.	CORRECTIVE ACTION PLAN
				Have sprinklers been maintained and in operational condition?	Install FDC signage. Install cap on FDC.	CORRECTIVE ACTION PLAN

Krystal - 1909 E Walnut AVE - 7066717136

06/21/2021	Site Visit	Passed with Comments	Acquisition of Hood system ventilation information.	Have all applicable code requirements been met?		CORRECTIVE ACTION PLAN
------------	------------	----------------------	---	---	--	------------------------

Engine 5 C Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Jack's - 1202 N Glenwood AVE - 706-920-2799

06/24/2021	Annual	Corrective Action Plan Given	All corrective actions regarding fire related equipment must be addressed by 6-28-2021.	Is required emergency lighting in place?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	36" clearance must be maintained in front of all electrical panels.	FAIL
				Has a Knox Box containing the property access keys been installed?	A key that accesses the building must be installed in the Knox Box	FAIL
				Are Class K fire extinguishers provided in cooking areas?	Class K extinguisher must be maintained in proper operating condition and requires a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	FAIL
				Has the cooking equipment been inspected and cleaned by a properly trained individual?	Hood system must be properly cleaned as scheduled.	FAIL
				Has the appropriately scheduled inspection of the entire exhaust system for grease buildup been conducted by a Georgia licensed contractor?		FAIL
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Installed fire extinguishers must be mounted and maintained in proper operating condition. Fire extinguishers require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	FAIL

Salon Garibaldi - 1309 Morris (East) ST - 706-508-9304

06/23/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Notified tannate of improper zoning for an event center. Building is zoned for heavy manufacturing and does not meet the minimum life safety requirements of having a sprinkler system and fire alarm. DPD and Building Inspector were present.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	---	------------------------

Ladder 3 B Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Baymont Inn & Suites - 2106 Chattanooga RD

06/03/2021	Annual	Corrective Action Plan Given		Have all applicable code requirements been met?	Don't use grill under awning. Grills should be at least 10 feet from the building. Ensure smoke alarms are properly maintained.	CORRECTIVE ACTION PLAN
				Components required to be fire or smoke resistant are properly maintained?	Ensure fire rated walls are properly sealed.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Add signage on electrical room doors. Extension cords should only be used for temporary power.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Hang fire extinguisher in lobby. Replace missing fire extinguisher.	CORRECTIVE ACTION PLAN

Benchmark Physical Therapy - 785 Shugart RD #Suite 10

06/18/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Install Knox Box. Install address signage. Install fire extinguishers as discussed.	CORRECTIVE ACTION PLAN
06/22/2021	OTC	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Knox Box has been ordered. Contact us once installed.	CORRECTIVE ACTION PLAN

Ladder 3 C Shift

Flash Graphics - 212 N Pentz ST - 706-278-7779

06/22/2021	Annual	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	--	--	---------------------------	------------------------

Log Cabin - 1001 Poly Pac DR - 706-259-4824

06/01/2021	Site Visit	Corrective Action Plan Given		Have all applicable code requirements been met?	Riser 3 down due to head being damaged during roof construction. ASA has been notified and will repair at the latest tomorrow.	CORRECTIVE ACTION PLAN
------------	------------	------------------------------	--	---	--	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Rail Side Tattoo/Hempheads - 102 Waugh (West) ST - 706-671-1124

06/16/2021	OTC	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Remove exposed electrical wiring. Install cover on electrical outlet. Extension cords should only be used for temporary power.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box on the building.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install code compliant fire extinguisher upstairs.	CORRECTIVE ACTION PLAN
				Has a Georgia licensed contractor performed the required annual external inspection, and a 6 year interval examination or hydrostatic test on the fire extinguishers?	Have fire extinguishers serviced by a GA licensed contractor.	CORRECTIVE ACTION PLAN

Squad 1 A Shift

Angela Moss Gordy; Certified Public Accountant - 605 S Thornton AVE - 706-279-1475

06/17/2021	Annual	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov	Are there any identifiable electrical hazards?	Install appropriate covers on switch plates and electrical outlets.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install address signage.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguishers. Installed fire extinguishers require a current annual inspection. The fire extinguishers must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Big Brothers Big Sisters of Northwest Georgia Mountains - 209 W Morris ST - 706-280-0702

06/22/2021	Site Visit	Passed with Comments	A 30 day extension has been granted.	Have all applicable code requirements been met?	A site visit was conducted to assess progress of required corrective actions. Progress has been made; a 30 day extension has been granted.	CORRECTIVE ACTION PLAN
------------	------------	----------------------	--------------------------------------	---	--	------------------------

Squad 1 B Shift

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Salon 315 - 315 W Franklin ST - 706-337-2487

06/23/2021	Annual	Corrective Action Plan Given	Email photos of corrected actions to dstratton@daltonga.gov	Have all applicable code requirements been met?	Apply for Occupational Tax Certificate. (OTC)	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	All multi plug adapters must be mounted according to manufacturers recommended specifications.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install a fire extinguisher. The fire extinguisher requires a current annual inspection. All installed fire extinguishers must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

U.S.Post Office - 100 S Thornton AVE

06/04/2021	Annual	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	--	--	---------------------------	------------------------

UGA Extension Office - 104 S Thornton AVE

06/04/2021	Annual	Corrective Action Plan Given	Extinguishers need to be inspected.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have extinguisher inspected by a licensed Georgia contractor. Have not been inspected since 2017	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	-------------------------------------	---	--	------------------------

Squad 1 C Shift

A-1 Lock & Security - 209 W Emery ST #Suite A

06/29/2021	Annual	Corrective Action Plan Given		Are there any identifiable electrical hazards?	Install the appropriate electrical outlet cover.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Fire extinguishers must be properly mounted and require a current annual inspection. The inspection must be conducted by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.

Alpha & Omega Insurance LLC - 209 W Emery ST #Suite B

06/29/2021	Annual	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov	Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguishers. Fire extinguishers must be properly mounted and require a current annual inspection. They must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Beautiful Smiles Dentistry - 509 S Thornton AVE - 706-226-9798

06/15/2021	OTC	Corrective Action Plan Given		Are compressed gas cylinders properly secured?	Secure compressed gas cylinders.	CORRECTIVE ACTION PLAN
				Is address signage correct and in place?	Install address signage.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install key in Knox Box.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Mount fire extinguisher.	CORRECTIVE ACTION PLAN

Congressional Office - 702 S Thornton AVE #A- 706-278-1767

06/29/2021	Annual	Corrective Action Plan Given	Extinguisher needs an inspection.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have extinguisher inspected by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	-----------------------------------	---	---	------------------------

Daily Citizen News - 308 S Thornton AVE - 7062176397

06/03/2021	Annual	Corrective Action Plan Given		Have all applicable code requirements been met?	Add FACP and Riser Room signage to bathroom door.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Remove cardboard from in front of electrical panel.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.

Kinard Realty - 702 S Thornton AVE #B AND C- 7062265182

06/29/2021	Annual	Corrective Action Plan Given	Inspect extinguishers.	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Have extinguishers inspected by a licensed Georgia contractor.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	------------------------	---	--	------------------------

Kinard Realty - 704 S Thornton AVE - 7062265182

06/25/2021	Annual	Corrective Action Plan Given	Extinguisher	Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Add appropriate extinguishers for structures from a licensed Georgia contractor.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	--------------	---	--	------------------------

McCamy, Phillips, Tuggle, and Fordham - 411 W Crawford ST - 706-278-4499

06/22/2021	Annual	Corrective Action Plan Given	Add Knox Box to building.	Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
------------	--------	------------------------------	---------------------------	--	---------------------------	------------------------

Mitchael A. Corbin Attorney at Law - 505 S Thornton AVE - 7062786670

06/07/2021	Annual	Passed with Comments	Email photos of corrected actions to dstratton@daltonga.gov	Are there any identifiable electrical hazards?	Multi plug adapters shall not be plugged into multi plug adapters. Multi plug adapters must be mounted according to manufacturers recommended specifications. Install switch plate covers.	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguisher as discussed. Extinguishers must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Robinson Door - 209 W Emery ST #Suite C

06/29/2021	Annual	Corrective Action Plan Given		Are exit signs visible?	Repair or replace all non operational exit signs.	CORRECTIVE ACTION PLAN
				Are there any identifiable electrical hazards?	Multi plug adapters shall not be plugged into multi plug adapters. Multi plug adapters must be mounted according to manufacturers recommended specifications.	CORRECTIVE ACTION PLAN
				Has a Knox Box containing the property access keys been installed?	Install Knox Box	CORRECTIVE ACTION PLAN
				Does the selection, distribution, installation, and maintenance of portable fire extinguishers comply with NFPA 10?	Install fire extinguishers. The fire extinguishers must be inspected and tagged by a Georgia licensed contractor.	CORRECTIVE ACTION PLAN

The Aesthetic At Trevitt - 111 N Hamilton ST

06/02/2021	OTC	Corrective Action Plan Given		Has a Knox Box containing the property access keys been installed?	Add Knox Box to building.	CORRECTIVE ACTION PLAN
------------	-----	------------------------------	--	--	---------------------------	------------------------

Occupancy Inspection History per Occupancy with Violations where Remarks are recorded on Page 2 of Inspection.



Dalton Fire Department

Dalton, GA

This report was generated on 7/13/2021 2:29:01 PM



StartDate: 06/01/2021 | EndDate: 06/30/2021

OCCUPANCY	COUNT
INSPECTION TYPE: Annual	
A-2 • Eating, drinking places, (other)	1
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	2
A-3 • Athletic/health club	1
A-3 • Places of religious worship	1
A-3 • Public or government (other)	2
B • Banks	2
B • Business office	10
B • Business, (other)	3
B • Motor vehicle or boat sales, services, repair	2
B • Post offices or mailing firms	1
B • Print shops	2
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	15
B • Professional supplies, services	1
E • High school/junior high school/middle school	1
F-1 • Clothing	1
F-2 • Ice	1
R-1 • Motels (transient)	1
R-4 • Social rehabilitation facilities	1
R: Residential, (other)	1
S-1 • Warehouse	2
INSPECTION TYPE: Fireworks	
H-3 • Consumer fireworks, 1.4G (Class C, Common)	3
INSPECTION TYPE: New Construction	
R-1 • Hotels (transient)	1
INSPECTION TYPE: OTC	
A • Assembly, (other)	1
A-2 • Eating, drinking places, (other)	1
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	1
B • Personal service, including barber & beauty shops	3
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	3
M • Convenience stores	1
M • Household goods, sales, repairs	1
M • Retail or wholesale stores	1
M • Department stores	1

Locked inspections only.



OCCUPANCY	COUNT
INSPECTION TYPE: Plan Review	
A-2 • Banquet halls	1
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	1
B • Specialty shop	1
E • Elementary school, including kindergarten	1
F-1 • Carpets and rugs (includes cleaning)	3
F-1: Moderate-hazard factory industrial	1
M • Convenience stores	1
M • General retail, (other)	1
M • Grocery store	1
S-1 • Aircraft hangar (storage and repair)	1
U • Outside or special property, (other)	1
INSPECTION TYPE: Reinspection	
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	1
INSPECTION TYPE: Site Visit	
A-2 • Banquet halls	2
A-2 • Eating, drinking places, (other)	1
A-2 • Restaurants, cafeterias and similar dining facilities (including associated commercial kitchens)	4
A-3 • Community halls	2
B • Business office	6
B • Business, (other)	3
B • Motor vehicle or boat sales, services, repair	1
B • Personal service, including barber & beauty shops	1
B • Professional services (architects, attorneys, dentists, physicians, engineers, etc.)	1
F-1 • Carpets and rugs (includes cleaning)	2
F-2: Low-hazard factory industrial	1
R-1 • Hotels (transient)	1
R-2 • Apartment houses	2
R-4 • Residential board and care facilities	1
S-1 • Glues, mucilage, pastes and size	1
S-1 • Warehouse	1

Locked inspections only.

