

| Department          | Location                   | Address                 | Size kW        | Voltage/Phase | Fuel            | Main Size(Amps) | Brand                    | Model #         | Serial #          | Install Date<br>Date of mfg. | 2 Hour Load Bank Test<br>Required |      |      |      |      | Notes                   |
|---------------------|----------------------------|-------------------------|----------------|---------------|-----------------|-----------------|--------------------------|-----------------|-------------------|------------------------------|-----------------------------------|------|------|------|------|-------------------------|
|                     |                            |                         |                |               |                 |                 |                          |                 |                   |                              | 2025                              | 2026 | 2027 | 2028 | 2029 |                         |
| Buildings & Grounds | City Hall                  | 38 1st Street West      | 200            | 120/208       | Natural Gas     | 30              | Rolls Royce              | RG04845GNAX     | 3014245696        | 2023                         | X                                 | X    | X    | X    | X    | Load test twice a year  |
| Buildings & Grounds | Public Safety Center (1)   | 2475 State Avenue North | 140            | 480/3         | NG w/LP back up | 225.5           | Generacs                 | MGO150KG189     | 9739193           | 6/18/2015                    | X                                 | X    | X    | X    | X    | Load test quarterly     |
| Buildings & Grounds | Public Safety Center (2)   | 2475 State Avenue North | 140            | 480/3         | NG w/LP back up | 225.5           | Generacs                 | MGO150KG189     | 9739194           | 6/18/2015                    | X                                 | X    | X    | X    | X    | Load test quarterly     |
| Buildings & Grounds | Public Safety Center (3)   | 2475 State Avenue North | 140            | 480/3         | NG w/LP back up | 225.5           | Generacs                 | MGO150KG189     | 9739195           | 6/18/2015                    | X                                 | X    | X    | X    | X    | Load test quarterly     |
| Buildings & Grounds | Public Works Building      | 3411 Public Works Blvd  | 1000           | 277/480       | Diesel          | 1503.6          | Cummins Power Generation | DQFAD-1340532   | K130597337        | Nov-13                       | X                                 | X    | X    | X    | X    | Load test twice a year  |
| Buildings & Grounds | Armory                     | 46 W Museum Dr          | 100            | 208           | Natural Gas     | 60              | Generac                  | QT10054GNSN     | 4881220           | 8/27/2007                    |                                   |      |      |      |      |                         |
| Buildings & Grounds | Old Street Shop            | 615 W Broadway          | 100            | 240/3         | Natural Gas     | 400             | Generac                  | QT15068GNSN     | 4880615           | 8/24/2007                    |                                   |      |      |      |      |                         |
| Buildings & Grounds | Fire Hall - Station #1     | 25 2nd Ave West         | 60             | 210           | Natural Gas     | 60              | Generac                  | QT06030GNSN     | 4879831           | 8/23/2007                    | X                                 | X    | X    | X    | X    | Load test quarterly     |
| Buildings & Grounds | Animal Shelter             | 3405 Public Works Blvd  | 48             | 120/208       | Natural Gas     | 167             | Generac                  | RG04845GNAX     | 3014245696        | 11/10/2023                   | X                                 | X    | X    | X    | X    | Load test twice a year  |
| Buildings & Grounds | Museum                     | 188 Museum Drive E      | 5              | 120           | Natural Gas     | 20.8            | ONAN POWER PLANT 2 CYCLE | 5CCKFJ          | 3195U             | Nov-08                       |                                   |      |      |      |      |                         |
| Buildings & Grounds | Old Water Department       | 625 West Broadway       | Not Being Used |               |                 |                 | GENERAC                  | 10054GNSN       | 4881224           | 8/27/2007                    |                                   |      |      |      |      |                         |
| Solid Waste         | Baler Building             | 3389 Energy Dr          | 200            | 480/3         | Diesel          | 60              | Winnpower                | DR35014LAS      | 200729001         | Oct-07                       |                                   |      |      |      |      |                         |
| Sewer Collection    | Trailer #47 - Portable     | 3411 Public Works Blvd  | 20             | 208/3         | Propane         | 60              | Generac                  | QT02016GNSN     | 4876288           | 8/17/2007                    |                                   |      |      |      |      |                         |
| Sewer Collection    | Trailer # 25 - Portable    | 3411 Public Works Blvd  | 20             | 208           | Propane         | 60              | Generac                  | QT02016GNSN     | 4822498           | 5/6/2007                     |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift # 1                   | 500 East Broadway       | 100            | 240/3         | Natural Gas     | 60              | CAT                      | DG150           | T4500373          | 9/3/2019                     |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift # 2                   | 101 3rd St SE           | 20             | 240 /3        | Natural Gas     | 60              | Generac                  | QT2016GNSN      | 4954856           | 2/11/2008                    |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift #4                    | 460 South Main          | 20             | 240 /3        | Natural Gas     | 100             | Generac                  | QT2016GNSN      | 4876286           | 8/17/2007                    |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift # 5                   | 300 5th St SW           | 200            | 240 /3        | Diesel          | 125             | ONAN/Cummins             | DSGAE-1609642   | C160935940        | Mar-16                       |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift # 7                   | 820 West Broadway       | 30             | 240 /3        | Natural Gas     | 150             | Generac                  | QT3016GNSN      | 4875123           | 8/13/2007                    |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift #10                   | 672 12th St West        | 20             | 240 /3        | Natural Gas     | 30              | Generac                  | QT2016GNSN      | 4876285           | 8/17/2007                    |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift #11                   | 1307 Sims               | 100            | 208 /3        | Natural Gas     | 400             | Generac                  | QT10054GNSN     | 4881219           | 10/26/2001                   |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift #12                   | 989 15th St West        | 600            | 480/3         | Diesel Fuel #1  | 902             | CAT                      | 600             | CAT00C18TNAW00229 | 6/1/2015                     |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift #14                   | 977 21st St E           | 100            | 480/3         | Natural Gas     | 150             | Generac                  | G100LG4         | GXG04404          | 8/1/2016                     |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift #18                   | 1073 Sims               | 130            | 208 /3        | Natural Gas     | 200             | Generac                  | QT13068KNSY     | 5866864           | 2011                         |                                   |      |      |      |      |                         |
| Sewer Collection    | Lift #20                   | 1820 Yellowstone Cicle  | 150            | 480/3         | Natural Gas     | 200             | Generac                  | SG0150KG036     | 872868            | 11/1/2014                    |                                   |      |      |      |      |                         |
| Sewer Collection    | Hwy10 Lift #21             | 11470 Hwy 10            | 360            | 480/3         | Diesel Fuel #1  | 541             | Kohler                   | 350REOZJB       | SGM32BCT8         | 4/1/2014                     |                                   |      |      |      |      |                         |
| Sewer Collection    | West Pump Station Lift #22 | 2486 Villard St W       | 600            | 480/3         | Diesel Fuel #1  | 902             | CAT                      | 600             | CAT00C18LNAW00192 | 1/1/2014                     |                                   |      |      |      |      |                         |
| Sewer Collection    | Influent Pump Station      | 485 10th Ave SE         | 1612           | 480/3         | Diesel Fuel #1  | 2406            | Stamford                 | P1734D1         | X13L522717        | 2/1/2014                     | X                                 | X    | X    | X    | X    | Load test once per year |
| Water Distribution  | Million Gallon Res.        | 450 10th Ave East       | 150            | 480/3         | Natural Gas     | 400             | Generac                  | QT15068KNSN     | 4873321           | 5/17/2007                    |                                   |      |      |      |      |                         |
| Water Distribution  | Northeast/4th Ave E Tank   | 601 4th Ave East        | 20             | 240/3         | Natural Gas     | 30              | Generac                  | 153361          | 4713977           | 2/7/2007                     |                                   |      |      |      |      |                         |
| Water Distribution  | 10th Ave E Booster Station | 1378 10th Ave East      | 130            | 480/3         | Propane         | 300             | Generac                  | QT13068KVSN     | 4885065           | 5/9/2007                     |                                   |      |      |      |      |                         |
| Water Distribution  | State Ave Tank             | 2430 15th St W          | 7.5            | 240/3         | Natural Gas     | 66.6            | Generac                  | MPL0064622      | 10033553          | 12/19/2006                   |                                   |      |      |      |      |                         |
| Water Distribution  | State Ave Booster          | 3052 State Ave          | 500            | 480/3         | Diesel          | 751.8           | Cummins                  | DFEK-1626943    | G160978801        | 7/26/2016                    |                                   |      |      |      |      |                         |
| Water Distribution  | River Road Booster         | 140 6th Ave SE          | 450            | 480/3         | Diesel          | 676.6           | Generac                  | 450DFEK         | G160978803        | 7/26/2016                    |                                   |      |      |      |      |                         |
| WRF                 | WRF Booster                | 10816 38th St SW        | 400            | 480/3         | Diesel          | 601             | CAT                      | D400GC          | CatOD400E54400108 | 2/20/2018                    | X                                 |      |      |      |      | Load test in 2025       |
| WRF                 | Waster Water Plant         | 10816 38th St SW        | 2080           | 277/480       | Diesel          | 3007.1          | Cummins                  | DQKAB - 1332714 | G130537876        | 5/16/2013                    | X                                 | X    | X    | X    | X    | Load test once per year |