

OFFICE OF
PLANNING, ZONING AND
HISTORIC PRESERVATION
108 Sherman Street
Telephone (605) 578-2082
Fax (605) 722-0786



Kevin Kuchenbecker
Planning, Zoning and
Historic Preservation Officer
Telephone (605) 578-2082
kevin@cityofdeadwood.com

MEMORANDUM

Date: February 9, 2026
To: Deadwood City Commission
From: Kevin Kuchenbecker, Historic Preservation Officer
Re: Adams Museum Chime System Additional Electrical Wiring

The Adams Museum Chime project was completed in December of 2025. Since the installation there has been electrical issues. It is believed the issue is caused from the wiring not being replaced from the chimes to the electrical box. New wiring was installed with the chimes portion of the project. This has caused an unforeseen issue with the operation of the chimes.

Deadwood Electric has submitted a quote to replace the wiring from the chimes to the electrical box. The proposed quote is \$8,453.38. Chime Master Top Rung Tower Chime will be paying \$2,500.00 towards the wiring project leaving \$5,953.38 to be paid by the City of Deadwood. Staff recommends hiring Deadwood Electric to replace the wiring at the Adams Museum for the electrical wiring of the chimes \$5,953.38 being paid out of the Capital Assets line item.

Motion: *Move to hire Deadwood Electric in the amount of \$5,953.38 to replace the wiring for the chimes at the Adams Museum to be paid out of the capital assets line item. The remaining \$2,500.00 will be paid by Chime Master Top Rung Tower Chime.*