



RAPID CITY, SD
(605) 341-3473

INVOICE

Invoice No: 115007562
Invoice Date: 9/16/2022
Work Order: 115009766
Complete Date: 9/15/2022
PO Number: FIRE DEPT
Alt WO Number:
Customer ID: CITYOFD545
Terms: Net 30

Bill to: City Of Deadwood - Public Bldg
 102 SHERMAN ST
 DEADWOOD, SD 57732-1309

Service at: CITY OF DEADWOOD - PUBLIC BLDG
 PUBLIC BLDGS
 DEADWOOD, SD 57732

Description	Quantity	Rate	Amount
5 LB Dry Chemical Ext. Low Pressure Hydro Test	1.00	44.00	44.00
10 LB Dry Chemical Ext. Low Pressure Hydro Test	2.00	57.00	114.00
10 LB Dry Chemical Extinguisher 6-Yr Maintenance	4.00	36.00	144.00
10 LB Dry Chemical Extinguisher Recharge	1.00	36.00	36.00
20 LB Dry Chemical Ext. Low Pressure Hydro Test	2.00	74.00	148.00
10 LB CO2 Extinguisher High Pressure Hydro Test	1.00	58.00	58.00
Fire Extinguisher Annual Inspection	17.00	3.00	51.00
Truck Charge	1.00	50.00	50.00
Technician Labor	0.52	0.00	0.00
Technician Labor	0.73	0.00	0.00
PTS VLV STEM ASSY DRYCHE AX	9.00	19.00	171.00
5241A O RING OR27	10.00	5.00	50.00
PTS VLV STEM ASSY DRYCHE BADGER	1.00	19.00	19.00
PTS VERF COLLAR	10.00	0.00	0.00
AX DRYCHE 5# ABC AL HSE&HRN VHCL BKT	1.00	164.00	164.00
ANS DRYCHE 10# ABC AL HSE&HRN NOBKT	1.00	281.00	281.00
442255 ANS ABC CLEAN GUARD 5LB	2.00	864.00	1,728.00

Work Description: Annual fire extinguisher inspections

To Pay by Check or Credit Card
 (651) 272-3251

Account Inquiries
ar@summitcompanies.com

MAKE CHECKS PAYABLE TO
 SUMMIT FIRE PROTECTION
 PO BOX 6205
 CAROL STREAM, IL 60197-6205

PAY ONLINE:
<https://securepayment.link/summitfireprotection/>

Subtotal:	3,058.00
Sales Tax:	0.00
Payments:	0.00
Total Due:	\$3,058.00

Cust: CITYOFD545

Inv: 115007562



SERVICE REPORT

WORK ORDER:

115009766

DATE: 09/15/2022

CUSTOMER: CITY OF DEADWOOD - PUBLIC BLDG (AR#:CITYOFD545)
STREET: PUBLIC BLDGS
CITY: DEADWOOD, SD 57732
CONTACT: TOM

CALL TYPE: Service - Fire Extinguisher

TROUBLE REPORTED: ALL

WORK PERFORMED: Annual fire extinguisher inspections (Lanphear; Anthony D on Sep 15, 2022)

PARTS	
QUANTITY	DESCRIPTION
9	PTS VLV STEM ASSY DRYCHE AX
10	5241A O RING OR27
1	PTS VLV STEM ASSY DRYCHE BADGER
10	PTS VERF COLLAR
1	AX DRYCHE 5# ABC AL HSE&HRN VHCL BKT
1	ANS DRYCHE 10# ABC AL HSE&HRN NOBKT
2	442255 ANS ABC CLEAN GUARD 5LB
1	5 LB Dry Chemical Ext. Low Pressure Hydro Test
2	10 LB Dry Chemical Ext. Low Pressure Hydro Test
4	10 LB Dry Chemical Extinguisher 6-Yr Maintenance
1	10 LB Dry Chemical Extinguisher Recharge
2	20 LB Dry Chemical Ext. Low Pressure Hydro Test
1	10 LB CO2 Extinguisher High Pressure Hydro Test
17	Fire Extinguisher Annual Inspection
1	Truck Charge^(Service-FE) Non-Agreement

LABOR		
DATE	LABOR	TECHNICIAN/DESC
Sep 15, 2022	0.52	Lanphear; Anthony D (Technician Labor)

IS JOB COMPLETE? Yes

Customer

Name:
Date: 09/15/2022 11:28 AM
Comments:

Email

RMCGRATH@CITYOFDEADWOOD.COM,

Employee

Name: Anthony Lanphear
Date: 09/15/2022 11:28 AM
Comments: