

Return Completed Form To:
Planning and Zoning
108 Sherman Street
Deadwood, SD 57732



Questions Contact:
Jeremy Russell
(605) 578-2082 or
jeramyr@cityofdeadwood.com

Mobile Food Vehicle Fire Safety Inspection/Checklist

This document provides guidance regarding Fire Code requirements applicable to mobile food vehicles (i.e. food trucks, carts, trailers, etc.) operating within the city limits of Deadwood. These requirements are in addition to applicable public health and safety requirements determined by South Dakota Department of Health.

Date: ___ Business Name: _____ State/Vehicle License Plate# _____

Unless otherwise noted, references are from City of Deadwood adopted model codes and NFPA documents.

Instructions: Please place a checkmark in each box that applies below. If you have any questions, please contact Trent Mohr, Building Official at 605-578-2082.

A. LPG Containers, Piping and Appliances

- ☐ Approved LPG cylinders/containers shall be used and secured in the upright position.
- ☐ LPG cylinders, piping, valves and fittings located outside the mobile food facility shall be adequately protected to prevent tampering, damage by vehicles, or other hazards.
- ☐ All interior appliances shall be of an approved type.
- ☐ Cooking equipment used outside of the mobile food facility shall be approved by the Fire Code Official.
- ☐ Appliances shall not block exiting from a food truck.

B. Hood System

- ☐ Commercial cooking equipment that produces grease laden vapors shall be provided with a Type I hood (a kitchen hood for collecting and removing grease and smoke).
- ☐ A listed and labeled fire extinguishing system is required in a Type I hood.
- ☐ Extinguishing system serviced every 6 months and be provided with a tag.

C. Fire Extinguishers

- ☐ All cooking vehicles shall have a 2A10BC rated fire extinguisher.
- ☐ K type fire extinguisher shall be provided for Type I hood.
- ☐ Minimum 40BC rated fire extinguisher shall be provided for generators.

D. Electrical

- ☐ Generators shall be placed in locations approved by the Fire Code Official. Placement shall be a minimum of 20 feet from tents and canopies, inaccessible to the public and cordoned off with caution tape.
- ☐ Refueling of approved generators is prohibited during event hours or when public is in attendance.

E. General Requirements

- ☐ No smoking signs posted
- ☐ Operational permit required to be posted or available upon request of city staff.

Comments

Owner/Operator Signature: _____
(if submitting this form electronically, typed name is treated as if it were a signed original)

Date: _____