



November 21, 2023

Mr. Jon McCraw
 City Manager
 City of Diamondhead
 5000 Diamondhead Circle
 Diamondhead, MS 39525

**Re: Punch List from Final Inspection
 Makiki Drive Drainage Improvements
 City of Diamondhead**

Dear Mr. McCraw,

Enclosed, for your review and approval, is the Certification of Substantial Completion for the Makiki Drive Drainage Improvements constructed by Bottom 2 Top Construction, LLC. Listed below are the punch list items noted during the Final Inspection performed on November 21, 2023.

The following were the individuals present during the Final Inspection.

City of Diamondhead	B2T Construction	Covington Civil & Environmental
Jon McCraw	Joseph Raffeo John Dellinger Randall Fox	Andrew Levens Ryan Ladner

1. Area behind downstream wingwall has eroded/settled on both the east and west sides. Add rock and slurry to stabilize.
2. Build-up shoulders with "610" limestone.
3. Clean out asphalt from riprap.
4. Add riprap or slurry to holes where lacking in coverage.
5. Remove sediment from wingwall aprons.



Respectfully,

COVINGTON CIVIL & ENVIRONMENTAL, LLC

A handwritten signature in blue ink that reads "Andrew Levens".

Andrew Levens, P.E.
Engineering Manager

Enclosures: Certificate of Substantial Completion

Cc: Joseph Raffeo jraffeo@bottom2top.net
John Dellinger john@bottom2top.net

