

**DEPARTMENT OF HOMELAND SECURITY
U. S. Coast Guard
FACILITY INSPECTION REQUIREMENTS**

1. Date of Inspection 13JUN25	2. COTP Zone / Unit WESTERN AK & US ARCTIC	3. MISLE Activity Number TBD	4. FIN INC-D-012
---	--	--	----------------------------

5. Facility Name PORT OF DILLINGHAM	6. Inspection Type ANNUAL 126
---	---

Contact the inspecting officer to verify compliance when the following item(s) have been corrected.

Description	Cite	Due Date
LIGHTING THAT ILLUMINATES THE TRANSFER WORK AREA MUST OF ADEQUATE BRIGHTNESS. REPAIR OR REPLACE OUTDOOR LIGHTING USED DURING NIGHT TIME TRANSFERS. MST3 Km SL	33 CFR 126.15(a)(4)	PRIOR TO NEXT INSPECTION
EQUIPMENT AND VEHICLES EQUIPPED WITH INTERNAL COMBUSTION ENGINES MUST HAVE PORTABLE FIRE EXTINGUISHERS. EQUIP FORK-LIFTS, TRUCKS AND GENERATORS WITH SERVICED BIG TYPE FIRE EXTINGUISHERS.	33 CFR 126.15(a)(2) 33 CFR 126.15(b)(2)	23JUN2025
ALL RUBBISH/DEBRIS/WASTE MATERIALS MUST BE PLACED IN ADEQUATE RECEPTACLES. DISPOSE OF THE RUBBISH/DEBRIS/WASTE MATERIALS PILE BY THE ALASKA COMMERCIAL STORE BUILDING.	33 CFR 126.15(a)(11)	31AUG2025
AREAS WHERE DANGEROUS CARGOES ARE STORED OR TRANSFERRED MUST HAVE LIMITED ACCESS. PREVENT UNAUTHORIZED ACCESS TO THE FACILITY WHEN STORING OR TRANSFERRING DANGEROUS CARGO. MST3 M 2	33 CFR 126.15(a)(6)	PRIOR TO NEXT INSPECTION
N.F.E.		

Facility Representative: (print) Daniel Miller, Port Director	Signature: 
USCG Inspector: (print) MST3 GRANT GEHRIG	Signature: 
Phone: 907-538-3874	Email: WESTERNALASKAFACILITIES@USCG.MIL