

Sean Homyen

From: Robert Miller Jr. <robert@klswa.com>
Sent: Thursday, April 30, 2026 1:45 PM
To: Sean Homyen
Cc: Ken Bosma
Subject: 47 W Center Comments

Follow Up Flag: Follow up
Flag Status: Flagged

Hi Sean,

1. Show sanitary connection to Center and call-out material
2. Suggest to move water connection to 8" DI on Center vs 6" cast as shown

Otherwise, all set.

Thanks!

Robert Miller

Administrator

Kalamazoo Lake Sewer & Water Authority

6449 Old Allegan Road

P.O. Box 789

Saugatuck MI 49453

robert@klswa.com

(269)857-2709

