

Every attempt has been made to produce error free documents, it is the responsibility of the builder and/or the client to verify all existing conditions, dimensions, details, code compliance and specifications preceding commencement of work. In acceptance of these documents, the engineer takes full responsibility for changes, errors and/or omissions, but is relieved of these responsibilities once these documents have been accepted by the way of client signature. The design and original drawings of this project remain the property of M/JW Consulting, Inc. and no additional persons or parties may use the design or drawings for any other purpose without the consent of M/JW Consulting, LLC and Michael J. Wysocki.

©2015 COPYRIGHT MJW CONSULTING, LLC
Rights Reserved

STATISTICS		
DESCRIPTION	AVG	MAX
SITE	1.3 FC	25.8 FC

SITE LIGHTING FIXTURE SCHEDULE						
TAG	MARK	DESCRIPTION	MANUFACTURER/MODEL	LAMPS	INPUT WATTS	MOUNTING
A1	○ _{A1}	LED AREA LIGHT	RSX2 LED P1 40K RS4 HS	LED 2700K	72	POLE MOUNT 20' AFF
	○ _{V1}	FRONT DOOR MAIN EXTERIOR	SAFAVEH 9L PRO3JA	LED 3000K	9	EXTERIOR WALL MOUNT
W1	○ _{V2}	ARCHITECTURAL EXTERIOR SCENCE	GENERATION LIGHTING 890901EN3	LED 3000K	9	EXTERIOR WALL MOUNT



ISSUED FOR	DATE
REVIEW	05/30/26

ADDITIONS AND ALTERATIONS

THE DUTCHER HOTEL

86 CENTER STREET
DOUGLAS, MI 49406

SITE LIGHTING PLAN

ISSUED 05/30/26	SHEET NUMBER SL1.0
JOB NUMBER 26-350	



SITE LIGHTING PLAN

SCALE 3/32"=1'-0"