

City of



Dover

DATA SHEET FOR SITE DEVELOPMENT PLAN REVIEW

DEVELOPMENT ADVISORY COMMITTEE MEETING of October 4, 2023

PLANNING COMMISSION MEETING of October 16, 2023

Plan Title: Delaware State University New Agriculture Building

Plan Type: Site Development Plan

Owner: State of Delaware c/o Delaware State University

Project Engineer: Becker Morgan Group

Location: Delaware State University Main Campus at Baseball Field area in the southwestern portion of campus near intersection of University Drive and Loop Road

Property Address: 1200 N. Dupont Highway

Tax Parcels: ED-05-057.00-01-19.00
ED-05-057.00-01-20.00
Portion of ED-05-057.00-01-21.00

Site Area: 287.32 acres +/- (Entire Campus)
240.29 acres +/- (Portion of Campus on north side of College Road)

Project Area: 3.44 acres +/-

Zoning: IO (Institutional and Office Zone)
SWPOZ (Source Water Protection Overlay Zone): Tier 3 Excellent Recharge Area

Existing Use: University Campus – Baseball Field
Proposed Use: University Campus – Academic Building

Building Area: 10,402 SF

Sanitary Facilities: City of Dover

Water Supply: City of Dover

Waivers Requested: None

CITY OF DOVER

DEVELOPMENT ADVISORY COMMITTEE

APPLICATION REVIEW COMMENTARY

D.A.C. MEETING DATE: October 4, 2023

APPLICATION Delaware State University New Agriculture Building at 1200 North Dupont Highway

FILE #: S-23-18

REVIEWING AGENCY: City of Dover Planning Office

CONTACT PERSON: Katherine Oehmke

PHONE #: 302.736.7196

I. PLAN SUMMARY

This application is for the review of a Site Development Plan for a new 10,402 SF Building on the Delaware State University Campus for the Agricultural Department. This single-story building will be placed in the former baseball field on the west side of campus. The project will demolish the existing bleachers, dugout boxes, batting cage, existing parking, and press box. The new Site Plan outlines a parking lot in front of the building with 2 new entrances to the site from University Drive. The building will house offices and classrooms. A new storm water management system is shown on the south entrance off University Drive. This project is on the north side of the corner of Loop Road and University Drive.

The property is zoned IO (Institutional and Office Zone) and subject to the SWPOZ (Source Water Protection Overlay Zone). It is located on the westerly side of the Delaware State University main campus which the entirety is addressed as 1200 N. Dupont Highway. Tax Parcel IDs: ED-05-057.00-01-19.00, ED-05-057.00-01-20.00, and a portion of ED-05-057.00-01-21.00-000. Council District 4.

II. PROJECT DESCRIPTION

The project will redevelop the existing Baseball Field area. The Site Development Plan proposes the construction of a 10,402 square foot building for classrooms and offices. The new one-story building will be freestanding. There will be 31 parking spaces along the front of the building, including 2 handicap accessible spaces. There will be a network of sidewalks connecting the new building with the rest of the campus.

III. ZONING REVIEW

IO (Institutional and Office Zone)

The Delaware State University Campus property is zoned IO (Institutional and Office Zone). The application is a Site Plan for the proposed construction of another educational building which is an allowed use in the IO Zone per *Zoning Ordinance*, Article 3, Section 10. The IO Zoning district is subject to the bulk standards found in Article 4, Section 4.14. With the proposed building being internal to the campus, it will be compliant with the setbacks and complies with the height limitations. Additionally, the campus has a variance for a reduction in the number of parking spaces. Delaware State University also has a centralized waste collection area, so no on-site dumpsters would be required.

SWPOZ – Source Water Protection Overlay Zone: Tier 3 -Excellent Recharge Area

The purpose of the Source Water Protection Overlay Zone (*Zoning Ordinance* Article 3 §29) is to provide a safe drinking water supply and to ensure that groundwater is adequately protected and maintained. A significant portion of the Delaware State University Campus on the north side of College Road is subject to the Tier 3: Excellent Recharge Area and the provisions for Article 3, Section 29.7. The entire Project Area is with the SWPOZ: Tier 3 Excellent Recharge Area.

The following uses listed below are prohibited throughout the SWPOZ, including in the Tier 3 area. However, this development does not appear to include any prohibited uses.

Zoning Ordinance, Article 3 Section 29

29.51 *Uses prohibited:*

- a) Automobile body/repair shop, motor vehicle, boat or farm equipment service;
- b) Gas stations and motor vehicle service stations;
- c) Fleet/trucking/bus terminal;
- d) Dry cleaner;
- e) Electrical/electronic manufacturing facility;
- f) Machine shop;
- g) Metal plating/finishing/fabricating facility;
- h) Chemical processing/storage facility;
- i) Wood preserving/treating facility;
- j) Junk yard/scrap yard/salvage yard;
- k) Mines/gravel pit;
- l) Land divisions resulting in high density (> one unit/acre) septic systems;
- m) Equipment maintenance/fueling areas;
- n) Injection wells/dry wells/sumps, except for single-family residences directing gutter downspouts to a drywell;
- o) Underground storage tanks;
- p) All uses not permitted in the underlying zone district.

Tier 3 – Excellent Recharge Area Lands are additionally subject to specific rules for impervious surfaces. The Plan has provided information that within the Project Area of 3.44 acres the amount of impervious surface coverage will change from 30,797 SF (20.6%) to 33,730 SF (22.5%). (*Note: Some information reported in the Plan's data column must be clarified.*) In the Project Area, the amount of impervious surface remains under the maximum of 30% impervious coverage. When looking at the overall Campus (north of College Road) located within the SWPOZ, the total impervious surface coverage is 34.43% and will increase to 34.52% requiring the increase to be infiltrated as part of the Stormwater Management Plan unless deemed contrary to other conditions imposed by DNREC. This will be reviewed as part of the Stormwater Management Plan by the Department of Natural Resources and Environmental Control (DNREC).

IV. PARKING SUMMARY

For the New Agriculture Building, there are 2 entrances to the parking lot outlined from University Drive (internal to the Campus). Curbing is shown to completely surround the parking lot providing water direction for proposed drainage. Based on the size of the building and the parking rate for the IO zone of one parking space per 300 SF of floor area, the Building requires 35 parking spaces. While providing 31 new spaces for this site, two handicapped spaces are centrally across from the front entrance to the building. The remaining four parking spaces (not constructed) can be provided from the Campus Parking surplus.

There is a centralized parking plan for the Delaware State University campus. Per the Campus Parking Plan, the Board of Adjustment set the required number of parking spaces needed for the Delaware State University Campus at 1,650 parking spaces per Article 6 Section 3.8 of the *Zoning Ordinance* on April 15, 2009 (V-08-19). The current number of parking spaces on campus is estimated to be 2,243 parking spaces with a surplus of 335 parking spaces. (The last estimate was 2,212 spaces per Site Plan S-17-29). This project will remove 8 parking spaces and construct only 31 new parking spaces; therefore, four (4) spaces should be allocated from the surplus spaces. These parking calculations must be confirmed.

Bicycle Parking

Bicycle parking is required at the rate of 1 bike per 20 automobile parking spaces. The 31 parking spaces would amount to 2 bike spaces. This plan has outlined 4 bike spaces.

V. SITE CONSIDERATIONS

Access

There are multiple access points to the Delaware State University Campus. Delaware State University Drive is off Old College Road. The parking lot of the new Agriculture Building is directly off University Drive on the west side of campus. On the corner of Loop Road and University Drive. Two entrances are shown onto the site into the parking lot with a clear Fire Lane demarcation.

Lighting

There are 13 new lights on the plan for the new site. These light fixtures surround the parking lot and provide light for the front and north side of the building. There are an additional 2 lights along University Drive that show as previously existing.

Dumpster

Dumpsters do not appear on the site plan. The university has a centralized waste management system.

Sidewalks

There is an extensive sidewalk system moving around campus and the proposed new building has its main entrance off the parking lot into the east side of the building. A new sidewalk is shown along University Drive and has a connection to the rest of the campus on the northern side of the site. The sidewalk runs along the front and north side of the building.

VI. BUILDING ARCHITECTURE

The new Agricultural Building is a low single-story building with a central entrance covered by a flat metal canopy. The height of the middle of section of building is higher with large windows reaching to a metal panel wall surface at the height of the roof. The south side of the building is encased in running bond brick veneer with a thick band of Flemish bond brick veneer over the aluminum storefront windows. The right side of the building has fiber cement wood paneling outlined with horizontal metal panels making way for recessed areas topped with high windows. The back entrance is also recessed providing an alcove that could protect the entrance from cross winds. The southeast face of the building wraps to the south face of the building with 9 storefront windows. The north side of the building is windowless and provides texture variation with wood and metal materials. There are 2 exit doors and a loading door.

VII. SPECIAL FLOOD HAZARD AREAS

Flood Hazard Area

The *Zoning Ordinance*, Article 5 §11.21 requires that special flood hazard areas (100-year floodplain) remain as open natural areas with no impervious surfaces.

Portions of the Delaware State University campus property are within the Special Flood Hazard Area (100-year floodplain/ 1% chance of annual flooding). This property is found on the FEMA FIRM Panel of Kent County Delaware Map Number 10001C0166H effective date May 5, 2003. The flood hazard area is in the western area of the campus adjacent to the Fork Branch. This subject project area is not located in the special flood hazard area.

VIII. TREE PLANTING AND LANDSCAPE PLAN

Development Area

The project site development area consists of 3.44 acres. Overall, the existing impervious area will increase by 5.8% to 22.5% total.

Tree Plantings

The submitted plan includes the landscaping approach for the overall project. *Zoning Ordinance*, Article 5, Section 16.62 offers the option of the applicant defining a “Development Area” within the overall property for the purpose of tree planting calculations. Planning Staff is equating the delineated project area shown on the plan as the “Development Area”. The Development Area of the New Agricultural Building is 3.44 acres (150,000 square feet). This area is predominately void of trees and only 2 trees at the southeast corner of the development area will be cleared. A total of 50 trees are being added to the site which complies with the calculation rate of 1 tree per 3000 S.F. of development area. Many of the trees on the planting schedule are of the evergreen variety as Colorado Blue Spruce and Eastern Red Cedars. Additionally, there are 15 canopy trees and 9 understory trees. A line of trees extends down the west side (rear) of the building, the north side, and along the front. A group of 10 trees shields the building from Loop Road on the south.

Arterial Street Buffer

North DuPont Highway (U.S Route 13) is considered as a principal arterial and requires a thirty (30) foot landscape buffer along the road frontage known as an Arterial Street Buffer. The buffer is measured from the edge of the right-of-way. The University campus provides this required thirty (30) foot landscape buffer along DuPont Highway which includes tree plantings, landscape plantings of shrubs and annuals, and a brick wall. Activities of this Site Development Plan do not impact the Arterial Street Buffer.

IX. CITY AND STATE CODE REQUIREMENTS:

The subject proposal has been reviewed for code compliance, plan conformity, and completeness in accordance with the agency’s authority and area of expertise. The following items have been identified as elements which need to be addressed by the applicant:

- 1) Please replace all references of Public Works to Department of Water/Wastewater.
- 2) Sheet C-001, Site Data Column:
 - a) Item 9: Confirm if the existing impervious to remain (5,986 SF) is included in the Proposed Project Site Impervious Coverage of 33,730 SF. Revise calculations if

- necessary, including total impervious surface and associated percentages. Update information in total campus calculations also.
- b) Item 11: The number 10,400 does not match the number listed on the building starting page C-301. Verify and make adjustments to the plan set with the correct number.
 - c) Item 14: Verify the calculation for the “Current Campus Surplus”. Also update the remaining parking surplus to reflect parking spaces made and the spaces need to comply with the required parking rate.
 - d) Item 19: the acreage is listed as 150,000 sq feet which translates to 3.44352617 acres. This is slightly more than Item 8 which lists 3.44 acres. Landscape plans (L-001) lists 149,950 square feet. The number should be consistent. Once decided, please also make sure the cover page map label is updated (potentially with “+/-“ or “approx.”).
- 3) Page C-101: Comment R-5, A demo permit will be required for the ball field location.
- 4) Page C-201:
- a) The locations of the 2 stop signs are labeled T-6, and should be T-13.
 - b) The location of the second handicapped parking sign is labeled as a stop sign. Likely should be labeled T-15.
 - c) The sidewalk width should be specified along University Drive.
 - d) The Striping and Signage section has note at the bottom that references Detail page C-901 which is not included. Please include it with final submission.
- 5) Page C-301: Notes at the bottom of the page reference Page C-302 which are not included. Please include these in the final set submitted.
- 6) Any Sediment & Stormwater Management Plans granted approval by DNREC must reflect the Site Plan layout and design conditionally approved by the Planning Commission and be in compliance with the *Zoning Ordinance* and technical review requirements of other agencies.
- 7) Page L-001: Item 14, the Planning office would need to sign off on any changes to the landscape plan in addition to the parties listed.
- 8) Identify a consistent name for the building. The renderings list it as “Agricultural Building” and Project is referred to in the plan set as “Agriculture”.

X. RECOMMENDATIONS SUGGESTED AS CONDITIONS OF APPROVAL TO MEET CODE OBJECTIVES:

In accordance with the *Zoning Ordinance*, Article 10 §2.2, the Planning Commission in considering and acting upon Site Development Plans may prescribe appropriate conditions and safeguards so that the public health, safety, and welfare, the comfort and convenience of the public in general, and the residents of the immediate neighborhood in particular shall be taken into consideration. These safeguards may to the maximum extent possible further the expressed intent of the *Zoning Ordinance* and the accomplishment of several objectives in particular listed in subsections 2.21 to 2.28.

Other agencies may recommend additional considerations to meet code objectives in accordance

with their areas of expertise. Action on all considerations identified in this section is at the discretion of the Planning Commission.

XI. ADVISORY COMMENTS TO THE APPLICANT:

- 1) In the event that major changes and revisions to the Site Development Plan occur in the finalization of the Plan contact the Planning Office. Examples include reorientation of the complex/building, relocation of site components like stormwater management areas, and increases in floor area count. These changes may require resubmittal for review by the Development Advisory Committee, Planning Commission, or other agencies and commissions making recommendations in regard to the plan.
- 2) Following Planning Commission approval of the Site Plan, the Plan must be revised to meet all conditions of approval from the Development Advisory Committee or as otherwise noted. A Check Print must be submitted for review by Planning Office Staff and the other commenting agencies. Upon determination that the Plan is complete and all agency approvals have been received, copies of the Plan may be submitted for final endorsement (Final Plan Approval).
- 3) Other agencies and departments which participate in the Development Advisory Committee may provide additional comments related to their areas of expertise and code requirements.
- 4) The applicant/developer shall be aware that prior to any ground disturbing activities on the site the appropriate site inspections, Pre-Construction meeting and permits/licenses are required.
- 5) For building new construction, the requirements of the building code and the fire code must be complied with. Consult with the Chief Building Inspector and City of Dover Fire Marshal for these requirements. The resolution of these items may impact the site design including such items as building dimensions and height, building openings, and fire protection needs, etc.
- 6) The applicant should be aware that Site Plan approval does not represent a Sign Permit, nor does it convey permission to place any sign on the premises. Any proposed site or building identification sign shall require a Sign Permit from the City of Dover prior to placement of any such sign unless deemed internal to the campus. It is recommended that the applicant discuss the sign regulation requirements with the Planning Staff prior to applying for a Sign Permit.
- 7) The applicant should be aware that Site Plan approval does not represent a Building Permit and associated construction activity permits. A separate application process is required for the issuance of a Building Permit from the City of Dover.

If you have any questions or need to discuss any of the above comments, please call the above contact person and the Planning Department as soon as possible.



CITY OF DOVER

DEVELOPMENT ADVISORY COMMITTEE

APPLICATION REVIEW COMMENTARY

STAFF D.A.C. MEETING DATE: SEPTEMBER 27, 2023



APPLICATION: Delaware State University New Agricultural Building at
1200 N Dupont Highway

FILE #: S-23-18

REVIEWING AGENCY: City of Dover Department of Public Works and Water & Wastewater

CONTACT PERSON: Jason A. Lyon, P.E., Director of Water & Wastewater / Engineering Services

CONTACT PHONE #: 302-736-7025

CONTACT PHONE #: jlyon@dover.de.us

THE SUBJECT PROPOSAL HAS BEEN REVIEWED FOR CODE COMPLIANCE, PLAN CONFORMITY AND COMPLETENESS IN ACCORDANCE WITH THIS AGENCY'S AUTHORITY AND AREA OF EXPERTISE.

THE FOLLOWING ITEMS HAVE BEEN IDENTIFIED AS ELEMENTS WHICH NEED TO BE ADDRESSED BY THE APPLICANT:

CITY AND STATE CODE REQUIREMENTS

SANITATION

1. The solid waste service for this property shall remain private.

STORMWATER

1. Final site plan approval will not be granted until a copy of the approved Stormwater/Erosion and Sediment Control Plan from Delaware Department of Natural Resources and Environmental Control (DNREC) is submitted to our office.
2. The size, length, slope, type and flow directions must be shown on all existing and proposed storm sewer lines. Rim and invert elevations must be labeled on all stormwater structures.

STREETS

1. Final site plan approval will not be granted until a copy of the approved entrance plan, signed by DelDOT is submitted to our office.

WATER

1. All water utility components must meet the requirements of the Water Wastewater Handbook, effective date March 22, 2010. Please contact our office for more information.
2. The following notes must be added to the plans:
 - a. Hydrant connections by the contractor are prohibited. This method may not be utilized during any phase of the project.
 - b. Any existing water lines not to be utilized by the proposed facility must be properly abandoned at the mains in accordance with the City of Dover Department of Water & Wastewater specifications and requirements.
 - c. The site contractor shall contact the City of Dover Department of Water & Wastewater Construction Manager at (302) 736-7025 prior to the start of construction. A representative from the City of Dover Department of Water & Wastewater must observe and approve all City owned water and sanitary sewer interconnections and testing. All water taps must be performed by a City of Dover approved contractor. The proposed location for the water connection may need to be adjusted in the field due to conditions of the existing main. Possible conditions that would require tapping relocation include proximity to pipe

joints, other taps, concrete encasements, conflict with other utilities, and the like. Test holes must be performed by the contractor to determine the best tapping location. The City of Dover will not be held responsible for field conditions requiring adjustment of the tapping location or for any work required by the contractor to make an appropriate and lawful connection.

3. The size, type, and location of all proposed and existing water lines and valves must be shown on the plan. Please be advised that effective May 1, 2022, water mains can now be constructed using C900 PVC pipe.
4. Water usage projections (peak demand or plumbing fixtures) must be submitted to our office to correctly determine the size of the domestic and irrigation (if applicable) service line for the proposed building.
5. The domestic service, fire main connection and valves must be clearly shown for each building. A valve must be installed at the tee to isolate combined fire and domestic water service to the building from the water loop. Typically, this valve is installed at the tee or an acceptable distance from the building. A valve must be provided on the domestic water service, which must be tapped off of the combined eight-inch (8") fire/domestic service outside of the building. The domestic water tap and valve should be as close to the building as possible. Typically, the domestic tap and valve are located within five feet (5') to ten feet (10') of the building. A blow up detail of this layout is recommended.
6. Provide a construction detail for the proposed restraining system for the fire main located within the buildings. The Department of Public Works will test and inspect all fire mains to a blind flange located inside the buildings. The blind flange with tap is used for hydrostatic pressure testing (200 psi for two (2) hours) and dechlorination. The flange must be restrained in the direction of the pipe entering the facility. A pipe entering horizontally through a wall sleeve shall be restrained with rods through the wall. A pipe entering vertically through a slab shall be restrained through the floor to the ninety degree (90°) bend and thrust block. All rods shall be a minimum of ¾" all thread. All pipes through walls and slabs must be Class 52 cement lined ductile iron pipe. Confirm particulars to meet this requirement with mechanical designer.
7. Water services shall be either type K copper or SDR-9.
8. All water infrastructure on the property will be owned and maintained by the property owner.

WASTEWATER

1. All wastewater utility components must meet the requirements of the Water Wastewater Handbook, effective date March 22, 2010. Please contact our office for more information.
2. The following notes must be added to the plans:
 - a. Any existing sanitary sewer lines not to be utilized by the proposed facility must be properly abandoned at the mains in accordance with the City of Dover Department of Water & Wastewater specifications and requirements.
 - b. Part II, Chapter 180, Article III, Section 180-10 of the Code of Kent County requires that "no person shall discharge or cause to be discharged any stormwater, surface water, uncontaminated groundwater, roof runoff, subsurface drainage, uncontaminated noncontact cooling water or unpolluted industrial process waters to any sanitary sewer", this shall include condensate. Sec. 110-231 of the City of Dover Code defines storm sewer as "...any system used for conveying rain water, surface water, condensate, cooling water or similar liquid wastes, exclusive of sewage." The contractor, developer, owner and designers shall ensure during construction that no illegal discharges to the sanitary sewer system are created with the site improvements.
3. The size, length, slope, type and flow directions must be shown on all existing and proposed sanitary sewer lines. Rim and invert elevations must be labeled on all sanitary structures.
4. Cleanouts must be installed on sanitary sewer laterals within five feet (5') of the building, one foot (1') outside of the right-of-way and at all bends. Any cleanout located within a traffic bearing location shall be installed with a heavy duty cast iron frame and cover to prevent damage to the cleanout and lateral.
5. Sizing (flow) calculations must be submitted for all sanitary sewer laterals (other than for single-family dwellings) showing that velocity and all other requirements are met.
6. The minimum size of all sanitary sewer laterals shall be six-inch (6").

7. If kitchen facilities are proposed a minimum 1,000 gallon, two chamber grease trap, meeting all Kent County ordinance requirements, must be provided. A construction detail for the proposed grease trap, as well as the proposed location, must be provided on the plan.
8. All wastewater infrastructure on the property will be owned and maintained by the property owner.

GENERAL

1. All existing utilities shall be adjusted to final grade in accordance with current City of Dover requirements and practices. This must be included as a note on the plan.
2. No trees may be planted within ten feet (10') of utility infrastructure.
3. No structure may be installed within ten feet (10') of utility infrastructure, please depict all underground utilities and structures on the utility plan sheet to confirm compliance.
4. The final site plan must be submitted in the following compatible digital formats:
 - a. AutoCAD 2018 (.dwg format).
 - b. Adobe Reader (.pdf format).

RECOMMENDATIONS SUGGESTED AS CONDITIONS OF APPROVAL TO MEET CODE OBJECTIVES

SANITATION / STORMWATER / STREETS / WATER / WASTEWATER / GENERAL

1. None.

ADVISORY COMMENTS TO THE APPLICANT

WATER

1. The City of Dover water system is available to this site. The developer is responsible for all costs associated with extending and providing service to the proposed development.
2. Prior to plan approval, the water system plans must be submitted to the Division of Public Health, Office of Drinking Water for review and approval. The owner/developer will be responsible for providing all completed forms and plan sets to the City of Dover as required for submission to the Office of Drinking Water. Plans will not be submitted to the Office of Drinking Water until review has been completed by our office.
3. Hydrant flow testing is currently only performed during the spring and fall. The applicant must call the Department of Water & Wastewater directly to schedule these tests. This applies to both existing hydrants as well as those proposed for the site.
4. Water impact fees will be required to be paid prior to Certificate of Occupancy for this project.
5. On October 24, 2022, City of Dover Council approved the new Cross Connection Control Program. This program requires certain backflow prevention assemblies on water service connections to the city's distribution system. The city is currently working with Delaware State University to create a plan to handle this requirement directly downstream of the two (2) master meters that feed the campus.

WASTEWATER

1. The City of Dover sanitary sewer system is available to this site. The developer is responsible for all costs associated with extending and providing service and capacity to the proposed development.
2. Prior to plan approval, it may be required to submit the sanitary sewer system plans to the DNREC, Division of Water Resources, Surface Water Discharges Section for review and approval. The owner/developer is responsible for providing all application fees, completed forms and plan sets directly to DNREC.

3. Profiles of the sanitary sewer main must be provided with the construction plans. All water, sanitary sewer and storm sewer crossings must be shown on the profiles.
4. Wastewater impact fees will be required to be paid prior to Certificate of Occupancy for this project.
5. Depending on the effluent flow, the downstream pump station may need to be evaluated by the developer / engineer to verify it can handle the additional effluent flow.

GENERAL

1. The applicant is advised that depending upon the size of the existing water service and sanitary sewer lateral to be abandoned, flowable fill may be required.
2. Construction plans will not be reviewed by our office unless all previous comments have been clearly addressed within the plan set and accordingly identified within an itemized response letter and with the Water/Wastewater Initial Plan Submission Checklist, which can be obtained from the following website: https://imageserv9.team-logic.com/mediaLibrary/198/WaterWastewaterHandbookFinal_1.pdf, page 88.

SANITATION / STORMWATER / STREETS

1. None.

IF YOU HAVE ANY QUESTIONS OR NEED TO DISCUSS ANY OF THE ABOVE COMMENTS, PLEASE CALL THE ABOVE CONTACT PERSON AND THE PLANNING DEPARTMENT AS SOON AS POSSIBLE.

CITY OF DOVER ELECTRIC
DEVELOPMENT ADVISORY COMMITTEE
APPLICATION REVIEW COMMENTARY
STAFF D.A.C. MEETING DATE: SEP 27, 2023

APPLICATION: Delaware State University New Agricultural Building at
1200 N. Dupont Hwy

FILE #: S-23-18

REVIEWING AGENCY: City of Dover Electric Department

CONTACT PERSON: Shawn Burgett, Engineering Services & System Operations Superintendent

CONTACT PHONE #: 302-674-7568

CONTACT EMAIL #: sburgett@dover.de.us

THE SUBJECT PROPOSAL HAS BEEN REVIEWED FOR CODE COMPLIANCE, PLAN CONFORMITY AND COMPLETENESS IN ACCORDANCE WITH THIS AGENCY'S AUTHORITY AND AREA OF EXPERTISE.

THE FOLLOWING ITEMS HAVE BEEN IDENTIFIED AS ELEMENTS WHICH NEED TO BE ADDRESSED BY THE APPLICANT:

CITY AND STATE CODE REQUIREMENTS

ELECTRIC

1. The roadway and curbing must be in.
2. The right-of-way must be within 6" of final grade.
3. The property corners must be staked.
4. Owner is responsible for locating all existing underground electric, communications and water facilities.
5. Owner is responsible for installing all conduits and equipment pads per the City of Dover Engineering Department specifications.
6. Owner is responsible for site and/or street lighting.
7. Meter locations will be determined by City of Dover Engineering Department.
8. Load sheets and AutoCAD compatible DXF or DWG diskettes of site plans, including driveways, are required prior to receiving approved electrical construction drawings.
9. Any relocation of existing electrical equipment will be engineered by the City of Dover Electric Department. Developer may be required to perform a quantity of the relocation. Any work performed by the City of Dover will be at the owner's expense.
10. Prior to construction, owner is responsible for granting an easement to the City of Dover Electric Department. Easement forms will be furnished and prepared by the City of Dover Electric Engineering Department.
11. Fees will be assessed upon final site plans. The owner will be responsible for fees assessed prior to construction. Owner is required to sign off plans prepared by the Electric Department.
12. Must maintain 10' clearance around all electrical equipment, unless pre-approved by the City of Dover Electric Engineering Department.

13. Prior to the completion of any/all designs and estimates, the owner is responsible for providing the Electric Engineering Department with a physical address of the property.
14. All Engineering and design for Dover Electric will be engineered upon final approved plans. All Engineering work will be furnished by the City's Electric Engineering Department.

RECOMMENDATIONS SUGGESTED AS CONDITIONS OF APPROVAL TO MEET CODE OBJECTIVES

ELECTRIC

1. Owner must give the City of Dover Electric Department three (3) months' notice prior to construction. Owner is responsible for following the requirements outlined in the City of Dover's Electric Service Handbook. The handbook is now available on the website at the following link: <https://evogov.s3.amazonaws.com/media/27/media/13108.pdf>.

ADVISORY COMMENTS TO THE APPLICANT

ELECTRIC

1. The City of Dover Electric Department is responsible for electricity up to the primary metering cabinet (1M9) located between Frontage Rd and Highway 13. The University is responsible for the electric past this meter. All other comments on this form should be used as reference only in the event of future changes.
2. Provide load sheets if the new load requirements will change as soon as possible to verify proper sizing of transformers and creation of primary fee estimates. Current load sheets can be found at the following link: <https://www.cityofdover.com/media/Electric%20Department/COD%20Electric%20Load%20Sheet.pdf>.

IF YOU HAVE ANY QUESTIONS OR NEED TO DISCUSS ANY OF THE ABOVE COMMENTS, PLEASE CALL THE ABOVE CONTACT PERSON AND THE PLANNING DEPARTMENT AS SOON AS POSSIBLE.

S-23-18

CITY OF DOVER

DEVELOPMENT ADVISORY COMMITTEE

APPLICATION REVIEW COMMENTARY

D.A.C. MEETING DATE: 09/27/23

C
I
T
Y

O
F

D
O
V
E
R

F
I
R
E

M
A
R
S
H
A
L

APPLICATION: Delaware State University New Agriculture Building at 1200 N DuPont Hwy

FILE #: S-23-18

REVIEWING AGENCY: City of Dover, Office of the Fire Marshal

CONTACT PERSON: Jason Osika, Fire Marshal
josika@dover.de.us

PHONE #: (302) 736-4457

THE SUBJECT PROPOSAL HAS BEEN REVIEWED FOR CODE COMPLIANCE, PLAN CONFORMITY, AND COMPLETENESS IN ACCORDANCE WITH THIS AGENCY'S AUTHORITY AND AREA OF EXPERTISE.

THE FOLLOWING ITEMS HAVE BEEN IDENTIFIED AS ELEMENTS WHICH NEED TO BE ADDRESS BY THE APPLICANT:

CITY AND STATE CODE REQUIREMENTS:

1. Proposed occupancy classification is business.

2. Building Access shall be no further than 50 feet from a primary entrance.

Where buildings are provided with an automatic sprinkler system installed in accordance with NFPA 13, access shall be no further than 100 feet from the primary entrance.
(2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 3.4)

3. Parking shall be prohibited in front of the primary entrance for a width of not less than 1.5 times the width of the door(s) or for 10 feet, whichever is greater.
(2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 6.3.2)

4. Perimeter access shall be 50% and clearly shown on the plans.

Perimeter Access minimum width shall be 10 feet for one-story buildings and 15 feet for buildings of two or more stories, measured from the face of the building at grade with a maximum slope of ten percent (10%). Plantings and utility services (includes condenser units, transformers, etc.) shall be permitted within the perimeter access, and shall not interfere with emergency services fire ground operations.

If a physical barrier (fence, pond, steep slope, etc) prevents access, that portion of the building perimeter shall not be included in the calculation of Percent of Perimeter Access.
(2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 3.5)

Where parking is located between the building and perimeter access area, parking shall not be located closer than 10 feet to the exterior wall for one-story buildings and 15 feet to the exterior wall for building of two or more stories.

5. Fire lanes shall cover 25% of the proposed building.

Fire lanes are required to be 24 feet wide and run along the front of the building as determined by the primary entrance(s). In cases where there is more than one primary entrance(s), each shall be served by a fire lane even if this exceeds the percentage as required.

The closest edge of fire lanes shall not be located closer than ten (10) feet to the exterior wall and the closest edge of fire lanes shall not be located further than 50 feet from the exterior wall if one or two stories in height; 40 feet if three or four stories in height, or 30 feet if over four stories in height. (2021 Delaware State Fire Prevention Regulations, 705, Chapter 5)

6. Where parking is located between the building and the fire lane, parking shall not be located closer than 15 feet to the exterior wall.
(2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 6.4.1)

Where parking is located between the building and the perimeter access area, parking shall not be located closer than 10 feet to the exterior wall for one-story buildings and 15 feet to the exterior wall for building of two or more stories. 2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 3.5.2

7. All Fire Lanes shall be marked as follows:

both the inner and outer edges of the fire lane shall be marked, where curbs are present, the top and face of the curb shall be painted yellow, where no curbs are present, a four inch (4") solid yellow demarcation line shall mark the edge(s) of the fire lane.
(2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 7)

8. The specific color yellow shall be the uniformly accepted yellow as utilized by State of Delaware Department of Transportation (DelDOT). Only vivid and durable paint shall be used and shall be suitable for street surfaces

9. Fire lane signs shall be located as follows:

see Figure 5-16 – Approved Sign For Marking Fire Lanes, fire lane signs shall be spaced at 150 foot intervals maximum, all fire lane signs shall be located no less than six feet (6') and no higher than eight feet (8') above the pavement, signs shall be placed at each end of the fire lane, and signs shall face all oncoming traffic.

Where parking is not restricted roadway markings shall utilize the words "FIRE" and "LANE" in lieu of fire lane signs and shall conform to the specifications of 7.6.
(2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 7)

10. Where overhangs, canopies, balconies, or any other building or site features must project over any fire lane, an unobstructed vertical clearance of not less than 13'-6" above the fire lane shall be provided and the portion of the building perimeter which contains overhangs, canopies, balconies, or any other building features shall not apply towards the fire lane accessibility requirements of Section 4.0, Table 5-1 in this chapter.
(2021 Delaware State Fire Prevention Regulations, 705, Chapter 5, 6.8)
11. Multiple Access Roads shall be provided when a fire department access road (fire lane) is determined by the Fire Marshal to be impaired by vehicle congestion, condition of terrain, climatic conditions, or other factors that could limit access such as placement of fire hose from fire equipment.
12. Street width shall be in accordance with City of Dover Code of Ordinances, Appendix A, Article VII, Section A. 13,

Residential areas

- 24 feet wide with no parking,
- 30 feet wide with parking on one side, or
- 36 feet wide with parking on both sides

Commercial areas

- 26 feet wide with no parking,
- 32 feet wide with parking on one side, or
- 38 feet wide with parking on both sides

Alley

- 12 feet wide

13. Any dead-end road more than 300 feet in length shall be provided with a turnaround or cul-de-sac as outlined in the 2021 Delaware State Fire Prevention Regulations 705, chapter 5, 2.3.
14. Speed Reduction Devices must be approved, please see City of Dover Ordinance Chapter 98-10 in reference to this process.
15. Gated Areas: Fire Department access shall be provided to the property through the use of a system or device approved by the Fire Marshal. The system or device required shall be located in an area accessible to the fire department and approved by the Fire Marshal. All gates shall be either automatic or manual.

An automated system shall consist of one manual and one automated means to open the gate. The owner or their representative shall meet with the Fire Marshal prior to submission to agree on the system. A letter of agreement shall be created and signed by both parties. The letter shall include a detailed description of both the manual and automated means.

A manual gate shall consist of one manual means to open the gate. The owner or their representative shall meet with the Fire Marshal prior to submission to agree on the means to open. A letter of agreement shall be created and signed by both parties. The letter shall include a detailed description of the manual means to open.

To be considered accessible for fire department apparatus the actual clear openings shall be not less than 14 feet, the paved surface through the gate shall be not less than 12 feet, and the gate shall be setback from the perpendicular street by at least 50 feet.

Please contact this office to discuss options available to comply with this requirement.
(2021 Delaware State Fire Prevention Regulations 705, Chapter 5, 2.6)

16. Fire hydrants shall be installed per the requirements of City of Dover Public Utilities Water/Wastewater Handbook, NFPA requirements, and Delaware State Fire Prevention Regulations. City Ordinance Sec 46-9 (f).
5.1.1 Hydrant spacing as shown in the Fire Flow Tables shall be used as a general rule. Hydrants shall be located at the direction of the State Fire Marshal so as to minimize friction in fire hose. All hydrant spacing shall be located along available roads or at the direction of the State Fire Marshal. This measurement shall be calculated by way of accessible thoroughfare(s) from the building to be protected to the hydrant and may not necessarily be a radius. 5.1.3 Additional hydrants shall be provided when the State Fire Marshal deems it necessary based on the configuration of the site, building(s), exposures, construction, occupancy, and/or specific hazard(s).
Fire Flow table 2, hydrant spacing shall be 800 feet on center for one and two family detached dwellings, other residential, rowhouses and townhouses, assembly, health care, business, education, storage, industrial, mercantile, and mini storage. (702, Chapter 6)

NFPA 1

18.5.2 detached one- and two-family dwellings, fire hydrants shall be provided for detached one- and two-family dwellings in accordance with both of the following: 1. the maximum distance to a fire hydrant from the closest point on the building shall not exceed 600 feet 2. the maximum distance between fire hydrants shall not exceed 800 feet.

18.5.3 buildings other than detached one- and two-family dwellings, fire hydrants shall be provided for buildings other than detached one- and two-family dwellings in accordance with both of the following 1. The maximum distance to a fire hydrant from the closet point on the building shall not exceed 400 feet 2. The maximum distance between fire hydrants shall not exceed 500 feet

17. All fire hydrants shall be marked as prescribed within the appropriate section of this regulation and as illustrated by the appropriate figures of this regulation.

All fire hydrants shall have minimum of four-inch (4") solid yellow demarcation lines to define specific areas, where fire hydrants are located along a curb line with permitted parking, the area between the fire hydrant and the street or fire lane shall be stenciled with four inch (4") demarcation lines and the words "NO PARKING", demarcation lines shall be measured from the center line of the fire hydrant and extend for a distance 15 feet on both sides.

Where fire hydrants are located in parking lots or other areas susceptible to blockage by parked vehicles they shall be treated as follows: fire hydrants shall be protected in all directions for a distance of seven feet (7') with barriers or curbing, Minimum four-inch (4") diameter steel bollards filled with concrete and marked yellow shall be installed at the outermost corners of the fire hydrant demarcation area. The minimum height of the bollard shall be 36 inches above the finished grade of the adjacent surface, and the steamer connection of all fire hydrants shall be positioned so as to be facing the edge of the street, or traffic lane.

(2021 Delaware State Fire Prevention Regulations, 705, Chapter 6, 2)

The owner is responsible if the hydrant is private.

18. Hydrant barrels shall be provided with reflective material, such as paint, durable for highway/roadway markings or a reflective tape of a minimum of 2" in width around the barrel under the top flange, hydrant bonnets shall be color coded based on the following criteria: class AA 1500 GPM - painted light blue, class A 1,000 GPM -1499 GPM - painted green, class B 500 - 999 GPM - painted orange, class C 250 - 499 GPM - painted red, class D under 250 GPM - painted black.

(2021 Delaware State Fire Prevention Regulations 703, Chapter 3. 4)

The owner is responsible if the hydrant is private.

19. Hydrants are to be Darling Co. B-62-B Breakaway <https://american-usa.com/products/valves-and-hydrants/fire-hydrants/5-1-4-american-darling-b-62-b-5>

20. NFPA 72 compliant Fire Alarm System required per occupancy code requirements.

Fire alarm in place of assembly. *Fire alarm required.* Any new occupancy or new portion of an occupancy determined to be a place of assembly by the fire marshal and is capable of receiving an occupant load of 75 persons or greater, shall be required to install a fire alarm in accordance with NFPA codes governing the installation of fire alarms and the National Electrical Code.

Fire alarm system required. Any existing occupancy or portion of an existing occupancy determined to be a place of assembly by the fire marshal, and is undergoing renovations in excess of 50 percent of the assessed value of the building and is capable of receiving an occupant load 75 persons or greater or is being enlarged to receive an occupant load of 75 persons or greater, shall be required to install a complete fire alarm system in accordance with NFPA codes governing the installation of fire alarms and the National Electrical Code.

Public mode audible requirements. To ensure that audible public mode signals are clearly heard by occupants of a structure, they shall have a sound level at least 15 decibels (dB) above the average ambient sound level or five decibels (dB) above the maximum sound level having a duration of at least 60 seconds, whichever is greater, measured five feet (1.5m) above the floor in the area required to be served by the system using the A-weighted scale dBA. In the event the stated requirement cannot be met a shunt trip relay/switches shall be the approved method of meeting the intent of this section of the Code.
(City Code of Ordinances 46-171)

21. Sprinkler system required. System is to be monitored by an approved Fire Alarm System.

This chapter shall apply to all buildings, structures, marine vessels, premises, and conditions which are modified by more than 50% after the effective date of these Regulations. The 50% figure shall be calculated utilizing the gross square footage of the building, structure, marine vessel, premises and conditions as to arrive at the correct application.

Any proposal that is presented to the Office of the State Fire Marshal for review and approval for a building rehabilitation as defined in the 101 Life Safety Code, for less than 50% of the gross square footage of a non-sprinklered building, may not have another such project for the same building submitted for review and approval any sooner than three (3) years after the date of the final inspection unless sprinkler projection is provided throughout the entire building.

In all buildings exceeding 10,000 square feet of aggregate, gross floor area.

In all buildings in excess of 40 feet in height or more than four (4) stories in height.

In all buildings or areas thereof used for the storage, fabricating, assembling, manufacturing, processing, display or sale of combustible goods, wares, merchandise, products, or materials when more than two (2) stories or 25 feet in height.

In all basement areas exceeding 2,500 square feet floor area.

In residential occupancies when of: Type V (0,0,0) or Type III (2,0,0) construction and exceeding two (2) stories or 25 feet in height. Type V (1,1,1) and Type III (2,1,1) or

Type IV (2,H,H) construction exceeding three (3) stories or 3In all residential apartment buildings storage areas except individual unit closets that are located within individual residential living units.

In all buildings used as health care occupancies as defined in the Life Safety Code, NFPA 101, as adopted and/or modified by these Regulations. In all buildings or areas classified as "high hazard" under the Life Safety Code, NFPA 101, or "extra hazard" under the Standard for the Installation of Sprinkler Systems, NFPA 13, as adopted and/or modified by these Regulations.

All buildings used as dormitories, in whole or in part, to house students at a public or private school or public or private institution of higher education. (16 Del.C. Ch. 88) This applies to all such dormitories regardless if new or existing.

(2015 State of Delaware fire Prevention Regulations, 702, Chapter 4)

Places of assembly shall be sprinklered throughout in accordance with the most recently adopted edition of NFPA 13 when the following apply:

All new indoor places of assembly with an occupant load of 150 persons or greater.

Any interior renovations of 50 percent or more to an existing place of assembly with an occupant load greater than 150 persons.

Any additions or increase in interior size to an existing place of assembly that would create an occupant load of 150 persons or greater.

Places of assembly where alcohol is served for consumption on the premises shall be sprinklered throughout in accordance with the most recently adopted edition of NFPA 13 when the following apply:

All new indoor places of assembly with an occupant load of 100 persons or greater and where alcohol will be served for consumption on the premises.

Any interior renovation of 50 percent or more to an existing place of assembly with an occupant load greater than 100 persons and where alcohol will be served for consumption on the premises.

Any additions or increase in interior size to an existing place of assembly which would create an occupant load of 100 persons or greater and where alcohol will be served for consumption on the premises.

New educational occupancies of 5,000 square feet or greater shall be sprinklered throughout in accordance with the most recently adopted edition of NFPA 13.
(City of Dover Code of Ordinances 46-162)

22. Fire Department Connection is to be a 5-inch storz connection on a 30-degree elbow located within 50 feet of main entrance. Access to the Fire Department Connection must be clear unobstructed access as defined by the AHJ.

Fire department connections. Unless otherwise approved by the fire marshal, fire department connections shall be on the street side of the building and shall be located and arranged so that hose lines can be readily and conveniently attached to without interference from any nearby obstructions as defined by the fire marshal's office. Fire department connections shall be a five-inch Storz. Fire department connections shall be within 300 feet of an approved City of Dover Fire Hydrant and within 50 feet of the main entrance of the structure it serves. All fire department connections shall be not less than three feet nor more than five feet in height above finished grade. The fire marshal shall have the authority to require more stringent requirements when deemed necessary. (City of Dover Code of Ordinances 46-162)

23. Parking and/or obstructions shall be prohibited in front of fire department connections for a distance measuring from the center line and extending four feet on both sides.

(2015 Delaware State Fire Prevention Regulations, 705, Chapter 5, 6.3.4)

24. Fire Department Connection to be located within 300 feet of fire hydrant, measured as hose would come off the fire equipment.
25. If there is any type of rack storage, the following will be required: 1) a diagram showing the layout and type of rack system 2) a list and quantity of items being stored 3) a letter from an authorized/licensed fire suppression contractor stating that in rack sprinklers are or are not needed. If in rack sprinklers are not needed, a letter may be requested from an authorized/licensed fire suppression contractor to ensure that the sprinkler system is adequate for the storage presented.
26. All standpipe and sprinkler connections shall be marked as prescribed within the appropriate section of this regulation and as illustrated by the appropriate figures of this regulation. All standpipe and sprinkler connections shall have minimum of four inch (4") solid yellow demarcation lines to define specific areas, Solid yellow demarcation lines shall be measured from the center line of the connection and extend for a distance of four feet (4') on both sides, and where parking is allow between the building and the street or fire lane the solid yellow demarcation lines shall extend from the end of the sidewalk surface to the street or fire lane (Markings shall not be required on the sidewalk surface). All fire department connections (standpipe and sprinkler) shall have a minimum 12" x 18" sign that reads FIRE DEPT. CONNECTION, sign lettering shall be a minimum of 3 inches (3") in height with red scotchlite letters on white scotchlite background. The sign shall be clearly visible from the fire lane or roadway, and signs using NFPA international symbols shall be an acceptable alternative. (2021 Delaware State Fire Prevention Regulations, 705, Chapter 6, 3)

27. The installation of natural gas and LP gas meters, regulators, valves, and LP gas bottles shall be protected from impact damage by impact protection. Natural gas and LP gas meters, regulators, and valves located inside structures shall have impact protection, except when located in separate protected utility rooms.

Dimensions of bollards. Bollards shall be a minimum of six-inch diameter filled with concrete. The bollard shall be set into the ground at a depth of at least 36 inches (three ft.) embedded in concrete at a minimum of 18 inches surrounding the bollard. The bollards must be at least 48 inches (four ft.) in height above the finish grade elevation. Any deviation of the stated requirements must be approved by the fire marshal and/or chief building inspector. The above dimensions shall serve as the requirement for installation; however, the fire marshal and/or chief building inspector shall have the authority to require more stringent dimensions to fit the needs of devices warranting impact protection.

Color of bollards. Bollards should be of the following colors; yellow, amber or orange. All colors shall be of fluorescent or have a reflective coating. Any deviation of the stated requirements must be approved by the fire marshal and/or chief building inspector.
(City of Dover Code of Ordinances, 46-4)

28. Every house, building or structure used or intended for use as living quarters or as a place for conducting business, and having any wall facing or abutting any public or private street or alley, shall have displayed on that wall, in legible, easily read characters which are of contrasting color to the background, the proper street number for such house, building, or structure in accordance with the following:

One-family and two-family residential structures, height, the number shall measure a minimum of four inches in height, *location,* the number shall be placed on the house above or to the left or right of the front entrance, *color,* the number shall be contrasting to the background color, *Arabic numerals,* all numbers shall be Arabic numerals.

Multiple-family dwellings, measurements, the number shall measure a minimum of six inches when identifying individual apartments with exterior doors, and 12 inches when identifying buildings with apartment complexes where there are two or more buildings not assigned street addresses. Individual buildings with street addresses shall have numbers measuring six inches, *location,* numbers shall be placed either in the center of the building or on the street end of the building so as to be visible from either the public or private street or from the parking lot, *color,* numbers shall be contrasting to the background color, *Arabic numerals,* all numbers used shall be Arabic numerals.

Commercial, industrial and office buildings, height, the numbers shall measure a minimum of 12 inches in height, *location generally,* numbers shall be placed either in the center of the building or on the street end of the building so as to be visible from either the public or private street or from the parking lot,

property line or driveway, should the building be located far enough from a public or private road so that the numbers are not clearly visible from the street, then the street address shall also be posted on the property at or near the property line or driveway to said building,

color; each building, numbers shall be contrasting to the background color and shall be placed on each building in the complex,

Arabic numerals, all numbers used shall be Arabic numerals,

Shopping centers. Shopping centers consisting of two or more stores shall have a tenant or suite number affixed to the front of the tenant space and on the outside of the rear door which corresponds with that tenant space. Numbers shall measure six inches in height.
(City of Dover Code of Ordinances, 98-344)

29. A lock box (Knox) containing any and all means necessary for fire department access shall be provided at the following occupancies: any occupancy that contains a fire alarm signaling system that is monitored off-site, or any occupancy that contains an automatic sprinkler system.
(2021 Delaware State Fire Prevention Regulations 705, Chapter 5, 2.4)

Secured key systems. When required; exemption. A secured key system shall be required for any new or existing building where a fire alarm or sprinkler system is being installed. It shall be the responsibility of the owner or occupant to keep a set of keys in the secured key box that are current to the locks of the protected occupancy. Buildings with 24-hour staffing or guard service shall be exempt from this subsection.

Location. The secured key system shall be located as close to the main entrance as possible. Should the building design not allow the secured key system to be located by the main entrance, the fire marshal and fire chief shall come to an agreement as to an alternate location for the key box. A secured key system, once installed, shall not be obstructed from view or obstructed by any means that would delay the fire department access to the box.

Required keys. Keys to be secured in the key box shall include keys to all points of ingress or egress, whether on the interior or exterior of the building, and keys to locked mechanical rooms, electrical rooms, elevator rooms, fire alarm and sprinkler controls and any area protected by automatic fire detection. Keys to individual residential apartment units are not required.

Ordering responsibility. It shall be the responsibility of the general contractor to order the key box for new buildings. It shall be the responsibility of the owner or tenant to order the key box for existing buildings.

Installation before testing. No acceptance test for sprinklers or fire alarms shall be conducted before the installation of a key box.
(City Code of Ordinances 46-127)

Knox Box to be mounted 6 feet above ground level

30. All required means of egress shall have an exit discharge consisting of a non-slip surface and leading to and terminating at a public way. NFPA 101
31. Project to be completed per approved Site Plan.
32. Full building and fire plan review is required.
33. Separate building permits/plans submission will be required for each building and/or tenant fit out. If the permit submission is for a "shell" a Certificate of Occupancy will not be issued. Separate plans and permits submissions will be required for each "tenant fit out" at which time a Certificate of Occupancy will be issued upon compliance/completion of each "tenant fit out".

Each "shell" will require a fire permit for sprinkler and fire alarm if applicable. Those systems (for the "shell") must be accepted into service prior to any "tenant fit out" fire permits being issued.

34. Construction or renovations cannot be started until building plans are approved.

35. Fire alarm systems, fire suppression systems, hoods, exhaust ducts, and hood suppression systems require a fire permit from the Fire Marshal's Office. This work cannot be started until the permit is approved.
36. Building cannot be occupied by the public until a Certificate of Occupancy is obtained.
37. The following is City Ordinance, Appendix B-Zoning, Article 8 Enforcement and Penalties:

Section 1. - Building permits.

No building or structure in any district shall be erected or structurally altered without a building permit duly issued upon application to the building inspector. No building permit shall be issued unless the proposed construction or use is in full conformity with all the provisions of this ordinance. Any building permit issued in violation of the provisions of this ordinance shall be null and void and of no effect, without the necessity for any proceedings for revocations or nullification thereof, and any work undertaken or use established pursuant to any such permit shall be unlawful (see section 4 for penalties).

1.1 No building permit shall be issued for the construction or alteration of any building upon a lot without frontage upon, or legal permanent access to, a public street improved to the satisfaction of the planning commission, or without access to a public sewer.

1.2 No building permit shall be issued for any building where the site development plan of such building is subject to approval by the planning commission, except upon approval of such plans approved by the said commission.

1.21 No building permit shall be issued for any building in a subdivision unless the subdivision plot has been approved by the planning commission.

1.3 No building permit shall be issued for a building to be used for any conditional use in any zone where such use is allowed only with approval of the planning commission, unless and until such approval has been duly granted by the said commission.

(Ord. of 7-12-1993, § 3)

ADDITIONAL / SPECIFIC REQUIREMENTS TO OBTAIN APPROVAL:

1. N/A

APPLICABLE CODES LISTED BELOW (NOT LIMITED TO):

2021 NFPA 1 Fire Code (NFPA; National Fire Protection Association)

2021 NFPA 101 Life Safety Code (NFPA; National Fire Protection Association)

2019 NFPA 72 National Fire Alarm and Signaling Code (NFPA; National Fire Protection Association)

2019 NFPA 13 Installation of Sprinkler Systems (NFPA; National Fire Protection Association)

2009 IBC (International Building Code)

Latest editions of all other NFPA Codes as defined by the Delaware State Fire Prevention Regulations

2021 Delaware State Fire Prevention Regulations

City of Dover Code of Ordinances

***If you have any questions or need to discuss any of the above comments, please call the above contact person listed.**

CITY OF DOVER
DEVELOPMENT ADVISORY COMMITTEE
APPLICATION REVIEW COMMENTARY



=====

APPLICATION: Delaware State University New Agriculture Building

FILE#: S-23-18

REVIEWING AGENCY: DelDOT

CONTACT PERSON: Michael Vandevander

PHONE#: 302-760-2141

=====

THE SUBJECT PROPOSAL HAS BEEN REVIEWED FOR CODE COMPLIANCE, PLAN CONFORMITY AND COMPLETENESS IN ACCORDANCE WITH THIS AGENCY'S AUTHORITY AND AREA OF EXPERTISE.

THE FOLLOWING ITEMS HAVE BEEN IDENTIFIED AS ELEMENTS WHICH NEED TO BE ADDRESSED BY THE APPLICANT:

CITY & STATE CODE REQUIREMENTS:

No person, firm, corporation or the like shall construct, open, reconstruct, maintain, modify or use any crossing or entrance onto a state-maintained highway, street or road, including any drainage modifications leading into or carried by the highway drainage system, without first having complied with standards and regulations adopted by the Department and having obtained a permit issued by the Department. Please contact the Delaware Department of Transportation - Development Coordination section to begin permit process.

RECOMMENDATIONS SUGGESTED AS CONDITIONS OF APPROVAL TO MEET CODE OBJECTIVES:

ADVISORY COMMENTS TO THE APPLICANT:

1. A pre-submittal meeting with DelDOT is required to further discuss the project.



STATE OF DELAWARE
**DEPARTMENT OF NATURAL RESOURCES AND
ENVIRONMENTAL CONTROL**

DIVISION OF WATERSHED STEWARDSHIP

ENTERPRISE BUSINESS PARK
285 BEISER BOULEVARD, SUITE 102
DOVER, DELAWARE 19904

CONSERVATION PROGRAMS
SECTION

PHONE: (302) 739-9921
FAX: (302) 739-6724

MEMORANDUM

TO: Dawn Melson-Williams, City of Dover Planning Office

FROM: Elaine Z. Webb, P.E. *EW*
DNREC Sediment and Stormwater Program

DATE: September 28, 2023

SUBJECT: S-23-18 Delaware State University New Agriculture Building

CC: Michael Henry, Becker Morgan Group
Khalid Zerrad, Delaware State University
Bonnie Arvay, Acting Program Manager, Sediment and Stormwater Program

DNREC Sediment and Stormwater Program (SSP) has reviewed the plan provided and offers the following comments:

1. A Sediment and Stormwater Management Plan must be approved by DNREC Sediment and Stormwater Program prior to any land disturbance taking place on site.
2. DNREC SSP has a required three-step plan approval process. The first step is to compile and submit the [Stormwater Assessment Study](#) prior to scheduling a project application meeting, followed by a preliminary and construction level plan submittals. The SSP had a preliminary meeting with the site designer for this project but no formal submittal has been made.
3. If the total land disturbance associated with the project will exceed 1.0 acre, a Notice of Intent (NOI) for Stormwater Discharges Associated with Construction Activity must be secured prior to plan approval. The NOI application is filed online and the NOI fee of \$195 is paid electronically, and is assessed annually until construction is complete and the project is closed out.
4. DNREC SSP recently conducted a maintenance review of existing stormwater management BMPs on the DSU campus and have identified maintenance needs that must be addressed. DNREC SSP will be contacting DSU to review the maintenance needs and establish a path forward for that effort. The New Agriculture Building project does not appear to discharge to any existing stormwater management BMPs and therefore, maintenance of those BMPs will not be tied to this project's approval. However, future projects at DSU may need to consider maintenance requirements on existing stormwater management BMPs.

If you should have any questions, please do not hesitate to contact me at (302) 608-5460 or Elaine.Webb@delaware.gov.