

# Dripping Springs Wastewater Plant Report

Month of November 2025

| Regional      | Combined Flow | Plant TLAP | Caliterra | 210 Reuse | Cl2 residual | NTU  | BOD   | TSS | E-coli |
|---------------|---------------|------------|-----------|-----------|--------------|------|-------|-----|--------|
| Total         | 9287.1        | 2547       | 4331.32   | 2408.78   | >1           | <3   | <5    | <5  | <20    |
| Daily Average | 310.00        | 85.00      | 144       | 80        | 7.89         | 2.41 | 2.125 | 2.5 | 0.259  |


| Arrowhead     | Flow | Cl2 residual | BOD  | TSS  | E-coli |
|---------------|------|--------------|------|------|--------|
| Total         | 1796 | >1           | <10  | <15  | <126   |
| Daily Average | 59   | 7.02         | 2.75 | 11.5 | 90.8   |

| Big Sky       | Flow | Cl2 residual | BOD   | TSS | E-coli |
|---------------|------|--------------|-------|-----|--------|
| Total         | 909  | >1           | <20   | <20 | <126   |
| Daily Average | 30   | 7.84         | 1.025 | 0   | N/A    |

| 210 Reuse     | Fill Station | Sports Park | Founders Park | Village Grove Construction | Total |
|---------------|--------------|-------------|---------------|----------------------------|-------|
| Total         | 228          | 1393        | 464           | 324                        | 2409  |
| Daily Average | 7.6          | 46.44       | 15.45         | 10.8                       |       |

Flow is in 1000's gallons

REGIONAL FLOW DISTRIBUTION



REGIONAL FLOW DISTRIBUTION

