

CoDS Arrowhead/ TPDES Permit No. WQ0014824001

Year :	2024-2025			Month:	November							
	Combined Flow		Effluent				Influent		Phase 1		Phase 2	
Date	Flow Drip S	Combined	BOD (mgl)	TSS (mgl)	e-Coli (cfu)	pH (su)	BOD (mgl)	TSS (mgl)	CL2 (mgl)	Daily Avg Flow (mgd)	Daily Avg Fl	CL2 (mgl)
Daily Avg mgl		1.0 - 4.0	25	40	126	6.0 - 9.0			1.0 - 4.0			1.0 - 4.0
Smpl Frequency		5/wk	1/wk	1/wk	1/qtr	1/mo	2/mo	2/mo	5/wk			5/wk
11/1/2024	0.066	8.8							5.5	0.028	0.038	8.8
11/2/2024	0.053	8.8							6.2	0.023	0.03	7.8
11/3/2024	0.06	8.8							5.3	0.023	0.037	6.4
11/4/2024	0.085	4.7							4.5	0.038	0.047	4.2
11/5/2024	0.072	5.2	0	14	1	7.8	285	134	5	0.033	0.039	2.9
11/6/2024	0.088	8.8							8	0.036	0.052	6.4
11/7/2024	0.074	8.8							8.3	0.029	0.045	8.8
11/8/2024	0.062	4.7							4.8	0.033	0.053	4
11/9/2024	0.058	4.6							4.5	0.044	0.05	3.9
11/10/2024	0.067	4.3							3.6	0.09	0.06	4.4
11/11/2024	0.059	4.1							3.9	0.073	0.043	4
11/12/2024	0.064	7.4	0	16		7.5			8.8	0.041	0.054	8.8
11/13/2024	0.059	7.7							5.5	0.028	0.05	5.2
11/14/2024	0.057	5.1							4.5	0.026	0.053	4.5
11/15/2024	0.046	8.3							4.6	0.038	0.082	8.8
11/16/2024	0.057	8							5.3	0.078	0.052	7.8
11/17/2024	0.054	7.4							5.6	0.136	0.054	7.6
11/18/2024	0.07	6.5							5.1	0.083	0.056	4.8
11/19/2024	0.058	8.6	3	8		7.6	443	332	6	0.103	0.054	8.1
11/20/2024	0.066	8.8							8.8	0.049	0.037	8.8
11/21/2024	0.055	8.8							8.8	0.1	0.067	8.8
11/22/2024	0.063	5.6							7.4	0.066	0.07	6.6
11/23/2024	0.059	8.8							8.8	0.037	0.051	8.7
11/24/2024	0.056	8.5								0.009	0.045	3.5
11/25/2024	0.064	6.3							7.8	0.027	0.041	4.7
11/26/2024	0.057	4.3	1	7		7.7			6.2	0.024	0.031	4.7
11/27/2024	0.054	8.5							1.8	0.033	0.042	8.8
11/28/2024	0.05	8.8							8.8	0.017	0.033	8.8
11/29/2024	0.058	8.8							3.6	0.026	0.038	8.8
11/30/2024	0.047	8.8							8.8	0.02	0.026	4.3
Average	0.061267	7.22	1	11.25	1	7.65	364	233	6.062069	0.046366667	0.047667	6.456667

