

# CoDS Arrowhead/ TPDES Permit No. WQ0014824001

Year : 2024-2025

Month: June

Date	Daily Avg Flow (mgd)	Flow Drip Skid (mgd)	Effluent					Influent		Aeration	
			BOD (mg/l)	TSS (mg/l)	e-Coli (cfu)	CL2 (mg/l)	pH (su)	BOD (mg/l)	TSS (mg/l)	TSS	VSS
Daily Avg mg/l			25.0	40.0	126.0	1.0 - 4.0	6.0 - 9.0				
Smpl Frequency			1/wk	1/wk	1/qtr	5/wk	1/mo	2/mo	2/mo	1/wk	1/wk
6/1/2024	0.073	0.078				7.3					
6/2/2024	0.065	0.066				7.2					
6/3/2024	0.052	0.054				1.9					
6/4/2024	0.049	0.046	6	14	26.9	4.3	7.8	402	372	2730	2030
6/5/2024	0.073	0.074				3.7					
6/6/2024	0.053	0.052				2.2					
6/7/2024	0.064	0.068				2					
6/8/2024						2.3					
6/9/2024		0.059				2					
6/10/2024	0.071	0.074				2.1					
6/11/2024	0.061	0.059	32	34		2.03	7.7			3000	2700
6/12/2024	0.079	0.056				2.1					
6/13/2024	0.074	0.058				2					
6/14/2024	0.065	0.064				3.4					
6/15/2024	0.043	0.052				3.1					
6/16/2024	0.051	0.054				3					
6/17/2024	0.062	0.065				1.2					
6/18/2024	0.058	0.06	11	23		1.4	7.8	595	304	2230	2030
6/19/2024	0.057	0.054				1.6					
6/20/2024	0.068	0.075				1.5					
6/21/2024	0.066	0.069				1.4					
6/22/2024	0.068	0.072				1.5					
6/23/2024	0.072	0.074				1.8					
6/24/2024	0.04	0.037				8.8					
6/25/2024	0.061	0.062	4	13		8.8	7.6			3120	2760
6/26/2024	0.059	0.06				1.6					
6/27/2024	0.054	0.056				4.1					
6/28/2024	0.054	0.056				1.6					
6/29/2024	0.072	0.072				4.3					
6/30/2024	0.066	0.057				7.6					