

Feb-24								Effluent							
Day	Rain	Flow	Drip meter	Reuse meter	Combine	Chlorine	NTU	Solids	TVSS	BOD	TSS	E-coli	Ph	DO	Temp
1	0	295	122	197.2	319.2	5.66	2.19								
2	0	308	114	114.4	228.4	5.64	2.36								
3	0.75	317	129	83.1	212.1	6.05	2.42								
4	0	276	115	185.7	300.7	6.26	2.32								
5	0.03	288	99	12.2	111.2	4.93	2.83			4		1			
6	0	280	135	192.8	327.8	5.11	2.67	6300	5400	3	1	1	7.7	9.4	17.4
7	0	275	116	94.6	210.6	4.17	3.23								
8	0	276	110	185.3	295.3	5.92	3.12								
9	0	278	139	99.8	238.8	8.51	-								
10	0.47	283	107	140.2	247.2	8.57	3.48								
11	0	311	100	178.3	278.3	8.16	3.24								
12	0.03	260	80	5.3	85.3	5.63	2.62			3		1			
13	0	314	135	208.7	343.7	7.16	2.88	6650	5650	3	1	ND			
14	0	279	95	170.8	265.8	5.74	2.33								
15	0	283	106	94.4	200.4	4.97	2.07								
16	0	285	104	82.5	186.5	5.41	2.12								
17	0	292	117	145.8	262.8	6.19	2.27								
18	0	279	109	157.3	266.3	6.62	1.68								
19	0	273	92	1.4	93.4	5.03	1.73			2		7.9			
20	0	305	114	196.6	310.6	5.79	1.92	6400	5700	0	1	1			
21	0	284	117	144.9	261.9	7.2	2.11								
22	0	257	111	125.5	236.5	6.43	2.31								
23	0	292	111	22.5	133.5	2.28	2.28								
24	0	306	113	186	299	-	-								
25	0	281	105	128.4	233.4	-	-								
26	0	282	113	164.1	277.1	4.77	1.99			3		1			
27	0	284	38	114.7	152.7	6.61	1.98	5550	4800	3	1	4.1			
28	0	316	49	167.1	216.1	8.06	1.9								
29	0	300	134	216.6	350.6	3.49	1.84								
30															
31															
TOTAL		8359	3129	3816.2	6945.2										
AVG		288.2414	107.896552	131.5931034	239	5.94	2.38	6225		2.625	1.000	1.644	7.700	9.400	17.400
MIN		257	38	1.4	85.3	2.28	1.68	5550		0.000	1.000	1.000	7.700	9.400	17.400
MAX		317	139	216.6	350.6	8.57	3.48	6650		4.000	1.000	7.900	7.700	9.400	17.400

