

## **Dundee Fire and Rescue Department**

## **Fire Safety Inspection**

118 Merrill Ave. Dundee, FL 33838

Office Phone: (863) 419-3104

## **Fire Inspection Inspection Result**

**Status**Completed with failures

**Inspected by**Joseph Carbone

**Completed at** 12/05/2022 11:50

<b>Business Address Suite</b>	City	State	Zip
202 E MAIN ST	DUNDEE	FL	33838
	<b>Business Name</b>	Building Type	
	Town Hall	(1549	- Library Public)

Next inspection scheduled to be conducted on or after 12/05/2023.

Item	Result	Remarks
Is a light-weight roof (R), floor (F), or roof-floor (RF) sign posted, if applicable?	Fail	Light Weight truss signs are required to be displayed at entry points to the building.

Item	Result	Remarks
Electrical Other	Fail	The use of extension cords must be removed within 90 days in accordance with NFPA 10.3.3.1

Inspection #DF-2022-0000003

## **Inspection Signatures**

Occupancy Contact Signature
Unable to sign:

Not present

**Inspector Signature** 

Jon Vice Business 863-514-6636 jvice@townofdundee.com