

Mission:

To protect, promote & improve the health of all people in Florida through integrated state, county & community efforts.



Ron DeSantis
Governor

Joseph A. Ladapo, MD, PhD
State Surgeon General

Vision: To be the **Healthiest State** in the Nation

October 27, 2022

Notification of Acceptance of Use of a General Permit

Permittee:

Town of Dundee
Tracy Mercer, Interim Public Services Dir.
PO Box 1000
Dundee, FL 33838
tmercerc@townofdundee.com

Permit Number: 136414-086

Issue Date: October 27, 2022

Expiration Date: October 26, 2027

Project Name: WH to Dundee Interconnect –
Dundee Side (Main to Riner WTP)

Water Supplier: Town of Dundee

PWS ID: 6530485

Dear Ms. Mercer:

On October 10, 2022 the Florida Department of Health Environmental Engineering received a “*Notice of Intent to Use the General Permit for Construction of Water Main Extensions for PWSs*” [DEP Form No. 62-555.900(7)], under the provisions of Rule 62-4.530 and Chapter 62-555, Florida Administrative Code (F.A.C.). The proposed project includes installation of 12-inch water main to supply water from the distribution system of PWS 6531992 (City of Winter Haven) to the Town of Dundee Riner WTP (PWS 6530485) (640 LF – 12-inch)

Project Location: State Road 542 (Dundee Road) approximately one quarter of a mile east of US Route 27 in Dundee, FL.

Based upon the submitted Notice and accompanying documentation, this correspondence is being *sent* to advise that the Department does not object to the use of such general permit at this time. Please be advised that the permittee is required to abide by Rule 62-555.405, F.A.C., all applicable rules in Chapters 62-4, 62-550, 62-555, F.A.C., and the General Conditions for All General Drinking Water Permits (found in 62-4.540, F.A.C.).

The permittee shall comply with all sampling requirements specific to this project. These requirements are attached for review and implementation.

Pursuant to Rule 62-555.345, F.A.C., the permittee shall submit a certification of construction completion [DEP Form No. 62-555.900(9)] to the Department and obtain approval, or clearance from the Department before placing any water main extension constructed under this general permit into operation for any purpose other than disinfection or testing for leaks.

**Florida Department of Health
in Polk County**

ENVIRONMENTAL HEALTH DIVISION
2090 East Clower Street • Bartow, FL 33830-6741
PHONE: (863) 519-8330 • FAX: (863) 534-0245
www.MyPolk.Flhealth.gov



www.FloridaHealth.gov

TWITTER: HealthyFLA
FACEBOOK: FLDepartmentofHealth
YOUTUBE: fldoh
FLICKR: HealthyFla
PINTEREST: HealthyFla

Florida Health: the first accredited public health system in the U.S.

Within 30 days after the sale or legal transfer of ownership of the permitted project that has not been cleared for service in total by the Department, both the permittee and the proposed permittee shall sign and submit an application for transfer of the permit using Form 62-555.900(8), F.A.C., with the appropriate fee. The permitted construction is not authorized past the 30-day period unless the permit has been transferred.

This permit will expire five years from the date of issuance. If the project has been started and not completed by that time, a new permit must be obtained before the expiration date in order to continue work on the project, per Rule 62-4.030, F.A.C.

Should you have any questions, please contact me at (863) 578-2019, or by email at Gerald.Robinson@flhealth.gov

Sincerely,

A handwritten signature in cursive script that reads "Gerald Robinson".

Gerald Robinson, P.E.
Professional Engineer III

Cc: Bryan M. Martin, P.E. – Chastain-Skillman, Inc. - bmartin@chastainskillman.com
April D. Breton - SWFWMD - April.Breton@swfwmd.state.fl.us

File Copy: Town of Dundee

Instructions for Clearing Water Mains

To obtain a clearance from this office, the following items must be submitted to the Department:

1) Clearance Form

Submission of a fully completed Department of Environmental Protection (DEP) Form 62-555.900(9) “*Certification of Construction Completion and Request for a Letter of Clearance to Place a Public Drinking Water Facility into Service.*”

2) Bacteriological Results

Copies of satisfactory bacteriological analyses taken from locations within the distribution system or water main extension to be cleared, in accordance with Rules 62-555.315 (6), 62-555.340 and 62-555.330, F.A.C. and American Water Works Association (AWWA) Standard C 651-92 as follows:

- *The endpoint of the proposed addition;*
- *Any water lines branching off a main extension;*
- *Every 1,200 feet of water main;*
- *Each location shall be sampled on two separate days (at least 6 hours apart) with sample point locations and chlorine residual readings **clearly indicated** on the report and/or drawings.*
- *Bacteriological sample results will be considered unacceptable if the tests were completed more than 60 days before the Department receives the results.*

Modifications

The permittee shall **submit written notification** to the Department before making modifications to the permitted project. The permittee may begin such changes seven days after providing notification unless they are advised otherwise by the department. Notification must include (a) *description of the scope and purpose*, (b) *location of the change*, and (c) assurance that the changes will comply with applicable requirements.

For further clarification contact:

Gerald Robinson, P.E.
2090 East Clower Street, Bartow FL 33830
(863) 578-2019
Gerald.Robinson@flhealth.gov