



TOWN COMMISSION MEETING

December 12, 2023 at 6:30 PM

AGENDA ITEM TITLE:	RESOLUTION 23-32, EMERGENCY PURCHASE RINER WATER PLANT
SUBJECT:	Town Commission will consider Resolution 23-32 for and emergency purchase from Southern Corrosion
STAFF ANALYSIS:	Water ground storage tanks need to be inspected every five years to help maintain good water quality, and to help extend the life of the tank. Cleaning and repairs should be addressed based on the findings of the tank inspection. Town's most recent storage tank inspections are documented with pictures in the compliance areas. In accordance with these inspections, the Health Department has advised staff of needed repairs to be made to continue functioning as the internal system was designed and other repairs that are required to be fixed immediately. Additionally, there are some cracks that will need to be reviewed by a structural engineer.
FISCAL IMPACT:	TBD
STAFF RECOMMENDATION:	Staff recommends approval
ATTACHMENTS:	Resolution 23-32 Agreement