

Exhibit "A"

24 CFR PART 8

SELF EVALUATION - TRANSITION PLAN

LOCALITY NAME: TOWN OF EATONVILLE

A. List structures (facilities) in which programs and activities are conducted. (Particularly where public meetings are held)

B. Determine if there are physical barriers to program participation? YES or NO.

STRUCTURES	1. Access Route	2. Outside walks	3. Parking	4. Curb cuts	5. Ramps	6. Ext. doors	7. Int. doors	8. Elev.	9. Lifts	10. Restrooms	11. Fountains	12. Warn-signal	13. Assem-areas	14. Tele-phones	NEEDED CHANGES
TOWN HALL	No	No	No	No	No	No	Yes	N/A	N/A	Yes	No	No	Yes	N/A	1. Need plumbing shields on exposed plumbing under restroom sinks 2. Need rear grab bar behind handicap commode. 3. Need ADA compliant restroom signs with braille at proper height and location 4. Need lever door knobs throughout interior
LIBRARY	No	No	No	No	No	No	No	N/A	N/A	No	No	Yes	No	N/A	1. Need ADA compliant restroom signs with braille at proper height and location
POST OFFICE	No	No	No	No	No	Yes	No	N/A	N/A	N/A	N/A	Yes	No	N/A	1. Need ADA compliant doorknob to rear exterior ADA entrance door

Resolution # _____ Date Approved: _____

Exhibit "A"

**24 CFR PART 8
SELF EVALUATION - TRANSITION PLAN
Page #2**

LOCALITY NAME: TOWN OF EATONVILLE

- A. List structures (facilities) in which programs and activities are conducted. (Particularly where public meetings are held)
 B. Determine if there are physical barriers to program participation? YES or NO.

STRUCTURES	1. Access Route	2. Outside walks	3. Parking	4. Curb cuts	5. Ramps	6. Ext. doors	7. Int. doors	8. Elev.	9. Lifts	10. Restrooms	11. Fountains	12. Warn-signal	13. Assem-areas	14. Tele-phones	NEEDED CHANGES
POLICE DEPARTMENT	Yes	Yes	No	No	No	No	No	N/A	N/A	Yes	No	No	No	N/A	1. Need level transition from the parking lot to entrance sidewalk
DENTON JOHNSON CENTER	No	No	Yes	No	No	No	No	N/A	N/A	Yes	Yes	Yes	No	N/A	1. ADA parking needs to be restriped 2. Needs an ADA compliant stall in each bathroom to include commode and grab bars 3. Need ADA compliant restroom signs with braille at proper height and location 4. Need plumbing shields on exposed plumbing under restroom sinks 5. Water fountain needs to be lowered to accessible height.

Exhibit "A"

**24 CFR PART 8
SELF EVALUATION - TRANSITION PLAN
Page #3**

LOCALITY NAME: TOWN OF EATONVILLE

- A.** List structures (facilities) in which programs and activities are conducted. (Particularly where public meetings are held)
B. Determine if there are physical barriers to program participation? YES or NO.

STRUCTURES	1. Access Route	2. Outside walks	3. Parking	4. Curb cuts	5. Ramps	6. Ext. doors	7. Int. doors	8. Elev.	9. Lifts	10. Restrooms	11. Fountains	12. Warn-signal	13. Assem-areas	14. Tele-phones	NEEDED CHANGES
DENTON JOHNSON PARK.	No	No	No	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No	N/A	1. Need ADA compliant hard surface access route to all venues to include playground
MUNICIPAL POOL	Yes	Yes	Yes	No	No	No	No	N/A	No	Yes	N/A	Yes	No	N/A	1. Need ADA compliant hard surface parking to include signs and striping. 2. Need ADA compliant hard surface access route from parking to venue 3. Need ADA compliant restroom signs with braille at proper height and location at interior bathroom entrances and on exterior bathroom entrances from pool area

Exhibit "A"

**24 CFR PART 8
SELF EVALUATION - TRANSITION PLAN
Page #4**

LOCALITY NAME: TOWN OF EATONVILLE

- A.** List structures (facilities) in which programs and activities are conducted. (Particularly where public meetings are held)
B. Determine if there are physical barriers to program participation? YES or NO.

STRUCTURES	1. Access Route	2. Outside walks	3. Parking	4. Curb cuts	5. Ramps	6. Ext. doors	7. Int. doors	8. Elev.	9. Lifts	10. Restrooms	11. Fountains	12. Warn-signal	13. Assem-areas	14. Tele-phones	NEEDED CHANGES
MUNICIPAL POOL (CONT.)	Yes	Yes	Yes	No	No	No	No	N/A	No	Yes	N/A	Yes	No	N/A	4. Need pull knobs on interior side of bathroom doors leading to building foyer
FRANCES JERRY COMMUNITY PARK	No	No	No	No	No	N/A	N/A	N/A	N/A	N/A	N/A	N/A	No	N/A	No Changes Needed
ELIZABETH PARK	Yes	Yes	Yes	Yes	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Yes	N/A	1. Need ADA compliant hard surface parking to include signs and striping. 2. Need ADA compliant hard surface access route from parking to all park venues

Exhibit "A"

**24 CFR PART 8
SELF EVALUATION - TRANSITION PLAN
Page #5**

LOCALITY NAME: TOWN OF EATONVILLE

- A.** List structures (facilities) in which programs and activities are conducted. (Particularly where public meetings are held)
B. Determine if there are physical barriers to program participation? YES or NO.

STRUCTURES	1. Access Route	2. Outside walks	3. Parking	4. Curb cuts	5. Ramps	6. Ext. doors	7. Int. doors	8. Elev.	9. Lifts	10. Restrooms	11. Fountains	12. Warn-signal	13. Assem-areas	14. Tele-phones	NEEDED CHANGES
HUNGERFORD LAKE PARK	Yes	Yes	Yes	Yes	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	Yes	N/A	1. Need ADA compliant hard surface parking to include signs and striping. 2. Need ADA compliant hard surface access route from parking to all park venues

Exhibit "A"

24 CFR PART 8
SELF EVALUATION - TRANSITION PLAN
Page #6

LOCALITY NAME: TOWN OF EATONVILLE

C. The schedule for taking steps necessary to make needed changes:

Year 1 –

Town Hall

1. Install ADA compliant plumbing shields to exposed plumbing under bathroom sinks
2. Install ADA compliant bathroom signs

Library

1. Install ADA compliant bathroom signs at proper location and height

Denton Johnson Center

1. Restripe Handicap Parking Spaces
2. Install ADA compliant bathroom signs at proper location and height
3. Install ADA compliant plumbing shields to exposed plumbing under bathroom sinks

Municipal Pool

1. Install ADA compliant bathroom signs at both interior and exterior entrances

Year 2 –

Town Hall

1. Install ADA compliant rear grab bars behind handicap accessible commodes
2. Replace all round doorknobs throughout interior with lever style knobs

Post Office

1. Install ADA compliant lever doorknob to handicap entrance

Police Department

1. Repair transition from parking lot to sidewalk so it is level

Resolution # _____ Date Approved: _____

Exhibit "A"

24 CFR PART 8
SELF EVALUATION - TRANSITION PLAN
Page #7

LOCALITY NAME: TOWN OF EATONVILLE

C. The schedule for taking steps necessary to make needed changes (continued):

Year 2 (continued) –

Denton Johnson Center

1. Install ADA compliant handicap accessible bathroom stalls to include proper ADA compliant, commodes, sinks and grab bars.
2. Reinstall ADA compliant water fountain at proper height, existing fountain height is too high.

Denton Johnson Park

1. Install hard surface access route to all venues to include playground entrance

Municipal Pool

1. Install ADA compliant hard surface parking with striping and sign
2. Install hard surface access route from parking to walkway
3. Install ADA compliant handles to rear side of bathroom doors leading from building foyer

Elizabeth Park

1. Install ADA compliant hard surface parking with striping and sign
2. Install hard surface access route from parking to all venues

Hungerford Lake Park

1. Install ADA compliant hard surface parking with striping and sign
2. Install hard surface access route from parking to all venues

Resolution # _____ Date Approved: _____

Exhibit "A"

**24 CFR PART 8
SELF EVALUATION - TRANSITION PLAN
Page #8**

LOCALITY NAME: TOWN OF EATONVILLE

D. The official responsible for implementation is: Chief Administrative Officer

E. The person(s) or groups with whose assistance the plan was developed: Fred Fox Enterprises, Inc.

F. This Transition Plan for complying with 24 CFR part 8 was made public by:

1. Posting on bulletin board.
2. Making the public aware of its availability.

DATE APPROVED _____ BY RESOLUTION # _____

Resolution # _____ Date Approved: _____