



HISTORIC TOWN OF EATONVILLE, FLORIDA

TOWN COUNCIL MEETING

JULY 05, 2023, AT 07:30 PM

Cover Sheet

****NOTE**** Please do not change the formatting of this document (font style, size, paragraph spacing etc.)

ITEM TITLE: Approval And Consent Of Emergency Water Main Repair Kennedy Blvd
(Administration-CAO)

TOWN COUNCIL ACTION:

PROCLAMATIONS, AWARDS, AND PRESENTATIONS		Department: ADMINISTRATION (CAO)
PUBLIC HEARING 1ST / 2ND READING		Exhibits: <ul style="list-style-type: none">• CCI Proposal and other quotes• Pictures for Repair• Orange County Emergency Permit
CONSENT AGENDA		
COUNCIL DECISION	X	
ADMINISTRATIVE		

REQUEST: The Public Works & Utilities Department is requesting the Town Council to approve consent of an Emergency Repair Proposal for Kennedy Blvd. (Under Interstate 4)

(Kennedy Blvd. Emergency Water Main Exploratory, Pipe Repair & Road Restoration Proposal)

SUMMARY: On May 16, 2023, after several observations of puddling water under Interstate 4, Public Works Staff determined that there was a water main leak in the area where the I-4 Ultimate Project took place. This being a major thoroughfare in Eatonville shift and emergency measure were implemented. Due to the exploratory work required the identified best course of action was to excavate, expose, locate the damaged pipe section, replace and repair the road. The emergency cause for the normal procurement process to be bypassed to ensure public safety requirements for roadway were met.

Carr and Collier, Inc. (CCI), price proposal for the Kennedy Blvd. Emergency Water Main Repair & Road Restoration Project amount is \$72,483.45. This price includes the exploratory work, pipe repair, and road restoration. The project scope of services is based upon our site visits and other correspondences. This Scope of Work included: Mobilization / General Conditions / Project Management / Supervision Maintenance of Traffic (including plan) / Sawcut Asphalt & Concrete & Remove (as necessary) / Excavate & Expose Existing AC Water Main Sections / Locate Damaged Pipe Section / Relay Exploratory Findings & Proposed Corrective Measures to Eatonville.

RECOMMENDATION: The Public Works & Utilities Department is recommending the Town Council ratify the emergency repair proposal.

FISCAL & EFFICIENCY DATA: The proposal total cost for the watermain pipe replacement project is \$72,483.45. The provided funds will be allocated from the budget line-item Utilities Contingency:400-0536-536-5800.