



JURGENSEN PUMP, LLC
PO Box 256
McGregor, TX 76657

Date	Estimate #
4/8/2024	7094

Phone # 254-932-6251 Fax # 254-932-6770

REGULATED BY THE TEXAS
 DEPARTMENT OF LICENSING &
 REGULATIONS PO BOX 12157
 AUSTIN, TX 78711
 LICENSE #54576

Name / Address
City of Eden P.O. Box 915 Eden, TX 76837

WARRANTY: New well equipment is covered by
 Manufacturer's Warranties and these warranties are
 the responsibility of the Manufacturers.
 LABOR WARRANTY: Is 30-days from
 installation of new well equipment

Project
Well #3 - 125HP

Description	Qty	Cost	Total
Well #3 - 125HP HT Water Temp = 130 F 13" Casing: 0 - 1,494 FT 8" Casing: 1,494 - 3,820 FT SWL = 650 FT PWL = 860 FT Pump Setting = 1,080 FT (6" 8R Pipe) 360 GPM @ 900 FT TDH			
Field Service for Crew with Rig to Pull Well Pump	1	5,000.00	5,000.00
Flowise 7LC - 10 Stage Pump - 360 GPM at 900' TDH	1	8,930.00	8,930.00
8" 150HP 460V 3PH SME Motor, with Heat Exchanger (derated to 125HP due to water temperature)	1	28,830.00	28,830.00
1/2" Break Off Plug for 3-6" Check Valve	2	71.00	142.00
(2) 1/4" Toro Airline	2,200	0.30	660.00
Miscellaneous HTH, Splice Kit, Buckles, Bandit, Tape, Etc.	1	650.00	650.00
Field Service for Crew with Rig to Install / Start-Up Well Pump	1	5,500.00	5,500.00
Note: - Reuse all 6" Pipe - Reuse 250MCM Cable - Reuse 6" check valves			

Quote valid for 30 days!	Subtotal	\$49,712.00
	Sales Tax (0.00)	\$0.00
	Total	\$49,712.00

City of Eden Administrator

From: Chris Browder <chrisb@jurgensenpump.com>
Sent: Wednesday, April 24, 2024 12:55 PM
To: City of Eden Administrator
Subject: Re: Well 3

Priscilla,

The pump and motor have been returned to their factories for evaluation. I doubt very seriously that either one will be covered. It appears that the electrical issues you were having caused serious vibration down hole which caused the unit to fail. That is just my opinion. I am asking for warranty but this will probably need to be filed on your insurance.

As for the first motor, I am still waiting on Franklin for an answer.

Let me know if you want to proceed with the order.

Chris

On Wed, Apr 24, 2024 at 11:54 AM City of Eden Administrator <cityadmin@edentexas.com> wrote:

Good Morning Chris,

I will review the attached, thank you. Is this motor under warranty? Have you heard from the manufacturer regarding the previous motor replaced in Feb 2024?

Respectfully,

Priscilla Aguirre

City Administrator

City of Eden

120 Paint Rock Street

PO BOX 915

Eden, TX 76837

P: 325-869-2211

F: 325-869-5075