

## Staff Report

**Subject:** Approval of Proposal #160132 from Aqua-Aerobic Systems, Inc for replacement equipment needed at the Wastewater Treatment Plant

**Author:** Alison Bruton, Purchasing Agent

**Department:** WWTP

**Meeting Date:** June 6, 2023

**Item Description:** Proposal #160132 from Aqua-Aerobic Systems, Inc for replacement equipment needed at the Wastewater Treatment Plant

**Summary Recommendation:** Staff recommends approval of Proposal #160132 from Aqua-Aerobic Systems, Inc for replacement equipment needed at the Wastewater Treatment Plant

### Executive Summary/Background:

- The effluent disc filter controllers at the WWTP are no longer produced or supported. Should one fail, the filters would the need to be manually operated around the clock.
- This proposal is from the current manufacturer of the existing effluent disc filter system. Using the same manufacturer will avoid a costlier full replacement.
- The total price of the quote is \$35,012.00.

### Alternatives for Commission to Consider

1. Approval of Proposal #160132 from Aqua-Aerobic Systems, Inc for replacement equipment needed at the Wastewater Treatment Plant
2. Deny Quote.

**Recommended Alternative:** 1

**Other Alternatives:** 2

**Department Review:** Finance, EOM, Purchasing

**Funding Source:** Plant Repair funds

**Attachments:** Quote #2022-549153