



McWright, LLC.

Date: April 5, 2024

Job: Effingham County EMS and PW

Address: 285 1st Street Extension Springfield, GA 31329

Owner: Effingham County Board of Commissioners

Change Order Request #9- EMS Trough Change

Reference: RFI Email on 4/2

“All, looking at the NEC section 376.56 splices and taps in metal wireways in allows up to 75% of it's area at a certain point. It looks like we probably meet that even with a slightly larger Polaris fitting for the new addition.

However, this is easy to draw on the computer and say that but when and you look at the difficulty of adding another tap it may be wise to expand the wiring gutter.

I spoke with Michael earlier today and the EC is getting a price to replace the gutter with a larger gutter that would enable a safer installation. I believe that is the best route to follow. This may take some extra time to install but is the better part of valor.

My thoughts.

Kent Gilbreath, CFO, PE
Delta Engineering Group, LLC
A Certified Women's Business Enterprise
3604 C Wheeler Road
Augusta, Ga 30909
Office 706 364-1770 ext 103
Cell 706 495-4904

Scope of Work:

- Change out existing trough at EMS to accommodate new wires and conduits for MTS
- Includes all myers hub and GRS nipples
- New trough to be rain tight
- Labor to demo the existing and install the new trough

Total Add Price-\$2,955.00

McWright LLC

PO Box 903
 Boanire, GA 31005
www.mcwrightconstruction.com

Project:	Effingham County EMS and PW
COR #:	8
Date:	4/4/2024
Description:	EMS trough Change Over
Architect:	DPR

Description	Subcontractor	Notes	Price
labor and materials to demo the existing trough and replace it with a larger trough to better accommodate the new conduits and wiring	Bargeron		\$ 2,586.00

Description	Subcontractor	Notes	Price

Description	Subcontractor	Notes	Price

Totals	Subcontractor(s) Price		\$ 2,586.00
---------------	-------------------------------	--	--------------------

0

Cost Summary	
Subcontractor(s)	\$ 2,586.00
GC General Liability	\$ 71.12
GC Job Overhead Expenses	\$ -
Sub Total	\$ 2,657.12
GC Fee	
GC Fee	\$ 212.57
Sub Total	\$ 2,869.68
Bond Premium Increase	\$ 86.09
Total	\$ 2,955.77



Barger Electric Company, LLC

PO Box 58
10507 Waycross hwy
Screven, GA 31560
Phone: (912) 371-0010
Email: office@bargerelectriccompnay.com

Change Order

C/O Date: 3/25/2024

Quoted to: McWright LLC
PO Box 903

Bonaire, GA 31005

Regarding Job: Effingham EMS&PW/Springfield/G
EMS - 285 1st St Ext
PW - 321 Hwy 119 S
Springfield, GA 31329

C/O Number:	10	Comments
Sequence:	0	Change out existing trough to a larger trough to accomodate new wires & pipes for MTS. This includes myers hubs, GRS nipples,
Owner C/O No:		

Description	Amount
Change out existing trough to a larger trough to accomodate new wires & pipes for MTS. This includes myers hubs, GRS nipples, mounting, disconnecting of cables, taking wires out to remove old trough, installation of new trough & connecting of existing cables.	0.00
Materials -Myers hubs,Threaded nipples,mounting hardware, Rain tight trough & freight.	1,566.00
Labor 3 guys @ 4 hours each x \$85	1,020.00

Original Contract	\$	287,200.00
Previous Change Orders	\$	17,198.79
Revised Contract	\$	304,398.79
Current Change Order	\$	2,586.00
New Contract Total	\$	306,984.79

Authorized by: _____ Date: _____
McWright LLC

Representative: _____ Date: _____
Barger Electric Company, LLC