

Staff Report

Subject: Approval of PO 23-REQ-039 for the purchase of a Sewer Bypass Pump

Author: Alison Bruton, Purchasing Agent

Department: Water/Sewer

Meeting Date: September 4, 2023

Item Description: PO 23-REQ-039 for the purchase of a Sewer Bypass Pump

Summary Recommendation: Staff recommends approval of PO 23-REQ-039 for the purchase of a Sewer Bypass Pump from Synergy Equipment for \$99,527.00

Executive Summary/Background:

- Staff posted a Request for Quotes for the purchase of a trailer mounted sewer bypass pump for the Water/Sewer Department.
- Four quotes were received:
 - MWI Pumps: \$94,678.00
 - Synergy Equipment: \$99,527.00
 - Holland Pump Company: \$108,450.00
 - Technology International, Inc.: \$143,200.00
- The pump spec provided by MWI shows a max TDH of 140 ft. During the question/answer portion of the bid process, the County stated that 170 ft was required. The pump spec for Synergy meets that requirement with a TDH of 175 ft. After a thorough review by EOM staff, they recommend award to Synergy Equipment.

Alternatives for Commission to Consider

1. Approval of PO 23-REQ-039 for the purchase of a Sewer Bypass Pump from Synergy Equipment for \$99,527.00
2. Approval of PO 23-REQ-039 for MWI Pumps in the amount of \$94,678.00
3. Take no action.

Recommended Alternative: 1

Other Alternatives: 2, 3

Department Review: EOM, Purchasing

Funding Source: SPLOST

Attachments:

1. Synergy Equipment PO
2. MWI Pumps PO

