



**CITY OF EVERMAN**  
212 North Race Street Everman, TX 76140  
**STAFF REPORT**

---

**AGENDA TITLE:** Approve expenditure of up to \$104,000 for the repair and replacement of the Shelby Well Pump and associated parts and equipment

**MEETING DATE:** 07/05/2022

**PREPARED BY:** C. W. Spencer

---

**RECOMMENDED ACTION:**

It is recommended that the Everman City Council

**BACKGROUND INFORMATION:**

The Shelby Well Pump has completely malfunctioned and burned up. This pump requires replacement. The Shelby well-site is our largest producing site and is significantly hampering our water production during peak season. The pump has failed and been damaged due to extremely corroded lines. The waterlines should be replaced with the pump in order to assure a long-term solution. Council is being asked to approve this emergency expenditure request. Funding allocation will come at a later time through a budget amendment utilizing any ARPA and Water Reserve Funds available.

**FISCAL IMPACT:**

\$104,000