

Cojak Circle Manhole and Sewer Upgrade



- Project upgrades Cojak Circle manhole and 1200 linear feet of 6 in. sewer line which is undersized.
- Flow from Arbors, Setterfeld, No Le Hace and Cojak Circle cause backups and high levels in manhole.
- Ongoing construction in the Arbors will exacerbate the issue, may result in spills during peak flow events.
- **Total Estimated Cost = \$650,000**

Prioritization Score: New project
"Must Do" Project (Resiliency, Health and Safety)

