



City of Flagler Beach
105 S. 2nd Street
Flagler Beach, Florida 32136
(386) 517 – 2000 ext. 233

ADDENDUM NO. 1

RESPONSE TO INQUIRIES RECEIVED
South Central Water Main Replacement
Bid Number FB-24-1021
City Project No. 570
November 08, 2024

To All Plan Holders:

The following changes, clarifications and additions are hereby made a part of the bidding and contract documents for the above referenced project, and prepared by the City of Flagler Beach as fully and completely as if the same were fully set forth therein.

Response to Questions received at the Pre-bid Meeting and before the deadline of 5:00 p.m. Friday, November 08, 2024

1. What will the Scope be when connecting the existing water service to the new water main?
What should we be providing?

Response: Refer to Pay item 2.14 in specification 01 20 00 and Detail W-3 on plan sheet C-501.

2. Has a geotechnical report been filed for this project?

Response: See specification section 00 31 32.

3. Will the City provide a laydown area in close proximity to the project?

Response: The City has options that are available to use as a laydown yard. Specific locations will be discussed at the preconstruction meeting.

4. Will you require the abandoned water main to be grout filled?

Response: Yes

5. Is there an engineering budget for this project?

Response: Yes, but that is not disclosed.

6. In the bid document it states that bidder needs to submit "Attachment O" which is a List of Proposed Equipment. However, the actual "Attachment O" document is a List of Licenses and Certifications. Can this be clarified?

Response: Attachment "O" should read "List of Licenses and Certifications" in the TOC (Page 5 of 326).

7. Will bid bond forms be provided? Article 8.01 -Bid Security - states that a bid must be accompanied by bid security made payable to Owner in an amount of five (5) percent of

Bidder's maximum Bid price (determined by adding the base bid and all alternates) and in the form of a certified check, bank money order, or a Bid bond (on the form included in the Bidding Documents) issued by a surety meeting the requirements of Paragraphs 6.01 and 6.02 of the General Conditions.

Response: No.

8. Does the city have a preferred method of road closures and detours?

Response: The City does not have a "preferred method" but will discuss with the selected contractor once the project kicks off. Contractor to provide traffic control plan for approval.

9. South 2nd Street is one way going away from the project site. If we close the intersection of Central Ave and 2nd Street, there will be no way for traffic to travel down South 2nd street. Does the city have a preferred method for this scenario?

Response: See response 8 above.

10. Certificate of Corporation is asking for the executed date of the contract. Unsure how to fill this form out since no there is no signed contract date. Please advise? This is on page 15 of the bid docs.

Response: Attached a copy of the Certificate of Corporation and leave page 15 blank the awarded contractor will complete this page.

11. Is this project subject to State Bill SB 674 that went into effect on July 1, 2024?

Response: No

12. Is this project subject to BABAA or any other federal requirement for domestic made products?

Response: No

13. If State of Florida or Federal funds are being used where are those funds coming from?

Response: The funding source is 100% the City of Flagler Beach.

14. What are the depths of Asphalt, base, and subgrade for the open cut/repair base, bid item number 17?

Response: See detail R-8 on sheet C-502.

15. What are the depths of Asphalt, base, and subgrade for the open cut/repair asphalt, bid item number 18 & 6A?

Response: See response 14 above.

16. Can you please provide a geotechnical report for this project?

Response: See response 2 above.

17. Is removal of existing ACP water main, that is to be abandoned, required?

Response: No. Existing ACP is to be cut, capped, and grouted in place once new water main is in service.

18. Is in place grout filling of existing ACP water main, that is to be abandoned, required?

Response: Yes.

19. Are there any limits to the work times or day of week for this project?

Response: See specification section 00 22 13 Item 7.02.

Disclaimer: It is the sole responsibility of bidder to confirm that all addenda have been received prior to submitting bid and acknowledge such in bid documents

END OF ADDENDUM 1