BEFORE THE CODE ENFORCEMENT SPECIAL MAGISTRATE OF THE CITY OF FLAGLER BEACH, FLORIDA

THOMAS T & MONZELL TURNER 1816 S DAYTONA AVENUE FLAGLER BEACH, FL 32136

CITY OF FLAGLER BEACH, FLORIDA, a municipal corporation) ,)	
Petitioner,)	
vs. THOMAS T & MONZELL TURNER, owner,)	CASE NO: <u>EEN24-0024</u>
Respondent.)	

NOTICE OF VIOLATION

Premises:

1816 S DAYTONA AVENUE, FLAGLER BEACH, FL 32136

YOU ARE NOTIFIED that violations of 2015 INTERNATIONAL PROPERTY MAINTENANCE CODE, SECTION 303 SWIMMING POOLS, SPAS AND HOT TUBS: 303.2 ENCLOSURES exist on the premises located at 1816 S DAYTONA AVENUE, FLAGLER BEACH, FL 32136. The premises are more particularly described as follows:

Legal Description: FUQUAY SUBD BLOCK 27 LOT 5 OR BOOK 69 PAGE 507 OR 159 PG 562 OR 354 PG 671 OR 362 PG 922 OR and has Tax Parcel ID # 18-12-32-2750-00270-0050

The condition giving rise to the violation is described as follows:

POOL IS NOT PROPERLY SECURED

You must correct the violations by no later than 5:00 p.m. on the 31st day March, 2024. If the violation is not cured by the time stated above, a hearing will be scheduled before the City's Code Enforcement Special Magistrate. Should you be found in violation at the hearing, the Code Enforcement Special Magistrate has the power, by law, to levy fines of up to \$250.00 per day against your real and personal property for every day the violation continues beyond the date set by the Special Magistrate for compliance. If the violation is corrected and then recurs, this case shall be presented to the Code Enforcement Special Magistrate at the above-stated hearing even if the violation has been corrected prior to the hearing. To clear up this matter please notify this office as soon as the violation is in compliance by calling 386-517-2000 Extension 249.

DATED March 01, 2024

Code Enforcement Officer City of Flagler Beach, Florida

I hereby certify that a copy of the foregoing was delivered by Certified MailTM # 9214 8901 9403 8351 0362 79 March 01, 2024.