



CITY OF
FORESTPARK

City Council Agenda Item

Subject: Discussion and Approval of an Emergency Requisition Associated with the Public Safety Building – Executive Office

Submitted By: James Shelby

Date Submitted: March 26, 2024

Work Session Date: April 1, 2024

Council Meeting Date: April 1, 2024

Background/History:

This emergency requisition is a proposal and recommendation from Grounded Engineering Services based on a geotechnical investigation of undeveloped portions of property associated with the Gillem Public Safety Building, specifically the concrete trash dumpster located at the edge of the parking lot. The geotechnical investigation was in response to the appearance of subsidence / sinkholes on the property in areas that were outside the limits of construction and disturbance for the project. Site Mix Pressure Grouting LLC will inject cement – based, high mobility geotechnical grout through driven injections pipes and into the soils surrounding the concrete trash dumpster pad at the edge of the parking lot to protect it from sinking.

Cost: \$ 15,700.00

Budgeted for: Yes No

Financial Impact: No Financial Impact to General Fund

URA Bond 586-61-3510-54-1300

Action Requested from Council: Approval of an emergency requisition.