

Stephanie Garcia

From: Johnny Davis
Sent: Wednesday, December 11, 2024 3:04 PM
To: Stephanie Garcia
Subject: FW: Language for the Agenda

From: Michael Miller <miller@tealcon.com>
Sent: Wednesday, December 11, 2024 2:53 PM
To: Johnny Davis <buildingdept@fultontexas.org>
Cc: Norman Spears <nspears@rfisd.us>; Mike Nowotny <mnowotny@rfisd.us>; Jamin Welch <jaminwelch@tealcon.com>; Jeromy Schwabe <jeromyschwabe@tealcon.com>
Subject: Language for the Agenda

Agendas item: Discuss/Approve/Disapprove a variance request from the Rockport-Fulton Independent School District for the expansion of the existing fire alarm system at Fulton Elementary School.

Memo: The Rockport-Fulton Independent School District requests a variance for the expansion of their existing Fire Alarm System. NFPA 72 requires voice evacuation technology for audible devices. The current horn/strobe system is not equipped with voice evacuation, and upgrading the existing system to voice evacuation technology would require a full replacement of the existing system, which would put additional burden on the district construction budget and affect the available date of occupancy for the new additions. After discussion with the fire marshal, it is within the authority of the town council to approve a variance if they so choose.



Sincerely,

Michael M. Miller | Vice President
5110-B IH 37 | Corpus Christi, TX 78407
P: 361.882.4825 C: 361.438.8712 F: 361.882.4630

Follow us on Social Media    

Our Mission: To Build Structures and life-long Relationships through integrity, innovation, high-performance and an experienced professional team.

PLEASE SEND ALL INVOICES TO ACCOUNTSPAYABLE@TEALCON.COM