

	to send meter releases to all power providers for Johnstown.	
	Inspection #1	
Name *	Taqueria Rancho Alegre	
Phone Number *	970-506-1102	
Email *		
Address *	2729 8th Ave	
City *	Garden City	
State/Province/Region *	CO	
Date Inspection Is To Be Performed *	12/12/2024	
Permit Number *	Liquor License inspection	Results
Inspection Requested		Correction Required
		Pending
		Pending
		Pending
		Pending
		Pending
Time of Day *		
Additional Comments		
POWER COMPANY		
	Comments:	
	Receptacles above gas meter to be WR and	
	GFCI protected. Extension cords running	
	through ceiling tiles into ceiling.	
	Receptacle under left side counter feeding	
	dishwasher to be GFCI protected, no access	
	to receptacle on right side under counter.	
	Unable to test GFCI receptacle in water	
	closet due to hand dryer obstructing	
	receptacle. Men's bathroom receptacle	
	behind door within 6' of sink to be GFCI	
	protected, assuming same problem in	
	women's bathroom (we had no access)	
	Broken window at south entry. Missing	
	cover plate at receptacle above food	
	window counter outside kitchen.	