



REQUEST FOR SERVICE

Date of Request 1/6/2025 Citizen/Business Name 8th Ave Wing Shack
Time of Request 12 pm Citizen/Business Address 2704 S 8th Ave
Employee Maria Citizen/Business Phone/Email 970-732-2309

| | | |
|--|---|---|
| <input type="checkbox"/> Abandoned Vehicle | <input type="checkbox"/> Sidewalk | <input checked="" type="checkbox"/> Liquor License Renewal Inspection |
| <input type="checkbox"/> Animal Control | <input type="checkbox"/> Sign | <input type="checkbox"/> MMJ Center Renewal Inspection |
| <input type="checkbox"/> Snow Removal | <input type="checkbox"/> Water | <input type="checkbox"/> Code Violation |
| <input type="checkbox"/> Speeding | <input type="checkbox"/> Weeds | <input type="checkbox"/> Occupancy Inspection |
| <input type="checkbox"/> Street Cleaning | <input type="checkbox"/> Trash | <input type="checkbox"/> Water/Sewer Line Break |
| <input type="checkbox"/> Street Light | <input type="checkbox"/> Records | <input type="checkbox"/> Insect/Pest Problem |
| <input type="checkbox"/> Street Patching | <input type="checkbox"/> Traffic Problem | <input type="checkbox"/> Other (Please Describe) |
| <input type="checkbox"/> Parks | <input type="checkbox"/> Drainage Problem | |

Date(s) / Time / Location of Occurrence: _____

Description of Request/Problem/Concern: 8th Ave Wing Shack is on the agenda
for their liquor license renewal on January 21st. Please forward any
concerns or corrections.

Directed To: ProCode

Action Taken: A life safety inspection was performed on January 9th of 2025 for the renewal of a
liquor license. We are going to approve the license renewal, but we are going to require a hard wired
exit light with battery back up be installed above the front door. This installation needs to be
completed in a timely matter.

Date of Action Taken: 01-09-2025 Employee: Eric Weber