



**MEETING TYPE  
STAFF REPORT**

**Agenda Date:** August 14, 2023

**Eric Buckman, City  
Manager:**

**Department:** Water

**Department Head Name:**

Robert Spreitzer

**Presenter:** Robert Spreitzer

**Kim Berry, City Clerk:**

**This form and any background material must be approved by the City Manager, then delivered to the City Clerk by 4:00 PM the Tuesday prior to the Commission Meeting.**

**AGENDA ITEM TITLE:**

Hire Contractor to Rebuild High Service Pump #1

**BACKGROUND:**

The City Water Plant Has 3 high Service pumps each pump is original 1970 water plant equipment; HS # was rebuilt in 2007, HS # 3 was rebuilt in 2004. Pump HS #1 has not been rebuilt and is overdue. Quotes for the rebuild have been obtained from Northern Machine & Repair, Inc. of Escanaba, MI in the amount of \$17,134.62 and Municipal Well & Pump of Waupun, WI in the amount of \$10,380. Northern Machine has done work in the past for both the Water and Wastewater Plants. This would be our first time working with Municipal Well & Pump. We called the Negaunee Ishpeming Water Authority as a reference for Municipal Well and Pump, the Authority has been very satisfied with the service they have received and use them for most of their pump rehabilitation.

**FISCAL EFFECT:**

This project is part of our asset management plan and was budgeted for in the 2023-24 budget.

**SUPPORTING DOCUMENTATION:**

Please see the attached quotes from Northern Machining & Repair, Inc., and Municipal Well & Pump.

**RECOMMENDATION:**

Make motion to hire Municipal Well & Pump to rebuild high service pump as quoted.