

Rob Spreitzer

From: Steve Pollock <SPollock@dornerco.com>
Sent: Tuesday, November 25, 2025 12:56 PM
To: Rob Spreitzer
Cc: Troy Rodman
Subject: WTP Valve & Actuator Options (Dorner RFQ# Q2930msgl
Attachments: Q2930msgl.pdf; z13204.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Good afternoon, Rob and Troy,

Thank you for reaching out and showing me a few of your projects. Attached you will find a quote for replacement of the South Filter Influent Valve and North Filter Valve. Couple of notes:

South Filter Influent Valve:

As discussed, we have given two options- replace just the actuator cost and separate cost for the replacement valve. Please note that we have quoted our services for removal of the actuator and to replace it with the new kinetrol, wire and test. If going with a new valve as well, we want to be honest and say that Northern Machine could likely do this cheaper than we can because they are local. So, the installation of the valve only on the 16” would need to be done by others.

North Filter Valve Assembly:

The valve is well over 20 years old and should be replaced with the actuator, so we’ve quoted this as a valve/ actuator combo. The actuator we’ve quoted is 50 Second speed for full open. The slower speed actuator will be easier and provide less shock to the system when open or shut. This pump does not have a check valve on it, we highly recommend this otherwise with the 25 second or 50 second speed actuator, water has time to back spin the pump. Obviously, with the addition of the check valve, the piping needs to be slightly modified which is why you see a spool piece cost.

Please review some of this information and let me know if you’d like me to modify the quote or go over anything in better detail.

I am hoping to have the Booster Station Quote done for you guys by the end of next week.

Regards,

Steve Pollock |Sales Engineer

c: 262-685-8389 w: 262-932-2100 | spollock@dornerco.com

Shipping: N61W23043 Silver Spring Dr. | Mailing: P.O. Box 189
Sussex, WI 53089-0189



CONFIDENTIALITY NOTICE: THIS E-MAIL TRANSMISSION IS INTENDED ONLY FOR THE USE OF THE INDIVIDUAL OR ENTITY TO WHICH IT IS ADDRESSED, AND MAY CONTAIN INFORMATION THAT IS PRIVILEGED, CONFIDENTIAL AND EXEMPT FROM DISCLOSURE