



City of Gladstone, MI

1100 Delta Avenue
Gladstone, MI. 49837
www.gladstonemi.org

Staff Report

Agenda Date: December 9, 2024

Eric Buckman, City Manager: _____

Department: Wastewater

Department Head Name: Rodney Schwartz

Presenters: Rodney Schwartz

Kim Berry, City Clerk: _____

This form and any background material must be approved by the City Manager then delivered to the City Clerk by 4:00 PM the Tuesday prior to the Commission Meeting.

AGENDA ITEM TITLE: East End Lift Station Pump Replacement Bids

BACKGROUND: The East End Lift Station pumps have been plugging for more than a year and it has been getting progressively worse. The pumps and motors are originals with the pumps being rebuilt. The current layout is with the motors on the floor level and the pumps down in the pit with 17 foot drive shafts. We would like to replace these pumps and motors with Flygt dry pit submersible pumps. We currently have these pumps for our raw sewage and primary effluent pumping.

FISCAL EFFECT: \$\$27,562.00. This is in the wastewater 2024-25 budget.

SUPPORTING DOCUMENTATION: See attached.

RECOMMENDATION: Make a motion to approve the proposed bid price from Flygt-Xylem in the amount of \$27,562.00.