



GRAND RAPIDS PUBLIC UTILITIES COMMISSION AGENDA ITEM

AGENDA DATE: October 30, 2024

AGENDA ITEM: Consider a motion to ratify the procurement contract with Jasper Engineering and Equipment Company for the clamp on flow meter for the WW return activated sludge line for \$9,399.00.

PREPARED BY: Steve Mattson, Water Wastewater Manager

BACKGROUND:

This purchase is a non-budgeted expense due to an unplanned failure of the return activated sludge flow meter. Control of the return activated sludge is an essential part of managing the secondary plant effectively. This purchase is to replace the 25-year-old flow meter on the line to basin A1.

The GRPUC Procurement Policy was followed and the procurement contract is on file.

The vendor's Certificate of Insurance has been verified to meet the contract requirement and is on file.

RECOMMENDATION:

Approve a motion to ratify the procurement contract with Jasper Engineering and Equipment Company for the clamp on flow meter for the WW return activated sludge line for \$9,399.00.