




500 SE Fourth Street • Grand Rapids, Minnesota 55744

WASTEWATER MONTHLY ANALYSIS REPORT May 2025

Wastewater Operations

The Wastewater Treatment Plant (WWTP) met all National Pollutant Discharge Elimination System (NPDES) permit requirements last month while treating 171 million gallons of water removing 99.8% of the Total Suspended Solids (TSS) and 99.4% Biochemical Oxygen Demand (cBOD).




	Design Limits (monthly AVG)	Actual Results
--	--------------------------------	----------------

Primary Plant

Flow (MGD)	13.25	4.2
TSS (Tons/day)	162	24.7
TSS Peak (Tons/Day)	284	52.7

Primary Plant TSS (Tons/day)




Design Limits (monthly AVG)

Actual Results

Secondary Plant


Flow (MGD)	15.25	5.5
cBOD (lbs/Day)	41,300	24,863
Peak cBOD (lbs/Day)	57,350	47,557
Zinc-weekly (ug/L)	418	180
% GRPUC		27.6%

Industrial cBOD to Secondary Plant (Lbs/day)



Zinc-weekly (ug/L)



permit



	Permit Limits (monthly AVG)	Actual Results
--	--------------------------------	----------------

Effluent

TSS (mg/L) – monthly average	30	2.0
cBOD (mg/L) – monthly average	25	3.7
Dissolved Oxygen (mg/L)	>1.0	6.6



Sludge Landfill Operations

- 0.85 million gallons of leachate were hauled last month
- 4200 cubic yards of sludge solids were hauled to the landfill

