

Water Utility



July 24, 2024 Commission Meeting

- Legionella efforts (disinfection planning & communication, water quality monitor).
- Lead Service Line Inventory – SEH.
- Disinfection implementation – started June 24.

GRPU Water– Legionella Update

Health update

- 31 Legionnaires disease cases since April 2023.

Water System and Water Quality Monitoring

- GRPU continues to work with national experts and MDH.
- 4-6 sites of building plumbing samples weekly.
- Mostly non-detects but a few low-level positives found within some building plumbing. Customers notified immediately. All results are shared on GRPU website.
- Testing to continue for foreseeable future at building sites.

Disinfection Update

- Startup was on June 24th.
- Worked through issues throughout the week. Dialed in dosing at the WTP.
- Disinfection residual found throughout the system quickly.
- Have maintained good residual over time.
- Working with MDH on required testing.

