

GRAND RAPIDS  
PUBLIC UTILITIES



*Service is Our Nature*

500 SE Fourth Street • Grand Rapids, Minnesota 55744

## WATER MONTHLY ANALYSIS REPORT July 2025

### Water Operations

The water plant pumped an average of 1.13 million gallons of water per day (MGD) with a peak of 1.30 million gallons during the month which is normal for this time of the year.



Slight uptick in iron after taking aerator offline for repairs. Hardness slightly improved toward the goal. The rest of the water quality analysis was normal for the month as seen in the graphs below.

