

Service is Our Nature

500 SE Fourth Street • Grand Rapids, Minnesota 55744


# WATER & WASTEWATER DEPARTMENT MONTHLY REPORT February 2022 Commission Meeting

### **Safety**


There were no OSHA recordable accidents last month.


#### **WTP Operations**


The water plant pumped an average of 0.90 million gallons of water per day (MGD) with a peak of 1.02 million gallons during last month.




Phone: 218-326-7024 • Fax: 218-326-7499 • www.grpuc.org











### **WWTP Operations**


The Wastewater Treatment Plant (WWTP) met all National Pollutant Discharge Elimination System (NPDES) permit requirements last month. We treated 158 million gallons of water removing 99.4% of the Total Suspended Solids (TSS) and 97.9% Biochemical Oxygen Demand (cBOD).




	Design Limits (monthly AVG)	Actual Results
Primary Plant		
Flow (MGD)	13.25	4.0
TSS (Tons/day)	162	24.1
TSS Peak (Tons/Day)	284	64.8





	Design Limits (monthly AVG)	Actual Results
Secondary Plant		
Flow (MGD)	15.25	5.1
cBOD (lbs/Day)	41,300	33,240
Peak cBOD (lbs/Day)	57,350	47,696
Zinc-weekly (ug/L)	418	240
% GRPUC		23.5%






	Permit Limits (monthly AVG)	Actual Results
<u>Effluent</u>		
TSS (mg/L) – monthly average	30	6.0
cBOD (mg/L) – monthly average	25	20.2
Dissolved Oxygen (mg/L)	>1 0	3 2






### **Sludge Landfill Operations**

- 0.37 million gallons of leachate were hauled last month
- 4,092 cubic yards of sludge solids were hauled to the landfill



## **AMI Water Install Last Month**

We installed 1 water nodes and/or meters in residential routes. We currently have 3487 (99%) active water nodes installed in the system.



# **Projects Performed Last Month**

- Installed Sumotomo blower at WTP
- Rebuilt 5 hp KSP lift station pump
- Rebuilt and installed primary sludge pump 1A

#### **Projects Scheduled for This Month**

- Change out motor on aeration basin mixer A1
- Install air compressor at WTP
- Repair Helen filter for WWT secondary plant EWS system