



GRAND RAPIDS PUBLIC UTILITIES COMMISSION AGENDA ITEM

AGENDA DATE: May 27, 2026

AGENDA ITEM: Consider a motion to ratify the procurement contract with NOS Automation for the Landfill Loadout 2 PLC Upgrade for \$16,500.

PREPARED BY: Steve Mattson, Water/Wastewater Department Manager

BACKGROUND:

This procurement is for an approved Water Wastewater Capital project with a budget of \$36,907. \$0 has been spent to date.

Leachate from the sumps of the open landfill phases 5-8 pump into a 20,000 gallon leachate storage tank. The levels in the sumps, storage tanks, pump controls, flow measurement and loadout of leachate into the tanker is all controlled by the loadout 2 PLC. The existing PLC is beyond its useful life and showing signs of failure. The asset management plan indicates it is due for replacement.

The GRPUC Procurement Policy was followed. Two contractors provide quotes based on the RFQ. NOS Automation was the low quote.

The vendor's Certificate of Insurance has been verified to meet the contract requirement and is on file.

RECOMMENDATION:

Consider a motion to ratify the procurement contract with NOS Automation for the Landfill Loadout 2 PLC Upgrade for \$16,500.