
APPENDIX I

Greeley Municipal Code Chapter Sec. 22-454 is amended as follows (additions indicated by underline; deletions indicated by strikethrough):

Sec. 22-454. International Fire Code adopted.

The International Fire Code, ~~2018~~ 2021 edition, is hereby adopted by reference for the city, except as amended in this chapter, and is hereinafter referred to as the "fire code." The fire code is published by the International Code Council, Inc., 5360 Workman Mill Road, Whittier, CA 90601-2298. The fire code shall establish the minimum requirements consistent with nationally recognized good practice for providing a reasonable level of life, safety and property protection from the hazards of fire, explosion or dangerous conditions in new and existing buildings, structures and premises and to provide safety to firefighters and emergency responders during emergency operations.

Sec. 22-455. Additions, deletions and amendments to fire code designated.

Sections 101.1, 102.3, 102.4, 102.7, 104.1.1, 105.6.32, ~~109.1~~ 111.1, ~~110.4~~ 112.4, ~~111.4~~ 113.4, 903.2.8, 903.3.1.3, 5504.3.1.1.3, 5704.2.9.6.1, 5706.3.1, 5706.3.1.1, 5706.3.1.2, 5706.3.1.3.1, 5706.3.1.3.2, 6104.2.1, ~~and~~ 6104.3.2, Chapter 80, Appendix B and Appendix C of the fire code are hereby enacted as amended, added or deleted to read as set out in sections 22-456 through 22-473.

Sec. 22-462. Section ~~109.1~~ 111.1 amended; appeals process.

Sec. ~~109.1~~ 111.1 of the fire code is amended to read as follows:

~~109.1~~ 111.1 *Appeals process.* All appeals shall first be made in writing to the fire marshal. A subsequent appeal to the fire marshal's decision shall be made in writing to the fire chief. An appeal to the fire chief's decision shall be made in writing to the city construction trades advisory and appeals board. All decisions and findings shall be rendered in writing to the appellant with a duplicate copy filed in the office of the fire marshal. Rulings by the city construction trades advisory and appeals board shall be final.

Sec. 22-463. Section ~~110.4~~ 112.4 amended; violation penalties.

Sec. ~~110.4~~ 112.4 of the fire code is amended to read as follows:

~~110.4~~ 112.4 *Violation penalties.* Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the fire code official, or of a permit or certificate used under provisions of this code, shall be punishable pursuant to chapter 9 of title 1 of this Code. Each day that a violation continues after due notice has been served shall be deemed a separate offense.

Sec. 22-464. Section ~~111.4~~ 113.4 amended; failure to comply.

Sec. ~~111.4~~ 113.4 of the fire code is amended to read as follows:

~~111.4~~ 113.4 *Failure to comply.* Any person who shall continue any work after having been served with a stop-work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be punishable pursuant to chapter 9 of title 1 of this Code.

Sec. 22-465.5. Section 903.3.1.3 amended; NFPA 13D Sprinkler Systems.

Sec. 903.3.1.3 of the fire code is amended to read as follows:

903.3.1.3 NFPA 13D Sprinkler systems. Automatic sprinkler systems installed in one- and two-family dwellings; Group R-3; Group R-4 Condition 1; and townhouses shall **NOT** be permitted to be installed throughout in accordance with NFPA 13D. **When required, automatic residential fire sprinkler systems in one- and two-family dwellings; Group R-3; Group R-4 Condition 1; and townhouses shall be installed throughout in accordance with Section P2904 of the Residential Code.**

Sec. 22-474 – Chapter 80 is amended with the addition of NFPA Standard 855-20: Standard for the Installation of Stationary Energy Storage Systems

The Fire Code is amended by the addition of NFPA Standard 855-20-Standard for the Installation of Stationary Energy Storage Systems

Sec. 22-475 - APPENDIX B added - Fire-Flow Requirements for Buildings.

The Fire Code is amended by the addition of the Appendix B

Sec. 22-476 - APPENDIX C added – Fire Hydrants Locations and Distribution.

The Fire Code is amended by the addition of the Appendix C