# Attachment E JUSTIFICATION OF ADVANCE PAYMENT

SUB-RECIPIENT: City of Green Cove Springs

If you are requesting an advance, indicate same by checking the box below.

[X] ADVANCE REQUESTED
Advance payment of \$ 333,578.12 is requested. Balance of payments will be made on a reimbursement basis. These funds are needed to pay staff, award benefits to clients, duplicate forms and purchase start-up supplies and equipment. We would not be able to operate the program without this advance.

If you are requesting an advance, complete the following chart and line item justification below.

PLEASE NOTE: Calculate your estimated expenses at 100% of your expected needs for 90 days.

Submit Attachment D with the cost share breakdown along with Attachment E and all supporting documentation.

#### ESTIMATED EXPENSES

BUDGET CATEGORY/LINE ITEMS	2020 -2021 Anticipated Expenditures for First Three
(list applicable line items)	Months of Contract
For example ADMINISTRATIVE COSTS (Include Secondary Administration.)	75% of expenditures for the direct purchase of generators and transfer switches
For example PROGRAM EXPENSES	Program Expenses
TOTAL EXPENSES	\$444,770.94

LINE ITEM JUSTIFICATION (For each line item, provide a detailed justification explaining the need for the cash advance. The justification must include supporting documentation that clearly shows the advance will be expended within the first ninety (90) days of the contract term. Support documentation should include quotes for purchases, delivery timelines, salary and expense projections, etc. to provide the Division reasonable and necessary support that the advance will be expended within the first ninety (90) days of the contract term. Any advance funds not expended within the first ninety (90) days of the contract term as evidenced by copies of invoices and cancelled checks as required by the Budget and Scope of work showing 100% of expenditures for the 90 day period shall be returned to the Division Cashier, 2555 Shumard Oak Boulevard, Tallahassee, Florida 32399, within thirty (30) days of receipt, along with any interest earned on the advance.

## **City of Green Cove Spring**

# **Utility Mitigation and Generator Project**

Project # 4337-217 -R

#### Contract #H0297

### **Line Item Justification- Materials**

The City of Green Cove Springs is requesting the amount of \$333,578.12. The monies are 75% of the purchase cost for the generators for the above referenced project number. The City of Green Cove Springs will purchase the switches for each portable and permanent generator with the monies, as well. Obtaining the generators is a crucial need for completion of above referenced project. The City of Green Cove Springs obtain quotes and conducted a cost benefit analysis, from 4 vendors. Documentation of pricing will be attached with advanced pay request.

## Cost Breakdown

The City of Green Cove Springs will purchase ,11 portable and 6 Permanent generators from Yanmar Master Engine Center and Cummins Inc.

- 11 Portable Generators
- 6 Permanent Generators with Automatic Transfer Switches
- Switches for Portable Generators
- Total = \$444,770.94 75% of Total = \$333,578.12

ite									
oject#	October 8, 2020 HMGP Project # 4337-217-R								
prover Name	Velma Noel, FCCM								
bmitted by	Scott Schultz, Asst. Water Utilities Director								
one	(904) 219-7540								
nail	sschultz@greencovesprings.com								
nd Check to (name)	City of Green Cove Springs								
dress	321 Walnut Street								
y/State/Zip	Green Cove Springs, FL 32043								
scription of Purchase		Amount							
portable & 3 permanent g	enerators – Mastry / Yanmar	\$261,576.00 (75%)							
ermanent generators Cu	\$72,002.20 (75%)								
	Total	\$333,578.20							
nedule Description		Date							
eive payment from HMGP		October 31, 2020							
ate and send purchase orc	lers for Mastry and Cummins	November 7, 2020							
nerators received	January 15, 2021								
pices received and final pa	January 30, 2021								
	yment submitted								



Enclosure-Wind Load 180 MPH, ASCE7-10

Skidbase - Housing Ready

UL142 Sub Base Dual Wall Basic, Diesel Fuel Tank, 48 Hour Minimum

Control Mounting - Left Facing

PowerCommand2.3 Controller

Gauge - Oil Pressure

AmpSentryTM UL Listed Protective Relay

Stop Switch - Emergency

Signals - Aux, Input / Output

Control Display Language - English

Load Connection - Single

Circuit Breaker, Location A, 125A - 400A, 3P, LSI, 600 Volts AC, 100%, UL

Circuit Breaker or Terminal Box - Position B (Generator Right Side) - None

Circuit Breaker or Terminal Box - Position C (Generator Right Side) - None

Engine Governor - Electronic, Isochronous

Fuel Water Separator

Low Fuel Level Switch, 40%

Mechanical Fuel Gauge

Switch - Fuel Tank, Rupture Basin

Engine Starter - 12 Volt DC Motor

Engine Air Cleaner - Normal Duty

Battery Charging Alternator

Engine Cooling - Radiator, High Ambient Air Temperature, Ship Fitted

Shutdown - Low Coolant Level

Extension - Coolant Drain

Engine Coolant - 50% Antifreeze, 50% Water Mixture

Coolant Heater

**Engine Oil** 

Quotation: O-162202-Q-03264



Genset Warranty - 2 Years Base

Literature - English

Packing - Skid, PolyBag

Larger Battery Rack

Extension - Oil Drain

Sandstone Sound Level 2 Intake Baffle - Ship Loose

#### 2 OTPC Transfer Switch-Power Command: 400A Station 314

Transfer Switch-Onan, PwrCmd, 400 Amp

Listing - UL 1008 / CSA Certification

Application - Utility to Genset

Cabinet - Type 3R

Poles - 3 (Solid Neutral)

Frequency-60 Hz

System - Single Phase, 2 or 3 Wire

Voltage - 240 Volts AC

Level 1 Transfer Switch Control

Control Panel, Security Key Switch

Display - Digital

Aux Relay - Emergency Position - 12 Volts DC

Aux Relay - Normal Position - 12 Volts DC

Transfer Switch Warranty - Year 0 - 2: Parts, Labor and Travel Year 3 - 5: Parts Only Year 6 - 10: Main Contacts Only

#### 3 C80D6C Genset-Diesel, 60Hz, 80kW Station 315

U.S. EPA, Stationary Emergency Application

Genset-Diesel, 60Hz,80kW

Duty Rating - Standby Power (ESP)

Listing - UL 2200

Quotation: O-162202-Q-03264

Doc Ref: City of GCS Stations 314, 315, & 319 Q-03264-20201001-1301

Page 3 of 14



NFPA 110 Type 10 Level 1 Capable

Emission Certification, EPA, Tier 3, NSPS CI Stationary Emergency

Exciter / Regulator - Permanent Magnet Generator, 3 Phase Sensor

Voltage - 120/208, 3 Phase, Wye

Alternator - 60Hz, 12L, 208 / 120V, 120C, 40C Ambient

Alternator Heater, 120 Volt AC

Aluminum Sound Attenuated Level 2 Enclosure, with Exhaust System

Enclosure Color - Sandstone, Aluminum

Enclosure-Wind Load 180 MPH, ASCE7-10

Skidbase - Housing Ready

UL142 Sub Base Dual Wall Basic, Diesel Fuel Tank, 48 Hour Minimum

Control Mounting - Left Facing

PowerCommand2.3 Controller

Gauge - Oil Pressure

Amp Sentry TM UL Listed Protective Relay

Stop Switch - Emergency

Signals - Aux, Input / Output

Control Display Language - English

Load Connection - Single

Circuit Breaker, Location A, 125A - 400A, 3P, LSI, 600 Volts AC, 100%, UL

Circuit Breaker or Terminal Box - Position B (Generator Right Side) - None

Circuit Breaker or Terminal Box - Position C (Generator Right Side) - None

Engine Governor - Electronic, Isochronous

Fuel Water Separator

Low Fuel Level Switch, 40%

Mechanical Fuel Gauge

Switch - Fuel Tank, Rupture Basin

Engine Starter - 12 Volt DC Motor

Quotation: O-162202-Q-03264



Engine Air Cleaner - Normal Duty

**Battery Charging Alternator** 

Engine Cooling - Radiator, High Ambient Air Temperature, Ship Fitted

Shutdown - Low Coolant Level

Extension - Coolant Drain

Engine Coolant - 50% Antifreeze, 50% Water Mixture

Coolant Heater

Engine Oil

Genset Warranty - 2 Years Base

Literature - English

Packing - Skid, Poly Bag

Larger Battery Rack

Extension - Oil Drain

Sandstone Sound Level 2 Intake Baffle - Ship Loose

#### 4 OTPC Transfer Switch-Power Command: 300A Station 315

Transfer Switch-Onan, PwrCmd, 300 Amp

Listing - UL 1008 / CSA Certification

Application - Utility to Genset

Cabinet - Type 3R

Poles - 3 (Solid Neutral)

Frequency-60 Hz

System - 3 Phase, 3 or 4 Wire

Voltage - 208 Volts AC

Level 1 Transfer Switch Control

Control Panel, Security Key Switch

Display - Digital

Quotation: O-162202-Q-03264

Aux Relay - Emergency Position - 12 Volts DC

Doc Ref: City of GCS Stations 314, 315, & 319 Q-03264-20201001-1301

Page 5 of 14



Aux Relay - Normal Position - 12 Volts DC	
Transfer Switch Warranty - Year 0 - 2: Parts, Labor and Travel Year 3 - 5: Parts Only Year 6 - 10: Main Contacts Only	
Factory Direct Shipment to Customer	1
Factory Direct Shipment to Customer	1
C80D6C Genset-Diesel, 60Hz, 80kW Station 319	1
U.S. EPA, Stationary Emergency Application	
Genset-Diesel, 60Hz,80kW	
Duty Rating - Standby Power (ESP)	
Listing - UL 2200	
NFPA 110 Type 10 Level 1 Capable	
Emission Certification, EPA, Tier 3, NSPS CI Stationary Emergency	
Exciter / Regulator - Perman ent Magnet Generator, 3 Phase Sensor	
Voltage - 120 / 240, 3 Phase Delta	
Alternator - 60Hz, 12L, 240 / 120V, 120C, 40C Ambient	
Alternator Heater, 120 Volt AC	
Aluminum So und Attenuated Level 2 Enclosure, with Exhaust System	
Enclosure Color - Sandstone, Aluminum	
Enclosure- Wind Load 180 MPH, ASCE7-10	
Skidbase - Housing Ready	
UL142 Sub Base Dual Wall Basic, Diesel Fuel Tank, 48 Hour Minimum	
Control Mounting - Left Facing	
PowerCommand2.3 Controller	
Gauge - Oil Pressure	
Amp Sentry TM UL Listed Protective Relay	
Stop Switch - Emergency	
Signals-Aux, Input / Output	

Quotation: O-162202-Q-03264

5



Control Display Language - English

Load Connection - Single

Circuit Breaker, Location A, 70A - 250A, 3P, LSI, 600 Volts AC, 100%, UL

Circuit Breaker or Terminal Box - Position B (Generator Right Side) - None

Circuit Breaker or Terminal Box - Position C (Generator Right Side) - None

Engine Governor - Electronic, Isochronous

Fuel Water Separator

Low Fuel Level Switch, 40%

Mechanical Fuel Gauge

Switch - Fuel Tank, Rupture Basin

Engine Starter - 12 Volt DC Motor

Engine Air Cleaner - Normal Duty

**Battery Charging Alternator** 

Engine Cooling - Radiator, High Ambient Air Temperature, Ship Fitted

Shutdown - Low Coolant Level

Extension - Coolant Drain

Engine Coolant - 50% Antifreeze, 50% Water Mixture

Coolant Heater

Engine Oil

Genset Warranty - 2 Years Base

Literature - English

Packing - Skid, Poly Bag

Larger Battery Rack

Extension - Oil Drain

Quotation: O-162202-Q-03264

 $Sandstone\,Sound\,Level\,2\,Intake\,Baffle\,-\,Ship\,Loose$ 

EnclosureInstallationKit (Arrow)

Circuit Breaker Installation-12VDC Shunt Trip



	Circuit Breaker Installation-1SPDT, Auxiliary Contacts	1
	Battery Charger-10Amp, 120/208/240VAC, 12/24V, 50/60Hz	1
	E STOP BRK Glass NEMA 3 w/ contacts	1
	Factory Direct Shipment to Customer	1
	EnclosureInstallationKit (Arrow)	1
	Circuit Breaker Installation-12VDC Shunt Trip	1
	Circuit Breaker Installation-1SPDT, Auxiliary Contacts	1
	Battery Charger-10Amp, 120/208/240VAC, 12/24V, 50/60Hz	1
	E STOP BRK Glass NEMA 3 w/ contacts	1
	Factory Direct Shipment to Customer	1
	EnclosureInstallationKit (Arrow)	1
	Circuit Breaker Installation-12VDC Shunt Trip	1
	Circuit Breaker Installation-1SPDT, Auxiliary Contacts	1
	Battery Charger-10Amp, 120/208/240VAC, 12/24V, 50/60Hz	1
	E STOP BRK Glass NEMA 3 w/ contacts	1
	Factory Direct Shipment to Customer	1
6	OTPC Transfer Switch-Power Command: 260A Station 319	1
	Transfer Switch-Onan, PwrCmd, 260 Amp	
	Listing - UL 1008 / CSA Certification	
	Application - Utility to Genset	
	Cabinet - Type 3R	
	Poles - 3 (Solid Neutral)	

Quotation: O-162202-Q-03264



Frequency-60 Hz

System - 3 Phase, 3 or 4 Wire

Voltage - 240 Volts AC

Level 1 Transfer Switch Control

Control Panel, Security Key Switch

Display - Digital

7

Aux Relay - Emergency Position - 12 Volts DC

Aux Relay - Normal Position - 12 Volts DC

Transfer Switch Warranty - Year 0 - 2: Parts, Labor and Travel Year 3 - 5: Parts Only Year 6 - 10: Main Contacts Only

Factory Direct Shipment to Customer

1

Service - start up & load bank testing All Stations

3

Grand Total USD 96,002.94

NOTE: Quote Grand Total does not include any tax.

Quotation: O-162202-Q-03264

## **Scott Schultz**

From:

JENSEN Doug (Doug Jensen) <djensen@mastry.com>

Sent:

Wednesday, September 30, 2020 4:06 PM

To:

Scott Schultz

Subject:

**RE: Final Spreadsheet** 

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Confirmed all good

From: Scott Schultz <sschultz@greencovesprings.com>

Sent: Wednesday, September 30, 2020 8:30 AM

To: JENSEN Doug (Doug Jensen) < djensen@mastry.com>

Subject: Final Spreadsheet

Doug:

Please review the attached spreadsheet. This is what I will be sending to HMGP / FEMA. Just want to make sure we have the numbers correct as this will be the amount of the PO.

Scott Schultz Water & Wastewater Utilities City of Green Cove Springs 321 Walnut Street Green Cove Springs, FL 32043 (904) 219-7540

PERMANENT GENERATORS										Transfer	-	
Station # Address	Capacity (kW)	Incoming Electrical Volt (V)	Phase	Main Breaker (AMP)	Mastry quote #	Mastry Model	Mastry KW AMI	DOATING (	COST EA	Switch	COCTEA	The state of the s
305 507 Vermont Ave	30 kW	230 V	single	100 amps	QUO8085	MEC35DSA-Y	35	125	18,700	(COLOGORA)	COST EA	Total Cost
326 3260 US 17 North	30 kW	230 V	three	100 amps	QUO8082	MEC35DSA-Y	35	125	17,830	TS870 NEMA 4 200AMP	4048	22,748
331 3076 Five Oaks Ln Unit 1	30 kW	208 V	three	100 amps	QUO8008	MEC35DSA-Y	35	125	· ·	TS870 NEMA 4 200AMP	4048	21,878
					400000	WIEC33B3A 1	33	123	17,830	TS870 NEMA 4 200AMP	4048	21,878
TRAILER MOUNTED												
										V/Phase Selector SW		
311 Magnolia Lane shopping center	35 kw	208 V	three		QUO8146	MEC35DSA-Y	35	125	21,656	200 AMP	2657	24 212
313 Constancia Dr [Magnolia Pt]	35 kw	208 V	three		QUO8146	MEC35DSA-Y	35	125	21,656	200 AMP		24,313
329 Olympic Dr [Magnolia Pt]	35 kw	208 V	three		QUO8146	MEC35DSA-Y	35	125	21,656	200 AMP	2657	24,313
330 Majestic Oaks Ln Hickory Knolls	35 kw	208 V	three		QU08146	MEC35DSA-Y	35	125	21,656	200 AMP	2657	24,313
316 Cherry Hills Ct [Magnolia Pt]	35 kw	240 V	single		QUO8148	MEC35DSA-Y	35	125	20,545	200 AMP	2657	24,313
320 End of HallPark Rd@Tamko	60 kw	240 V	three		QUO8004	MEC60DSA-JD	60	225			2657	23,202
321 JP Hall Blvd@food Lion Whs	60 kw	240 V	three		QUO8004	MEC60DSA-JD	60		27,912	400 AMP	4367	32,279
324 Wildwood Rd @Pegasus Ind PK	35 kw	240 V	three		QU08152	MEC35DSA-Y		225	27,912	400 AMP	4367	32,279
327 Calico Jack Way -The Cove	35 Kw	230 V	three		QUO8158	MEC35DSA-Y	35	125	21,656	200 AMP	2657	24,313
334 Cypress Wall PL Edgewater Land	35 kw	230 V	three		QU08158		35	125	21,656	200 AMP	2657	24,313
336 Ball Rd Black Creek Village	35 kw	230 V	three			MEC35DSA-Y	35	125	21,656	200 AMP	2657	24,313
			unce		QUO8158	MEC35DSA-Y	35	125	21,656	200 AMP	2657	24,313
Total Cost												
												0.40 -44

PERMANENT GENERATORS

348,768