



ECS Florida, LLC

11554 Davis Creek Court

Jacksonville, FL 32256

T 904.880.0960

F 904.880.0970

FIELD REPORT

Project No. **35:36135**
Report No. **99R**
Day & Date **Thursday 4/9/2026**
Weather °/

Project **Rookery Phase 2B**
Location **Green Cove Springs, FL**
Client **Jax Dirtworks, Inc**
Contractor **Jax Dirtworks, Inc**

Remarks

* Travel time and mileage will be billed in accordance with the contract.

Summary of Services Performed (field test data, locations, elevations & depths are estimates) & Individuals Contacted.

****This report pertains to a site visit conducted on 3/12/26 – REVISED REPORT****

As requested, we arrived on site to perform asphalt coring for thickness tests. Please see the locations and results below:

TARGET THICKNESS=2.00"

Darter Chase Street

Sta. 14+00 RT: Thickness=2.00"

Sta. 16+00 CL: Thickness=2.50"

Sta. 18+00 LT: Thickness=2.00"

Sta. 20+00 CL: Thickness=2.00"

TARGET THICKNESS=1.50"

Little Heron Place

Sta. 15+00 RT: Thickness=2.50"

Sta. 21+00 CL: Thickness=3.00"

Banyon Tree Point

Sta. 11+00 LT: Thickness=2.50"

Sta. 14+00 CL: Thickness=2.00"

Quiet Roost Place

Sta. 11+00 RT: Thickness=2.00"

Sta. 17+00 CL: Thickness=2.00"

Hollow Branch Way

Sta. 11+00 RT: Thickness=2.00"

By J'Dan E Tillman


Sta. 13+00 CL: Thickness=2.00"

Migration Way

Sta. 4+00 RT: Thickness=2.00"

Sta. 8+00 CL: Thickness=2.00"

Thank you for allowing ECS Florida, LLC the opportunity to provide construction materials testing services for this project. Should you have any questions and/or comments, please contact our office.



Christopher M. Egan, P.E.
Assistant Office Manager, Principal

A handwritten signature in cursive script that reads "Kathleen M. Gaal".

Kathleen Gaal
CMT Senior Project Manager