



City of Green Cove Springs
Water Department

WATER SYSTEM PRESSURE AND LEAKAGE TEST

Date: February 10, 2026
Project Number: Graylon Oaks
From: Scott Schultz
Subject: Pressure Test

The subject pressure test was held today at Graylon oaks Subdivision and

[X] Passed [ ] Failed

In addition to myself the following individuals attended:

- 1. Jesse Ryan 4.
2. 5.
3. 6.

Time of Test: Begin 0930 End 1300
Pressure (PSI): Begin 161 End 161

Average PSI 161 [X] Water [ ] Sewer Force Main

Table with 6 columns: Pipe Diameter In Inches, Length of Pipe In Feet, S x D Equals, Number of Hours, Square Root of Pressure, ÷133200. Includes a TOTAL row with NA.

Formula L= S D sqrt(P) Allowable Leakage 0.4 Gal. Oz.
133200

Lost 0 PSI in Two Hours

Required 0 Gal. Oz. To pump back up to original starting pressure.

Name Schultz Signature [Signature]